#### **Deutsches Institut für Bautechnik**

#### Zulassungsstelle für Bauprodukte und Bauarten

#### **Bautechnisches Prüfamt**

Eine vom Bund und den Ländern gemeinsam getragene Anstalt des öffentlichen Rechts

Kolonnenstraße 30 B D-10829 Berlin Tel.: +493078730-0 Fax: +493078730-320 E-Mail: dibt@dibt.de www.dibt.de





Mitglied der EOTA Member of EOTA

## **European Technical Approval ETA-12/0575**

English translation prepared by DIBt - Original version in German language

Handelsbezeichnung Trade name

Capatect WDVS "A" mit Unterputz Capatect Klebe- und Armierungsmasse 186 M

Außenseitiges Wärmedämm-Verbundsystem mit Putzschicht zur

External Thermal Insulation Composite System with rendering for the

Zulassungsinhaber Holder of approval

**CAPAROL** Farben Lacke Bautenschutz GmbH Roßdörfer Straße 50

Wärmedämmung von Gebäuden

use as external insulation of building walls

64372 Ober-Ramstadt **DEUTSCHLAND** 

Zulassungsgegenstand und Verwendungszweck

Generic type and use of construction product

Geltungsdauer: Validity:

vom from

bis

8 January 2013

8 January 2018

Herstellwerk CAPAROL Manufacturing plant

Farben Lacke Bautenschutz GmbH

Roßdörfer Straße 50 64372 Ober-Ramstadt **DEUTSCHLAND** 

Diese Zulassung umfasst This Approval contains

19 Seiten einschließlich 1 Anhang

19 pages including 1 annex





Page 2 of 19 | 8 January 2013

#### I LEGAL BASES AND GENERAL CONDITIONS

- 1 This European technical approval is issued by Deutsches Institut für Bautechnik in accordance with:
  - Council Directive 89/106/EEC of 21 December 1988 on the approximation of laws, regulations and administrative provisions of Member States relating to construction products<sup>1</sup>, modified by Council Directive 93/68/EEC<sup>2</sup> and Regulation (EC) N° 1882/2003 of the European Parliament and of the Council<sup>3</sup>;
  - Gesetz über das In-Verkehr-Bringen von und den freien Warenverkehr mit Bauprodukten zur Umsetzung der Richtlinie 89/106/EWG des Rates vom 21. Dezember 1988 zur Angleichung der Rechts- und Verwaltungsvorschriften der Mitgliedstaaten über Bauprodukte und anderer Rechtsakte der Europäischen Gemeinschaften (Bauproduktengesetz - BauPG) vom 28. April 1998<sup>4</sup>, as amended by law of 31 October 2006<sup>5</sup>;
  - Common Procedural Rules for Requesting, Preparing and the Granting of European technical approvals set out in the Annex to Commission Decision 94/23/EC<sup>6</sup>;
  - Guideline for European technical approval of "External Thermal Insulation Composite Systems with Rendering", ETAG 004, edition March 2000.
- Deutsches Institut für Bautechnik is authorized to check whether the provisions of this European technical approval are met. Checking may take place in the manufacturing plant. Nevertheless, the responsibility for the conformity of the products to the European technical approval and for their fitness for the intended use remains with the holder of the European technical approval.
- This European technical approval is not to be transferred to manufacturers or agents of manufacturers other than those indicated on page 1, or manufacturing plants other than those laid down in the context of this European technical approval.
- This European technical approval may be withdrawn by Deutsches Institut für Bautechnik, in particular pursuant to information by the Commission according to Article 5 (1) of Council Directive 89/106/EEC.
- Reproduction of this European technical approval including transmission by electronic means shall be in full. However, partial reproduction can be made with the written consent of Deutsches Institut für Bautechnik. In this case partial reproduction has to be designated as such. Texts and drawings of advertising brochures shall not contradict or misuse the European technical approval.
- The European technical approval is issued by the approval body in its official language. This version corresponds fully to the version circulated within EOTA. Translations into other languages have to be designated as such.

Official Journal of the European Communities L 40, 11 February 1989, p. 12

Official Journal of the European Communities L 220, 30 August 1993, p. 1

Official Journal of the European Union L 284, 31 October 2003, p. 25

Bundesgesetzblatt Teil I 1998, p. 812

<sup>5</sup> Bundesgesetzblatt Teil I 2006, p. 2407, 2416

Official Journal of the European Communities L 17, 20 January 1994, p. 34



Page 3 of 19 | 8 January 2013

#### II SPECIFIC CONDITIONS OF THE EUROPEAN TECHNICAL APPROVAL

#### 1 Definition of products and intended use

The External Thermal Insulation Composite System "Capatect WDVS "A" mit Unterputz Capatect-Klebe- und Armierungsmasse 186 M" called ETICS in the following text, is designed and installed in accordance with the ETA-holder's design and installation instructions, deposited with the Deutsches Institut für Bautechnik (DIBt). The ETICS comprises the following components, which are factory-produced by the ETA-holder or a supplier. It's made up on site from these. The ETA-holder is ultimately responsible for the ETICS.

#### 1.1 Definition of the construction product

	Components (see clause 2.3 for further description, characteristics and performances)	Coverage [kg/m²]	Thickness [mm]
Insulation	Bonded ETICS:		
material with	Insulation product		
associated method of	factory-prefabricated mineral wool (MW) product to EN 13162:2008		
fixing	- MW lamella	_	≤ 200
	Adhesives		
	- Capatect-Klebe- u. Armierungsmasse 186 M	3.5 - 4.5	_
	(cement based powder requiring addition of about 20 – 24 % of water)	(powder)	
	- Capatect-Klebe- und Armierungsmasse 133 Leicht	3.5 - 4.5	_
	(cement based powder requiring addition of about 36 – 40 % of water)	(powder)	
	<ul> <li>Capatect ArmaReno 700 (cement based powder requiring addition of about 20 – 25 % of water)</li> </ul>	4.0 – 5.0 (powder)	_
	- Capatect-Klebe- und Spachtelmasse 190	about 4.0	_
	(cement based powder requiring addition of about 20 – 24 % of water)	(powder)	
	- Capatect-Dämmkleber 185 (cement based powder	4.0 - 5.0	_
	requiring addition of about 20 % of water)	(powder)	
	Mechanically fixed ETICS with profiles and supplementary adhesive:		
	Insulation product		
	factory-prefabricated mineral wool (MW) product to EN 13162:2008		
	- MW panel, σ <sub>mt</sub> ≥ 14 kPa	_	60 to 200
	Supplementary adhesive		
	(equal to bonded ETICS)		



#### Page 4 of 19 | 8 January 2013

	Components (see clause 2.3 for further description, characteristics and performances)	Coverage [kg/m²]	Thickness [mm]
	Profiles	<u> </u>	
	- Capatect-Halteleiste Alu		
	- Capatect-Verbindungsstück Alu		
	Aluminium (Al) – profiles		
Insulation	Anchors for profiles		
material with	- ejotherm SK U		
associated	- WS 8 L		
method of fixing	- WS 8 N		
lixilig	- ejotherm SDK U		
	- IsoFux ND-8Z		
	- SDF-K plus, SDF-K plus		
	- ejotherm NK U		
	Anchors for insulation product if necessary		
	(equal to mechanically fixed ETICS with anchors and		
	supplementary adhesive, see below)		
	Mechanically fixed ETICS with anchors and supplementary adhesive:		
	Insulation product		
	factory-prefabricated mineral wool (MW) product to EN 13162:2008		
	- MW panel	_	60 to 340
	- MW lamella	_	60 to 200
	Supplementary adhesive		
	(equal to bonded ETICS)		
	Anchors for insulation product		
	all anchors with ETA according to ETAG 014 <sup>7</sup> with characteristics defined in clause 2.3.2		
Base coat	Capatect-Klebe- u. Armierungsmasse 186 M	4.0 - 5.0	3.0 - 4.0
	Cement based powder requiring addition of 20 - 24 % of water.		
	Identical with the equally named adhesive given above.		
Glass fibre	Capatect-Gewebe 650	_	_
mesh	Alkali- and slide-resistant glass fibre mesh with mass per unit		
	area of about 160 g/m² and mesh size of about 4.0 mm x 4.0 mm.		
	Capatect-Panzergewebe 652	_	_
	(implemented in addition to the standard mesh to improve the		
	impact resistance)		
	Alkali- and slide-resistant glass fibre mesh with mass per unit area of about 330 g/m² and mesh size of about 6.0 mm x 6.0 mm.		

ETAG 014

Plastic anchors for fixing of external thermal insulation composite systems with rendering

Z69497.12



#### Page 5 of 19 | 8 January 2013

	Components (see clause 2.3 for further description, characteristics and performances)	Coverage [kg/m²]	Thickness [mm]	
Key coat	Putzgrund 610°	about 0.20 [l/m²]	_	
	Ready to use pigmented liquid - styrol acrylate binder.			
	To use with any finishing coats listed below if applicable.			
Finishing	To use with key coat "Putzgrund 610" if applicable:			
coat	Cement based powders requiring addition of about 28 – 44 % of water:			
	Capatect-Mineral-Leichtputze R (particle size 2.0 to 3.0 mm)	2.3 – 4.5	Regulated	
	Capatect-Mineral-Leichtputze K (particle size 2.0 to 3.0 mm)	2.3 – 4.5	by particle size	
	• Cement based powder requiring addition of about 20 – 24 % of water:			
	Capatect-Mineralputze R (particle size 2.0 to 3.0 mm)	about 3.0	Regulated	
	Capatect-Mineralputze K (particle size 2.0 to 3.0 mm)	about 3.0	by particle size	
	Capatect-Feinspachtel 195	4.0 - 6.0	2.0 - 3.0	
	<ul> <li>Cement based powder requiring addition of about 40 % of water:</li> </ul>			
	Capatect-Modellier- und Spachtelputz 134	about 4.0	2.0 - 5.0	
Ancillary material	Description in accordance with clause 3.2.2.5 of ETAG 004 and decorative coatings compatible with the ETICS to be applied to the finishing coat.			
	Remains the responsibility of the ETA-holder.			
* The instructio	n to the installer concerning the use of a key coat remains the responsibility of the	e ETA-holder.		

#### 1.2 Intended use

This ETICS is intended to be used as external insulation to the walls of buildings made of masonry (bricks, blocks, stones ...) or concrete (cast on site or as prefabricated panels) with and without rendering (Class A1 or A2 - s1,d0 according to EN 13501-1:2007). It shall be designed to give the wall to which it is applied satisfactory thermal insulation.

The ETICS is non load-bearing construction element. It does not contribute directly to the stability of the wall on which it is installed, but it can contribute to durability by providing enhanced protection from the effects of weathering.

The ETICS can be used on new or existing (retrofit) vertical walls.

The ETICS is not intended to ensure the air tightness of the building structure.

The choice of the method of fixing depends on the characteristics of the substrate, which could need preparation (see clause 7.2.1 of ETAG 004) and on the national instructions.

The provisions made in this European technical approval (ETA) based upon the assumed intended working life of the ETICS of at least 25 years, provided that the conditions laid down in clauses 4.2, 5.1 and 5.2 for the packaging, transport, storage, installation as well as appropriate use, maintenance and repair are met. The indications given on the working life cannot be interpreted as a guarantee given by the manufacturer or the Approval Body, but should only be regarded as a means to choosing the appropriate products in relation to the expected, economically reasonable working life of the works.



Page 6 of 19 | 8 January 2013

#### 2 Characteristics of products and methods of verification

#### 2.1 General

The assessment of the fitness for use of the ETICS for the intended use according to the Essential Requirements was carried out in compliance with ETAG 004, "Guideline for European Technical Approval of External Thermal Insulation Composite Systems with rendering", edition March 2000 (called ETAG 004 in this ETA).

Characteristics (of the components as well as of the ETICS), not mentioned in this ETA nor in the annex shall correspond to the respective values laid down in the technical documentation of this ETA.

#### 2.2 Characteristics of the ETICS

#### 2.2.1 Reaction to fire

Rendering system: Base coat with finishing coat and compatible key coat indicated hereafter	Maximum declared organic content	Class according to EN 13501-1:2007
Capatect-Mineral-Leichtputze R/K, Capatect-Mineralputze R/K, Capatect-Feinspachtel 195, Capatect-Modellier- und Spachtelputz 134	Base coat ≤ 2.3 % Finishing coat ≤ 2.4 %	A2 - s1,d0

#### Mounting and fixing

(for all end use applications given in clause 1.2 of the ETA)

The assessment of reaction to fire is based on tests according to EN 13823:2002 – SBI-test and EN ISO 1716:2002 with a maximum insulation layer thickness of 160 mm, a density of 100 kg/m³ (testing according to EN 13823:2002 – SBI-test) resp. 150 kg/m³ (testing according to EN ISO 1716:2002) as well as a rendering system with the highest organic content (silicate based finishing coat).

The manufacturer of the tested MW panels is Saint-Gobain Isover G+H AG, Bürgermeister-Grünzweig-Straße 1, 67059 Ludwigshafen.

Representative for the rendering system with the highest organic content a silicate based finishing coat was tested with the highest thickness of 3.5 mm.

Testing according to EN 1716:2002 was carried out with an adhesive with the highest organic content.

For the SBI-test the ETICS was mounted directly to a calcium silicate substrate (class A2 - s1,d0) according to EN 13238:2001 with a thickness of 11 mm.

The installation of the ETICS was carried out by the approval holder following his design and installation instructions using a single mesh all over the test specimen.

The tests specimens were prefabricated and did not include any joints.

For the SBI-test the lateral edges were covered with the rendering system.

For testing according to EN ISO 11925-2:2002 the edges were not covered with the rendering system (cut edges).

Anchors were not included in the tested ETICS as they have no influence on the test result.



Page 7 of 19 | 8 January 2013

#### Note:

A European reference fire scenario for facades has not been laid down. In some Member States, the classification of ETICS according to EN 13501-1:2007 might not be sufficient for the use in facades. An additional assessment of ETICS according to national provisions (e.g. on the basis of a large scale test) might be necessary to comply with Member State regulations, until the existing European classification system has been completed.

#### 2.2.2 Water absorption (capillarity test)

#### Base coat:

- Water absorption after 1 h < 1 kg/m²</li>
- Water absorption after 24 h < 0.5 kg/m²</li>

Rendering system:	Water absorption after 24 h		
Base coat with finishing coat indicated hereafter	< 0.5 kg/m²	≥ 0.5 kg/m²	
Capatect-Mineral-Leichtputze R/K	Х		
Capatect-Mineralputze R/K	Х		
Capatect-Feinspachtel 195	Х		
Capatect-Modellier- und Spachtelputz 134	Х		

#### 2.2.3 Hygrothermal behaviour

Hygrothermal cycles have been performed on a rig with the base coat "Capatect-Klebe- u. Armierungsmasse 186 M". None of the following defects occur during the testing:

- blistering or peeling of any finishing
- failure or cracking associated with joints between insulation product boards or profiles fitted with the system
- detachment of render
- cracking allowing water penetration to the insulation layer

The ETICS "Capatect WDVS "A" mit Unterputz Capatect-Klebe- u. Armierungsmasse 186 M" is so assessed resistant to hygrothermal cycles.

#### 2.2.4 Freeze/thaw behaviour

The water absorption of the base coat as well as the rendering system is less than 0.5 kg/m² after 24 hours for all configurations of the ETICS. The ETICS is so assessed as freeze/thaw resistant.

#### 2.2.5 Impact resistance

The verified resistance to hard body impact and to perforation of the ETICS results in the classification into categories listed below.

Rendering system: Base coat with finishing coat indicated hereafter	Single standard mesh "Capatect-Gewebe 650"
Capatect-Mineral-Leichtputze R/K	Category II
Capatect-Mineralputze R/K	Category II
Capatect-Feinspachtel 195	Category II
Capatect-Modellier- und Spachtelputz 134	Category II



#### Page 8 of 19 | 8 January 2013

#### 2.2.6 Water vapour permeability

Rendering system: Base coat with finishing coat indicated hereafter (evaluated without decorative coating or key coat)	Equivalent air thickness s <sub>d</sub>
Capatect-Mineral-Leichtputze R/K	≤ 1.0 m (Test result obtained with layer thickness of 3 mm: 0.10 m)
Capatect-Mineralputze R/K	≤ 1.0 m (Test result obtained with layer thickness of 3 mm: 0.06 m)
Capatect-Feinspachtel 195	≤ 1.0 m (Test result obtained with a layer thickness of 4 mm: 0.10 m)
Capatect-Modellier- und Spachtelputz 134	≤ 1.0 m (Test result obtained with a layer thickness of 4 mm: 0.10 m)

#### 2.2.7 Emission of dangerous substances or radiation

The ETICS complies with the provisions of Guidance Paper H ("A harmonized approach related to dangerous substances under the construction product directives Revision August 2002").

In addition to the specific clauses relating to dangerous substances contained in this ETA, there may be other requirements applicable to the products falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the Construction Products Directive, these requirements need also to be complied with, when and where they apply.

#### 2.2.8 Safety in use

#### 2.2.8.1 Bond strengths

Bond strength between base coat and insulation product (MW lamella)

Conditioning			
Initial state	After hygrothermal cycles	After freeze/thaw test	
≥ 0.08 MPa	< 0.08 MPa but failure in the insulation product	Test not required because freeze/thaw cycles not necessary	

Bond strength between adhesive and substrate resp. insulation product (MW lamella)

		Conditioning		
Adhesive	Substrate resp. insulation product	Initial state	2 d immersion in water + 2 h drying	2 d immersion in water + 7 d drying
Capatect Klebe- u.	Concrete	≥ 0.25 MPa	≥ 0.08 MPa	≥ 0.25 MPa
Armierungsmasse 186 M	MW lamella	≥ 0.08 MPa	≥ 0.03 MPa	≥ 0.08 MPa
	Concrete	≥ 0.25 MPa	≥ 0.08 MPa	≥ 0.25 MPa
Capatect Klebe- und Spachtelmasse 190	MW lamella	≥ 0.08 MPa	≥ 0.03 MPa	< 0.08 MPa but failure in the insulation product



#### Page 9 of 19 | 8 January 2013

		Conditioning		
Adhesive	Substrate resp. insulation product	Initial state	2 d immersion in water + 2 h drying	2 d immersion in water + 7 d drying
Capatect Klebe- u.	Concrete	≥ 0.25 MPa	≥ 0.08 MPa	≥ 0.25 MPa
Armierungsmasse 133 Leicht	MW lamella	≥ 0.08 MPa	≥ 0.03 MPa	< 0.08 MPa but failure in the insulation product
Capatect-Dämmkleber 185	Concrete	≥ 0.25 MPa	≥ 0.08 MPa	≥ 0.25 MPa
Capatect-Daminkleber 105	MW lamella	≥ 0.08 MPa	≥ 0.03 MPa	≥ 0.08 MPa
Capatect ArmaReno 700	Concrete	≥ 0.25 MPa	≥ 0.08 MPa	≥ 0.25 MPa
Capateot Affilianello 700	MW lamella	≥ 0.08 MPa	≥ 0.03 MPa	≥ 0.08 MPa

#### Bonded surface:

With a bonded surface of 50 % the formula given in clause 6.1.4.1.3 of ETAG 004 is fulfilled and the use as bonded ETICS is possible.

#### 2.2.8.2 Fixing strength (displacement test)

Test not required because the ETICS fulfils the following criterion to clause 5.1.4.2 of ETAG 004:

- E · d < 50 000 N/mm

(E: modulus of elasticity of the base coat – d: mean dried thickness of the base coat)

#### 2.2.8.3 Wind load resistance

#### Safety in use of mechanically fixed ETICS using profiles

The following failure loads only apply to the listed combination (MW panel's characteristics)/ (way of fixing the ETICS) and the characteristics of the insulation product given in clause 2.3.1.

#### Failure loads - Table 1

	Dimensions	625 mm x 800 mm
Characteristics of the <b>MW panels</b>	Thickness	≥ 60 mm
mir panere	Tensile strength perpendicular to the faces	≥ 14 kPa
Failure loads [N/panel] (Static Foam Block Test)	Horizontal profiles with a vertical distance of 625 mm, fixed every 30 cm and vertical connection profiles  No additional anchors in MW panel	Minimal: 1200 Average: 1250



#### Page 10 of 19 | 8 January 2013

#### Failure loads - Table 2

	Dimensions	625 mm x 800 mm
Characteristics of the <b>MW panels</b>	Thickness	≥ 60 mm
mir panere	Tensile strength perpendicular to the faces	≥ 14 kPa
Failure loads [N/panel] (Static Foam Block Test)	Horizontal profiles with a vertical distance of 625 mm, fixed every 30 cm and vertical connection profiles  Two additional anchors per MW panel,	Minimal: 2200 Average: 2400
	plate diameter ≥ 60 mm, mounted on the MW panel surface	

#### Safety in use of mechanically fixed ETICS using anchors

The following failure loads only apply to the listed combination (MW panel's characteristics)/ (anchor plate's characteristics) and the characteristics of the insulation product given in clause 2.3.1.

Failure loads - Table 3

Characteristics of the MW panels		Thickness  Tensile strength perpendicular to the faces		≥ 60 mm
				≥ 14 kPa
Plate diameter of	anchor			≥ Ø 60 mm
Failure loads [N]		rs not placed at the panel joints Foam Block Test)	R <sub>panel</sub>	Minimal: 650 Average: 740
		rs placed at the panel joints Foam Block Test)	R <sub>joint</sub>	Minimal: 590 Average: 610
		rs not placed at the panel joints prough test, dry conditions)	R <sub>panel</sub>	Minimal: 640 Average: 690
		rs not placed at the panel joints rough test, wet conditions) s 2 <sup>*</sup>	$R_{panel}$	Minimal: 360 Average: 390
	- serie	es 3 <sup>*</sup>		Minimal: 410 Average: 450



#### Page 11 of 19 | 8 January 2013

#### Failure loads - Table 4

Apply to all anchors listed in the Table in clause 1.1 mounted on the insulation panels surface					
the Mark of the same and the sa		Thickness		≥ 80 mm	
		Tensile strength perpendicular to the faces		≥ 5.0 kPa	
Plate diameter	er of anchor ≥ Ø 90 mm		≥ Ø 140 mm		
Failure loads [N]		chors not placed at the panel joints atic Foam Block Test)	R <sub>panel</sub>	Minimal: 480 Average: 490	Minimal: 560 Average: 690
		chors placed at the panel joints atic Foam Block Test)	R <sub>joint</sub>	Minimal: 380 Average: 390	Minimal: 440 Average: 540
		chors not placed at the panel joints ill-through test, dry conditions)	R <sub>panel</sub>	Minimal: 540 Average: 610	npd
	(Pu	chors not placed at the panel joints ill-through test, wet conditions) eries 2*	R <sub>panel</sub>	Minimal: 400 Average: 460	npd
* According to ETAG 004 clause 5.2.4.1.2 test method (2)					

#### Failure loads - Table 5

Apply to all anchors listed in the Table in clause 1.1 mounted on the insulation panels surface				
Characteristics of the MW lamella		Thickness		≥ 60 mm
		Tensile strength perpendicular to the faces		≥ 80 kPa
Plate diameter of anchor			≥ Ø 140 mm	
Failure loads [N]		ors placed at the panel joints through test, dry condition)		Minimal: 620 Average: 660
		ors placed at the panel joints through test, wet condition)	R <sub>joint</sub>	Minimal: 510 Average: 570
		ors placed at the panel joints c Foam Block Test)	R <sub>joint</sub>	Minimal: 710

The failure loads of Table 2 and 3 specified above only apply to the following anchors with deep mounting under the given conditions of installation:

Anchor	Thickness of the MW panel [d]	Conditions of installation*
ejotherm STR U ejotherm STR U 2G	100 mm > d ≥ 80 mm	<ul> <li>Maximum installation depth of the anchor plate: 15 mm (≜ thickness of insulation cover)</li> </ul>
(ETA-04/0023)		<ul> <li>Maximum depth of die: 5 mm</li> </ul>
	≥ 100 mm	<ul> <li>Maximum installation depth of the anchor plate: 15 mm (≜ thickness of insulation cover)</li> </ul>
		- Maximum depth of die: 20 mm
TERMOZ 8 SV (ETA-06/0180)	≥ 80 mm	<ul> <li>Maximum installation depth of the anchor plate: 15 mm (≜ thickness of insulation cover)</li> </ul>
* According to the appro	priate ETA of anchor	



#### Page 12 of 19 | 8 January 2013

The wind load resistance R<sub>d</sub> of the ETICS is calculated as follows:

$$R_{d} = \frac{R_{panel} \cdot n_{panel} + R_{joint} \cdot n_{joint}}{\gamma}$$

number (per m²) of anchors not placed at the panel joints n<sub>panel</sub>: number (per m²) of anchors placed at the panel joint n joint:

national safety factor γ:

#### 2.2.9 Thermal resistance

The nominal value of the additional thermal resistance R provided by the ETICS to the substrate wall is calculated in accordance with EN ISO 6946:2007 from the nominal value of the insulation product's thermal resistance R<sub>D</sub> given accompanied to the CE marking and from the thermal resistance of the rendering system R<sub>render</sub> which is about 0.02 (m<sup>2</sup>· K)/W.

$$R = R_D + R_{render}$$

The thermal bridges caused by mechanical fixing devices (anchors profiles) increase the thermal transmittance U. This influence had to take into account according to EN ISO 6946: 2007

2007.	
$U_c = U + \Delta U$	corrected thermal transmittance
$\Delta U = \Delta U_{anchor} + \Delta U_{profile}$	correction term for mechanical fixing devices (anchors, profiles)
$\Delta U_{anchor} = \chi_p \cdot n$	correction term for anchors
where: n	number of anchors per m <sup>2</sup>
$\chi_{ t p}$	local influence of thermal bridge caused by an anchor. The values listed below can be taken into account, if not specified in the

anchor's technical approval  $\chi_p = 0.004 \text{ W/K}$ for anchors with a galvanized steel screw with the head covered by

a plastic material

 $\chi_{p} = 0.002 \text{ W/K}$ for anchors with a stainless steel screw with the head covered by

plastic material, and for anchors with an air gap at the head of the

 $\Delta U_{profile}$ correction term for profiles; subject to the thickness of the insulation product and the thermal resistance of the substrate wall

the following values apply:

Thermal resistance of the substrate wall [(m²·K)/W]	Thickness of the insulation product [mm]	ΔU <sub>profile</sub> [W/(m²⋅K)]
	60 ≤ t < 80	0.03
R < 0.33	80 ≤ t < 120	0.02
	t ≥ 120	0
	60 ≤ t < 80	0.02
0.33 ≤ R ≤ 1.10	80 ≤ t ≤ 100	0.01
	t > 100	0
R > 1.10	t ≥ 60	0



#### Page 13 of 19 | 8 January 2013

# 2.2.10 Aspects of durability and serviceability Bond strength after ageing:

	Capatect-Mineral-Leichtputze R/K	
Rendering system:	Capatect-Mineralputze R/K	> 0.00 MDa
Base coat with finishing coat indicated hereafter	Capatect-Feinspachtel 195	≥ 0.08 MPa
Cour maioatoa moroantor	Capatect-Modellier- und Spachtelputz 134	

#### 2.3 Characteristics of the components

Detailed information on the chemical composition and other identifying characteristics of the components, following Annex C of ETAG 004 have been deposited with the DIBt.

Further information can be observed from the product data sheets, which are part of the technical documentation for this ETA.

#### 2.3.1 Thermal insulation product

Factory-prefabricated panels and lamella made of mineral wool (MW) to EN 13162:2008 with the following designation code and the other properties having the description in the Table below shall be used, provided that the manufacturer and the trade name of the MW are deposited with the DIBt.

MW - EN 13162 - T5 - DS(T+) - WS - WL(P) - MU1

Description and characteristics	MW panel	MW panel	MW lamella	
Reaction to fire; EN 13501-1:2007	Class A1			
Gross heat of combustion [MJ/kg]; EN ISO 1716:2002	PCS ≤ 1.02			
Thermal resistance [(m²· K)/W]	Defined in the CE	E marking in reference	e to EN 13162:2008	
Tensile strength perpendicular to the faces [kPa]; EN 1607:1997 - in dry conditions*	$\sigma_{mt} \ge 14$	$\sigma_{mt} \geq 5$	σ <sub>mt</sub> ≥ 80	
- in wet conditions** Average value - series 2 - series 3	≥ 33 % of average value in dry conditions ≥ 50 % of average value in dry conditions			
Compressive strength* [kPa]; EN 826:1996	$\sigma_m \geq 40$	$\sigma_m \geq 4$	$\sigma_m \geq 40$	
Apparent density [kg/m³]; EN 1602:1996	$120 \le \rho_a \le 150$	$100 \le \rho_a \le 150$	$80 \le \rho_a \le 150$	
Shear strength <sup>*</sup> [kPa]; EN 12090:1997	$20 \le f_{\tau k} \le 100$	$6 \le f_{\tau k} \le 100$	$20 \le f_{\tau k} \le 100$	
Shear modulus [MPa]; EN 12090:1997	$1.0 \leq G_m \leq 2.0$	$0.3 \leq G_m \leq 2.0$	$1.0 \leq G_m \leq 2.0$	
* Minimal value of all single values  ** According to ETAG 004 clause 5.2.4.1.2 test method (2)				

Thermal insulation materials (MW panel,  $\sigma_{mt} \ge 14$  kPa) for mechanically fixed ETICS with profiles must circumferentially at the edges, 24 mm from the inner surface, get an approx. 3 mm wide and 13 to 18 mm deep groove cut-in at the factory.



#### Page 14 of 19 | 8 January 2013

#### 2.3.2 Anchors

All anchors with ETA according to ETAG 014<sup>7</sup> with characteristics having the description below shall be used in the mechanically fixed ETICS:

- plate diameter of anchor ≥ 60 mm resp. ≥ 90 mm or ≥ 140 mm
- plate stiffness ≥ 0.3 kN/mm
- load resistance of the anchor plate ≥ 1.0 kN

These characteristics and the characteristic tension resistance of the anchors shall be taken from the corresponding ETA.

The anchors listed in the Table in clause 1.1 with reference to the respective ETA shall be used in the mechanically fixed ETICS with profiles for fixing the horizontal profiles.

Trade name	ETA-number
ejotherm SK U	ETA-02/0018
WS 8 L	ETA-02/0019
WS 8 N	ETA-03/0019
ejotherm SDK U	ETA-04/0023
IsoFux ND-8Z	ETA-04/0032
SDF-K plus, SDF-S plus	ETA-04/0064
ejotherm NK U	ETA-05/0009

#### 2.3.3 Profiles

Aluminium (Al) profiles, EN AW-6060 T66 to EN 755-2:2008 with the measurements according to Annex 1 are to be used in the mechanically fixed ETICS with profiles.

The Pull-through resistance of fixings from profiles is ≥ 500 N.

#### 2.3.4 Render (base coat)

The average value of crack width of the base coat reinforced with the glass fibre mesh "Capatect-Gewebe 650" measured at a render strain value of 1 % is about 0.06 mm.

#### 2.3.5 Reinforcement (glass fibre mesh)

Characteristics (alkali resistance): Pass

	Capatect-Gewebe 650	
	Warp	Weft
Residual strength after ageing [N/mm]	≥ 20	≥ 20
Relative residual resistance after ageing in % of the strength in the as-delivered state	≥ 50	≥ 50



Page 15 of 19 | 8 January 2013

#### 3 Evaluation and attestation of conformity and CE-marking

#### 3.1 System of attestation of conformity

According to the decision 97/556/EC of the European Commission<sup>8</sup> amended by 2001/596/EC<sup>9</sup> system 1 or 2+ of the attestation of conformity applies depending on reaction to fire.

Considering Class A2 for reaction to fire of the ETICS, the systems of attestation of conformity are system 1 regarding reaction to fire characteristic and system 2+ regarding other characteristics than reaction to fire.

These systems of attestation of conformity are defined as follows:

System 1: Certification of the conformity of the product by a notified certification body on the basis of:

- (a) Tasks for the manufacturer:
  - (1) factory production control;
  - (2) further testing of samples taken at the factory by the manufacturer in accordance with a prescribed test plan.
- (b) Tasks for the notified body:
  - (3) initial type-testing of the product;
  - (4) initial inspection of factory and of factory production control;
  - (5) continuous surveillance, assessment and approval of factory production control.

System 2+: Declaration of conformity of the product by the manufacturer on the basis of:

- (a) Tasks for the manufacturer:
  - (1) initial type-testing of the product;
  - (2) factory production control;
  - (3) testing of samples taken at the factory in accordance with a prescribed test plan.
- (b) Tasks for the notified body:
  - (4) certification of factory production control on the basis of:
    - initial inspection of factory and of factory production control;
    - continuous surveillance, assessment and approval of factory production control.

#### 3.2 Responsibilities

#### 3.2.1 Tasks for the manufacturer

#### 3.2.1.1 Factory production control

The manufacturer shall exercise permanent internal control of production. All the elements, requirements and provisions adopted by the manufacturer shall be documented in a systematic manner in the form of written policies and procedures, including records of results performed. This production control system shall insure that the ETICS and the components are in conformity with this ETA.

The manufacturer shall only use raw materials stated in the technical documentation of this ETA. The incoming raw materials are subjected to verifications by the manufacturer before acceptance.

Official Journal of the European Communities/Union L229/14 of 20.08.1997

Official Journal of the European Communities/Union L 209/33 of 2.8.2001



#### Page 16 of 19 | 8 January 2013

The factory production control shall be in accordance with the "Control plan" which is part of the technical documentation of this ETA. The "Control plan" has been agreed between the manufacturer and the DIBt and is laid down in the context of the factory production control system operated by the manufacturer and deposited with the DIBt.

The results of factory production control shall be recorded and evaluated in accordance with the provisions of the "Control plan" The records include at least the following information:

- designation of the product, the basic materials and components;
- type of control or testing;
- date of manufacture of the product and date of testing of the product or basic materials or components;
- result of control and testing and, if appropriate, comparison with requirements;
- signature of person responsible for factory production control.

The records shall be presented to the notified body involved in continuous surveillance. On request they shall be presented to the DIBt.

#### 3.2.1.2 Other tasks for the manufacturer

For initial type-testing of the ETICS and the components regarding other characteristics than reaction to fire the results of the tests performed as part of the assessment for the ETA shall be used unless there are changes in the production line or plant. In such cases the necessary initial type-testing has to be agreed with the DIBt.

The manufacturer shall, on the basis of a contract, involve a body which is notified for the tasks referred to in clause 3.1 in the field of ETICS in order to undertake the actions laid down in clause 3.2.2. For this purpose, the "Control plan" referred to in clauses 3.2.1.1 and 3.2.2 shall be handed over by the manufacturer to the notified bodies involved.

The manufacturer shall make a declaration of conformity, stating that the ETICS is in conformity with the provisions of ETA-12/0575 issued on 8 January 2013.

#### 3.2.2 Tasks for the notified bodies

The notified body shall perform the

- initial type-testing of the ETICS and the components regarding reaction to fire characteristic,
- initial inspection of factory and of factory production control,
- continuous surveillance, assessment and approval of factory production control,

in accordance with the provisions laid down in the "Control plan" 10.

The notified body shall retain the essential points of its actions referred to above and state the results obtained and conclusions drawn in a written report.

The notified certification body involved by the manufacturer shall issue an EC certificate of conformity of the ETICS which includes the certification of factory production control stating the conformity with the provisions of this ETA.

In cases where the provisions of the ETA and its "Control plan" are no longer fulfilled the notified certification body shall withdraw the certificate of conformity and inform the DIBt without delay.

The "Control plan" is a confidential part of the European technical approval and only handed over to the notified body involved in the procedure of attestation of conformity. See section 3.2.2.



Page 17 of 19 | 8 January 2013

#### 3.3 Marking

#### 3.3.1 CE marking

The CE marking shall be affixed on the accompanying commercial document. The letters "CE" shall be followed by the identification number of the notified certification body and be accompanied by the following additional information:

- the name and address of the ETA-holder (legal entity responsible for the manufacture),
- the last two digits of the year in which the CE marking was affixed,
- the number of the EC certificate of conformity for the ETICS,
- the number of the ETA,
- the number of the ETAG.
- the ETICS trade name.

#### 3.3.2 Additional marking

The respective trade name of the individual components of the ETICS shall be given on the packaging.

In addition to the trade name the following information shall be given in the accompanying commercial document and/or on the packaging of the thermal insulation product:

- minimum value of the tensile strength perpendicular to the faces of the insulation product,
- shear modulus of the insulation product.

## 4 Assumptions under which the fitness of the product for the intended use was favourably assessed

#### 4.1 Manufacturing

The composition and manufacturing process used for the components of the ETICS shall comply with those on which the approval tests were based. Composition and manufacturing process are deposited at the DIBt.

The ETA is issued for the ETICS on the basis of agreed data/information, deposited with the DIBt, which identifies the ETICS that has been assessed and judged. Changes to the ETICS or the components or their production process, which could result in this deposited data/information being incorrect, should be notified to the DIBt before the changes are introduced. DIBt will decide whether or not such changes affect the approval and consequently the validity of the CE marking on the basis of the approval and if so whether further assessment or alterations to the approval shall be necessary.

#### 4.2 Installation, design and execution

#### 4.2.1 General

The wall on which the ETICS is applied shall be sufficiently stable and airtight. Its stiffness shall be large enough to ensure that the ETICS is not subjected to deformations, which could lead to damage.

The requirements given in ETAG 004, chapter 7, have to be considered.

#### 4.2.2 Installation

The ETICS is installed on site. The approval holder is obliged to instruct all those entrusted with the design and execution of the ETICS about the specific conditions of this ETA and all other details necessary for perfect execution.

Only the components whose trade name is given in clause 1.1 and which have the characteristics according to clause 2.3 may be used for the ETICS.



Page 18 of 19 | 8 January 2013

#### 4.2.3 Design

#### 4.2.3.1 Requirements for the substrate

As to the requirements for the substrate and its preparation, ETAG 004, clause 7.2.1 applies.

The substrate for mechanically fixed systems should have a sufficient resistance for the use of anchors according to clause 2.3.2. The conditions of the ETA for the anchor concerned apply.

#### 4.2.3.2 Resistance to wind load

Judging of sufficient resistance to wind load should be on the basis of the resistance of the fixings according to clause 2.2.8.3 and of the characteristic tension resistance of the used anchor according to clause 2.3.2. Taking into account the national safety factors the design values of resistance are determined. The smaller one of the design resistances of the ETICS ( $R_d$ ) and of the anchor ( $N_{Rd}$ ) is decisive.

The determined design wind load suction  $S_d$  (taking into account the national safety factors) is compared with the design resistance.

#### 4.2.4 Execution

The manufacturer's design and installation instructions, which are part of the technical documentation for this ETA, shall be observed with respect to the installation of the ETICS and drying times of rendering products.

#### 5 Indications to the manufacturer

#### 5.1 Packaging, transport and storage

Packaging of the components has to be such that they are protected against moisture during transport and storage, unless other measures are foreseen by the manufacturer for this purpose.

The components are to be protected against damage.


#### 5.2 Use, maintenance, repair

To the indications on use, maintenance and repair ETAG 004, clause 7.3 applies.


Uwe Benderbeglaubigt:Head of DepartmentWachner



### Horizontal profile - "Capatect-Halteleiste ALU"



### Vertical connection profile – "Capatect-Verbindungsstück ALU"



Capatect WDVS "A" mit Unterputz Capatect-Klebe- und Armierungsmasse 186 M	
Horizontal and vertical Aluminium profiles	Annex 1

Z91374.12 8.04.04-121/07