



## European Technical Approval ETA-12/0502

English translation prepared by DIBt - Original version in German language

Handelsbezeichnung <i>Trade name</i>	EJOT Porenbetondübel SDP-S-10G und EJOT SDP-KB-10G <i>EJOT SDP-S-10G and EJOT SDP-KB-10G</i>
Zulassungsinhaber <i>Holder of approval</i>	EJOT Baubefestigungen GmbH In der Stockwiese 35 57334 Bad Laasphe DEUTSCHLAND
Zulassungsgegenstand und Verwendungszweck <i>Generic type and use of construction product</i>	Kunststoffdübel als Mehrfachbefestigung von nichttragenden Systemen zur Verankerung im Porenbeton (AAC) <i>Plastic anchor for multiple use in autoclaved aerated concrete (AAC) for non-structural applications</i>
Geltungsdauer: <i>Validity:</i>	vom <i>from</i> bis <i>to</i>
Herstellwerk <i>Manufacturing plant</i>	EJOT Herstellwerk 1, 2, 3 und 4
	7 January 2013 7 January 2018

Diese Zulassung umfasst  
*This Approval contains*

16 Seiten einschließlich 6 Anhänge  
*16 pages including 6 annexes*

## I LEGAL BASES AND GENERAL CONDITIONS

- 1 This European technical approval is issued by Deutsches Institut für Bautechnik in accordance with:
  - Council Directive 89/106/EEC of 21 December 1988 on the approximation of laws, regulations and administrative provisions of Member States relating to construction products<sup>1</sup>, modified by Council Directive 93/68/EEC<sup>2</sup> and Regulation (EC) N° 1882/2003 of the European Parliament and of the Council<sup>3</sup>;
  - *Gesetz über das In-Verkehr-Bringen von und den freien Warenverkehr mit Bauprodukten zur Umsetzung der Richtlinie 89/106/EWG des Rates vom 21. Dezember 1988 zur Angleichung der Rechts- und Verwaltungsvorschriften der Mitgliedstaaten über Bauprodukte und anderer Rechtsakte der Europäischen Gemeinschaften (Bauproduktengesetz - BauPG) vom 28. April 1998<sup>4</sup>, as amended by Article 2 of the law of 8 November 2011<sup>5</sup>;*
  - Common Procedural Rules for Requesting, Preparing and the Granting of European technical approvals set out in the Annex to Commission Decision 94/23/EC<sup>6</sup>;
  - Guideline for European technical approval of "Plastic Anchors for Multiple Use in Concrete and Masonry for Non-structural Applications - Part 5: Plastic Anchors for uUe in Autoclaved Aerated Concrete", ETAG 020-05.
- 2 Deutsches Institut für Bautechnik is authorized to check whether the provisions of this European technical approval are met. Checking may take place in the manufacturing plant. Nevertheless, the responsibility for the conformity of the products to the European technical approval and for their fitness for the intended use remains with the holder of the European technical approval.
- 3 This European technical approval is not to be transferred to manufacturers or agents of manufacturers other than those indicated on page 1, or manufacturing plants other than those indicated on page 1 of this European technical approval.
- 4 This European technical approval may be withdrawn by Deutsches Institut für Bautechnik, in particular pursuant to information by the Commission according to Article 5(1) of Council Directive 89/106/EEC.
- 5 Reproduction of this European technical approval including transmission by electronic means shall be in full. However, partial reproduction can be made with the written consent of Deutsches Institut für Bautechnik. In this case partial reproduction has to be designated as such. Texts and drawings of advertising brochures shall not contradict or misuse the European technical approval.
- 6 The European technical approval is issued by the approval body in its official language. This version corresponds fully to the version circulated within EOTA. Translations into other languages have to be designated as such.

<sup>1</sup> Official Journal of the European Communities L 40, 11 February 1989, p. 12  
<sup>2</sup> Official Journal of the European Communities L 220, 30 August 1993, p. 1  
<sup>3</sup> Official Journal of the European Union L 284, 31 October 2003, p. 25  
<sup>4</sup> *Bundesgesetzblatt Teil I 1998*, p. 812  
<sup>5</sup> *Bundesgesetzblatt Teil I 2011*, p. 2178  
<sup>6</sup> Official Journal of the European Communities L 17, 20 January 1994, p. 34



The provisions made in this European Technical Approval are based on an assumed working life of the anchor of 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

## 2 Characteristics of the product and methods of verification

### 2.1 Characteristics of the product

The anchor corresponds to the drawings and information given in Annex 1, 2, 3 and 4. The characteristic material values, dimensions and tolerances of the anchor not given in these Annexes shall correspond to the respective values laid down in the technical documentation<sup>7</sup> of this European Technical Approval.

The characteristic values for the design of the anchorages are given in Annex 4, 5 and 6.

Each anchor is to be marked with the identifying mark, the type, the diameter and the length of the anchor according to Annex 2 and 3.

The minimum embedment depth shall be marked.

The anchor shall only be packaged and supplied as a complete unit.

### 2.2 Methods of verification

The assessment of the fitness of the anchor for the intended use in relation to the requirements for safety in use in the sense of the Essential Requirement 4 has been made in compliance with the Guideline for European Technical Approval of "Plastic Anchors for Multiple Use in Concrete and Masonry for Non-structural Applications", ETAG 020,

- Part 1: "General",
- Part 5: "Plastic Anchors for Use in Autoclaved Aerated Concrete",  
based on the use category d.

In addition to the specific clauses relating to dangerous substances contained in this European Technical Approval, there may be other requirements applicable to the products falling within its scope (e. g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the Construction Products Directive, these requirements need also to be complied with, when and where they apply.

## 3 Evaluation and attestation of conformity and CE marking

### 3.1 System of attestation of conformity

According to the decision 97/463/EG of the European Commission<sup>8</sup> the system 2(ii) (referred to as system 2+) of attestation of conformity applies.

This system of attestation of conformity is defined as follows.

System 2+: Declaration of conformity of the product by the manufacturer on the basis of:

- (a) Tasks for the manufacturer:
  - (1) initial type-testing of the product;
  - (2) factory production control;
  - (3) testing of samples taken at the factory in accordance with a prescribed control plan.

<sup>7</sup> The technical documentation of this European Technical Approval is deposited at the Deutsches Institut für Bautechnik and, as far as relevant for the tasks of the approved bodies involved in the attestation of conformity procedure, is handed over to the approved bodies.

<sup>8</sup> Official Journal of the European Communities L 198 of 25.07.1997.

- (b) Tasks for the approved body:
- (4) certification of factory production control on the basis of:
- initial inspection of factory and of factory production control;
  - continuous surveillance, assessment and approval of factory production control.

### 3.2 Responsibilities

#### 3.2.1 Tasks of the manufacturer

##### 3.2.1.1 Factory production control

The manufacturer shall exercise permanent internal control of production. All the elements, requirements and provisions adopted by the manufacturer shall be documented in a systematic manner in the form of written policies and procedures, including records of results performed. This production control system shall insure that the product is in conformity with this European Technical Approval.

The manufacturer may only use raw materials stated in the technical documentation of this European Technical Approval.

The factory production control shall be in accordance with the control plan which is part of the technical documentation of this European Technical Approval. The control plan is laid down in the context of the factory production control system operated by the manufacturer and deposited at Deutsches Institut für Bautechnik.<sup>9</sup>

The results of factory production control shall be recorded and evaluated in accordance with the provisions of the control plan.

##### 3.2.1.2 Other tasks of manufacturer

The manufacturer shall, on the basis of a contract, involve a body which is approved for the tasks referred to in section 3.1 in the field of anchors in order to undertake the actions laid down in section 3.2.2. For this purpose, the control plan referred to in sections 3.2.1.1 and 3.2.2 shall be handed over by the manufacturer to the approved body involved.

The manufacturer shall make a declaration of conformity, stating that the construction product is in conformity with the provisions of this European Technical Approval.

#### 3.2.2 Tasks of approved bodies

The approved body shall perform the

- initial inspection of factory and of factory production control,
  - continuous surveillance, assessment and approval of factory production control,
- in accordance with the provisions laid down in the control plan.

The approved body shall retain the essential points of its actions referred to above and state the results obtained and conclusions drawn in a written report.

The approved certification body involved by the manufacturer shall issue an EC certificate of conformity of the factory production control stating the conformity with the factory production control of this European Technical Approval.

In cases where the provisions of the European Technical Approval and its control plan are no longer fulfilled the certification body shall withdraw the certificate of conformity and inform Deutsches Institut für Bautechnik without delay.

<sup>9</sup> The control plan is a confidential part of the documentation of the European Technical Approval, but not published together with the ETA and only handed over to the approved body involved in the procedure of attestation of conformity. See section 3.2.2.

### 3.3 CE marking

The CE marking shall be affixed on each packaging of the anchor. The letters "CE" shall be followed by the identification number of the approved certification body, where relevant, and be accompanied by the following additional information:

- the name and address of the producer (legal entity responsible for the manufacturer),
- the last two digits of the year in which the CE marking was affixed,
- the number of the EC certificate for the factory production control,
- the number of the European Technical Approval,
- the number of the guideline for European Technical Approval,
- use category d.

## 4 Assumptions under which the fitness of the product for the intended use was favourably assessed

### 4.1 Manufacturing

The European Technical Approval is issued for the product on the basis of agreed data/information, deposited with Deutsches Institut für Bautechnik, which identifies the product that has been assessed and judged. Changes to the product or production process, which could result in this deposited data/information being incorrect, should be notified to Deutsches Institut für Bautechnik before the changes are introduced. Deutsches Institut für Bautechnik will decide whether or not such changes affect the ETA and consequently the validity of the CE marking on the basis of the ETA and if so whether further assessment or alterations to the ETA shall be necessary.

### 4.2 Design of anchorages

#### 4.2.1 General

Fitness for the intended use of the anchor is given under the following conditions:

- The design of anchorages is carried out in compliance with ETAG 020, Guideline for European Technical Approval of "Plastic Anchors for Multiple Use in Concrete and Masonry for Non-structural Applications", Annex C under the responsibility of an engineer experienced in anchorages.
- Verifiable calculation notes and drawings shall be prepared taking account of the loads to be anchored, the nature and strength of the base materials and the dimensions of the anchorage members as well as of the relevant tolerances.
- The anchor is to be used only for multiple fixing for non-structural applications.

Therefore the design of the fixture may specify the number  $n_1$  of fixing points to fasten the fixture and the number  $n_2$  of anchors per fixing point. Furthermore the design value of actions  $N_{Sd}$  on a fixing point to a value  $\leq n_3$  (kN) is specified up to which the strength and stiffness of the fixture are fulfilled and the load transfer in the case of excessive slip or failure of one anchor need not be taken into account in the design of the fixture.

The following default values for  $n_1$ ,  $n_2$  and  $n_3$  may be taken:

$$n_1 \geq 4; \quad n_2 \geq 1 \quad \text{and} \quad n_3 \leq 4,5 \text{ kN} \quad \text{or}$$

$$n_1 \geq 3; \quad n_2 \geq 1 \quad \text{and} \quad n_3 \leq 3,0 \text{ kN}.$$

- Shear loads acting on an anchor may be assumed to act without lever arm if both of the following conditions are fulfilled:

- The fixture shall be made of metal and in the area of the anchorage be fixed directly to the base material either without an intermediate layer or with a levelling layer of mortar with a thickness  $\leq 3$  mm.
- The fixture shall be in contact with the anchor over its entire thickness. (Therefore the diameter of clearance hole in the fixture  $d_f$  has to be equal or smaller than the value given in Annex 4, Table 3.)

If these two conditions are not fulfilled the lever arm is calculated according to ETAG 020, Annex C. The characteristic bending moment is given in Annex 6, Table 6.

#### 4.2.2 Specific conditions for the design method in autoclaved aerated concrete

The characteristic values of resistance of the anchor and the appropriated partial safety factor for use in autoclaved aerated concrete are given in Annex 6, Table 5. These values are independent of the load direction (tension, shear or combined tension and shear) and the mode of failure.

The characteristic resistance  $F_{Rk}$  for a single plastic anchor may also be taken for a group of two or four plastic anchors with a spacing equal or larger than the minimum spacing  $s_{min}$ .

The distance between single plastic anchors or a group of anchors should be  $a_{min} = 250$  mm.

If the joints are not visible the characteristic resistance  $F_{Rk}$  has to be reduced with the factor  $\alpha_j = 0,5$ .

If the joints of the masonry are visible (e.g. unplastered wall) following has to be taken into account:

- The characteristic resistance  $F_{Rk}$  may be used only, if the wall is designed such that the joints are glued together or fixed with key and slot.
- If the wall is designed such that the joints are not to be glued together or fixed with key and slot the characteristic resistance  $F_{Rk}$  may be used only, if the minimum edge distance  $c_{min}$  to the vertical joints is observed. If this minimum edge distance  $c_{min}$  can not be observed then the characteristic resistance  $F_{Rk}$  has to be reduced with the factor  $\alpha_j = 0,5$ .

#### 4.2.3 Characteristic values, spacing and dimensions of anchorage member

The minimum spacing and dimensions of anchorage member according to Annex 5, Table 4 shall be observed depending on the base material.

#### 4.2.4 Displacement behaviour

The displacements under tension and shear loading in autoclaved aerated concrete are given in Annex 6, Table 7.

#### 4.3 Installation of anchor

The fitness for use of the anchor can only be assumed if the following conditions of installation are met:

- Anchor installation carried out by appropriately qualified personnel under the supervision of the person responsible for technical matters on site.
- Use of the anchor only as supplied by the manufacturer without exchanging any component of the anchor.
- Anchor installation in accordance with the manufacturer's specifications and drawings using the tools indicated in this European Technical Approval.
- Checks before placing the anchor, to ensure that the characteristic values of the base material in which the anchor is to be placed, is identical with the values, which the characteristic loads apply for.
- Observation of the drill method according Annex 6 (Drill holes in autoclaved aerated concrete may only be drilled using the rotary drill).
- Placing drill holes without damaging the reinforcement.
- Observation of the overall plastic anchor embedment depth.

- Holes to be cleaned of drilling dust.
- In case of aborted hole: New drilling at a minimum distance away of twice the depth of the aborted hole or smaller distance if the aborted drill hole is filled with high strength mortar.
- The plastic sleeve is inserted through the fixture by slight hammer blows and the special screw is screwed in until the head of the screw touches the sleeve. The anchor is correct mounted, if there is no turn-through of the plastic sleeve in the drill hole and if slightly move on turning of the screw is impossible after the complete turn-in of the screw.
- Temperature during installation of the anchor  $\geq -10$  °C (plastic sleeve and base material).

#### 4.4 Job site tests according to ETAG 020, Annex B

##### 4.4.1 General

In the absence of national requirements the characteristic resistance of the plastic anchor may be determined by job site tests, if the plastic anchor has already characteristic values given in Annex 6 for the same base material as it is present on the construction works.

Furthermore job site tests for use in different autoclaved aerated concrete are possible only if the plastic anchor has already characteristic values given in Annex 6 for use in the equivalent base material.

Job site tests are also possible, if another drill method is been used as it is given in Annex 6.

The characteristic resistance to be applied to a plastic anchor should be determined by means of at least 15 pull-out tests carried out on the construction work with a centric tension load acting on the plastic anchor. These tests may also performed in a laboratory under equivalent conditions as used on construction work

Execution and evaluation of the tests as well as issue of the test report and determination of the characteristic resistance should be supervised by the person responsible for execution of works on site and be carried out by a competent person.

Number and position of the plastic anchors to be tested should be adapted to the relevant special conditions of the construction work in question and, for example, in the case of blind and larger areas be increased such that a reliable information about the characteristic resistance of the plastic anchor embedded in the base material in question can be derived. The tests should take account of the unfavourable conditions of practical execution.

##### 4.4.2 Assembly

The plastic anchor to be tested shall be installed (e. g. preparation of drill hole, drilling tool to be used, drill bit, type of drilling hammer or rotation, thickness of fixture) and as far as spacing and edge distances are concerned be distributed in the same way as foreseen for the intended use.

Depending on the drilling tool hard metal hammer drill bits or hard metal percussion drill bits, respectively, according to ISO 5468 should be used. New drill bits should be used for one test series or drill bits with  $d_{\text{cut,m}} = 10,25 \text{ mm} < d_{\text{cut}} \leq 10,45 \text{ mm} = d_{\text{cut,max}}$ .

#### 4.4.3 Execution of test

The test rig used for the pull-out tests shall provide a continuous slow increase of the load, controlled by a calibrated load cell. The load shall apply perpendicular to the surface of the base material and shall be transmitted to the anchor via a hinge. The reaction forces shall be transmitted into the base material such that possible breakout of the masonry is not restricted. This condition is considered as fulfilled, if the support reaction forces are transmitted either in adjacent masonry units or at a distance of at least 150 mm from the plastic anchors. The load shall be increased continuously in a way that the ultimate load is reached after about 1 minute. The load is measured when the ultimate load ( $N_1$ ) is achieved.

If no pull-out failure occurs, other test methods are needed, e.g. proof-loading.

#### 4.4.4 Test report

The test report shall include all information necessary to assess the resistance of the tested anchor. It shall be given to the person responsible for the design of the fastening and shall be included in the construction dossier.

The minimum data required are:

- Name of product
- Construction site, owner of building; date and location of the tests, air temperature
- Test rig
- Type of structure to be fixed
- Base material (e.g. strength class, dimensions of brick)
- Plastic anchor and special screw
- value of the cutting diameter of hard metal hammer-drill bits, measured before and after drilling if no new drill bits are used
- Results of tests including the indication of value  $N_1$ ; mode of failure
- Tests carried out or supervised by ...; signature

#### 4.4.5 Evaluation of test results

The characteristic resistance  $F_{Rk1}$  is derived from the measured values  $N_1$  as follows

$$F_{Rk1} = 0,5 \cdot N_1$$

The characteristic resistance  $F_{Rk1}$  has to be equal or smaller than the characteristic resistance  $F_{Rk}$  which is given in the ETA for the equivalent base material

$$N_1 = \text{the mean value of the five smallest measured values at ultimate load}$$

In absence of national regulations the partial safety factors for the resistance of the plastic anchor may be taken as  $\gamma_{MAAC} = 2.0$  for use in autoclaved aerated concrete.

## 5 Indications to the manufacturer

### 5.1 Responsibility of the manufacturer

It is in the responsibility of the manufacturer to ensure that the information on the specific conditions according to 1 and 2 including Annexes referred to 4 is given to those who are concerned. This information may be made by reproduction of the respective parts of the European Technical Approval. In addition, all installation data shall be shown clearly on the packaging and/or on an enclosed instruction sheet, preferably using illustrations.

The minimum data required are:

- base material for the intended use,
- ambient temperature of the base material during installation of the anchor,
- drill bit diameter ( $d_{cut}$ ),
- overall anchor embedment depth in the base material ( $h_{nom}$ ),
- minimum hole depth ( $h_0$ ),
- information on the installation procedure,
- identification of the manufacturing batch.

All data shall be presented in a clear and explicit form.

### 5.2 Packaging, transport and storage


The anchor shall only be packaged and supplied as a complete unit.

The anchor shall be stored under normal climatic conditions in its original light-proof packaging. Before installation, it shall not be extremely dried nor frozen.


Georg Feistel  
Head of Department

*beglaubigt:*  
Bürger

**EJOT SDP-10G**



**Picture 1: Intended use: screw head-type: countersunk (S)**



**Picture 2: intended use: screw head-type: hexagon head with collar (KB)**

**Application range – anchorage in autoclaved aerated concrete (AAC)**

- h** = thickness of member
- h<sub>1</sub>** = depth of drill hole to deepest point
- h<sub>nom</sub>** = embedment depth of the anchor in the member (setting depth)
- t<sub>tol</sub>** = thickness of equalizing layer or non-load-bearing layer
- t<sub>fix</sub>** = t<sub>tol</sub> + thickness of fixture

EJOT SDP-S-10G and EJOT SDP-KB-10G

Product and intended use


Annex 1

### EJOT SDP-S-10G

#### Plastic sleeve



#### Special screw



Picture 3: Type of anchor: countersunk (S)

#### Anchor marking:

manufacturer, anchor type incl. head type, diameter, length (at the anchor tip)


example: EJOT SDP-S-10S x 140

#### screw marking:


length of anchor (e.g. 100)

### EJOT SDP-KB-10G

#### Plastic sleeve



#### Special screw



Picture 4: Type of anchor: collar with flange (KB)

#### Anchor marking:

manufacturer, anchor type incl. head type, diameter, length (at the anchor tip)

example: EJOT SDP-KB-10S x 140

#### screw marking:


length of anchor (e.g. 100)

EJOT SDP-S-10G and EJOT SDP-KB-10G

Anchor marking and marking of the special screw


Annex 2

**Example of product explanation:**



**Table 1: Dimensions [mm]**

Anchor type	Anchor sleeve							Appropriate specific screw		
	color	d <sub>nom</sub>	h <sub>nom</sub>	min t <sub>fix</sub>	max t <sub>fix</sub>	min l <sub>a</sub>	max l <sub>a</sub>	d <sub>s</sub>	c <sub>1</sub>	c
SDP – KB - ø10G	orange	10	70	10	150	80	220	7,0	55	80
SDP – S - ø10G	orange	10	70	10	150	80	220	7,0	55	80



EJOT SDP-S-10G and EJOT SDP-KB-10G

Example of product marking  
Dimensions

Annex 3

**Table 2: Material**

<b>Element</b>	<b>material</b>
<b>Anchor sleeve</b>	Polyamide, colour orange
<b>Specific screw</b>	Carbon steel galvanized zinc plated > 5 µm according to EN ISO 4042, blue passivated, coated
	Stainless steel, material number 1.4401 / 1.4571 (e.g. A4 according to ISO 3506), coated

**Table 3: Installation parameters**

<b>Anchor type</b>		SDP - KB – 10G SDP - S – 10G
<b>Use category</b>		d
<b>Drill hole diameter</b>	$d_o$ [mm] =	10
<b>Cutting diameter of drill bit</b>	$d_{cut}$ [mm] ≤	10,45
<b>Depth of drill hole to deepest point</b>	$h_1$ [mm] ≥	80
<b>embedment depth of the anchor in the member</b>	$h_{nom}$ [mm] ≥	70
<b>Diameter of the clearance hole in the fixture</b>	$d_f$ [mm] =	10,5
<b>Installation temperature</b>	[°C]	-10 bis +40
<b>Temperature range</b>	[°C]	-40 bis +80
<b>maximum long-term temperature</b>	[°C]	+50
<b>maximum short-term temperature</b>	[°C]	+80

EJOT SDP-S-10G and EJOT SDP-KB-10G


Materials, installation parameters

Annex 4

**Table 4: Minimum thickness of member, edge-distance and spacing in autoclaved aerated concrete (use category „d“)**

EJOT SDP-10G			AAC 2	AAC 6
Setting depth	$h_{nom} \geq$	[mm]	70	
Minimum thickness of substrate	$h_{min} \geq$	[mm]	115	175
Single anchor	Minimal allowable spacing	$a_{min} \geq$	250	250
	Minimal allowable edge distance	$c_{1min} \geq$	100	120
	Minimal allowable edge distance	$c_{2min} \geq$	100	130
Anchor group	min. spacing perpendicular to free edge	$s_{1,min} \geq$	80	95
	min. spacing parallel to free edge	$s_{2,min} \geq$	80	95

**Scheme of spacing and edge distances**



EJOT SDP-S-10G and EJOT SDP-KB-10G

Minimum thickness of member, edge distance and spacing

Annex 5

**Table 5: Characteristic resistance  $F_{Rk}$  for use in autoclaved aerated concrete (use category „d“<sup>1)</sup>)**

			characteristic resistance $F_{Rk}$ <sup>2) 4)</sup> in kN
tension resistance	AAC 2 $F_{Rk}$	[kN]	0,75
	AAC 6 $F_{Rk}$	[kN]	3,0
Partial safety factor	$\gamma_{MAAC}$ <sup>3)</sup>		2,0

**Table 6: Characteristic bending moment of specific screw**

	$M_{Rk,s}$ [Nm]	$\gamma_{Ms}$ <sup>3)</sup>
carbon steel, galvanized	17,7	1,5
stainless steel	20,6	1,87

- 1) Drill-hole only with rotary drilling
- 2) Characteristic resistance for tension, shear or combined tension and shear loading.  
The characteristic resistance is valid for single anchor or for a group of two or four plastic anchors with a spacing equal or larger than the minimum spacing  $s_{min}$  according to Table 4. The specific conditions for the design method have to be considered according to chapter 4.2.2 of the ETA. Interim values can be interpolated.
- 3) In absence of other national regulations
- 4) The bearing strength of AAC with strength classes  $>6$  N/mm<sup>2</sup> is limited by  $F_{Rk}$  of AAC 6.

**Table 7: Displacements under tension load and shear load in autoclaved aerated concrete**

	F [kN]	$\delta_{N0}$ [mm]	$\delta_{N\infty}$ [mm]	$\delta_{V0}$ [mm]	$\delta_{V\infty}$ [mm]
SDP-S $\varnothing$ 10G / SDP-KB $\varnothing$ 10G	0,27	0,18	0,36	0,54	0,81

EJOT SDP-S-10G and EJOT SDP-KB-10G

Characteristic resistance, displacements

Annex 6