

Approval body for construction products
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and
Laender Governments



European Technical Assessment

ETA-10/0141
of 22 August 2014

General Part

Technical Assessment Body issuing the
European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

Nobex heavy-duty anchor SXP

Product family
to which the construction product belongs

Torque controlled expansion anchor for use in
non-cracked concrete

Manufacturer

NOBEX srl
Via Monviso, 5
27010 SIZIANO (PV)
ITALIEN

Manufacturing plant

Nobex, plant 1 - Italy

This European Technical Assessment
contains

12 pages including 3 annexes which form an integral part
of this assessment

This European Technical Assessment is
issued in accordance with Regulation (EU)
No 305/2011, on the basis of

Guideline for European technical approval of "Metal
anchors for use in concrete", ETAG 001 Part 2: "Torque
controlled expansion anchors", April 2013,
used as European Assessment Document (EAD)
according to Article 66 Paragraph 3 of Regulation (EU)
No 305/2011.

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission according to Article 25 Paragraph 3 of Regulation (EU) No 305/2011.

Specific Part

1 Technical description of the product

The Nobex heavy-duty Anchor SXP (type SXP/SXP-X, type SXP-B/SXP-XB, type SXP-P) in the range of M6, M8, M10 and M12 is an anchor made of galvanised steel or stainless steel which is placed into a drilled hole and anchored by torque-controlled expansion.

The product description is given in Annex A.

2 Specification of the intended use in accordance with the applicable European assessment Document

The performances given in Section 3 are only valid if the anchor is used in compliance with the specifications and conditions given in Annex B.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the anchor of at least 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and references to the methods used for its assessment

3.1 Mechanical resistance and stability (BWR 1)

Essential characteristic	Performance
Characteristic resistance and Displacements under tension loads	See Annex C 1
Characteristic resistance and Displacements under shear loads	See Annex C 2

3.2 Safety in case of fire (BWR 2)

Essential characteristic	Performance
Reaction to fire	Anchorage satisfy requirements for Class A1
Resistance to fire	No performance determined (NPD)

3.3 Hygiene, health and the environment (BWR 3)

Regarding dangerous substances there may be requirements (e.g. transposed European legislation and national laws, regulations and administrative provisions) applicable to the products falling within the scope of this European Technical Assessment. In order to meet the provisions of Regulation (EU) No 305/2011, these requirements need also to be complied with, when and where they apply.

3.4 Safety in use (BWR 4)

The essential characteristics regarding Safety in use are included under the Basic Works Requirement Mechanical resistance and stability.

3.5 Protection against noise (BWR 5)

Not applicable.

3.6 Energy economy and heat retention (BWR 6)

Not applicable.

3.7 Sustainable use of natural resources (BWR 7)

The sustainable use of natural resources was not investigated.

3.8 General aspects

The verification of durability is part of testing the essential characteristics. Durability is only ensured if the specifications of intended use according to Annex B are taken into account.

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

According to Decision of the Commission of 24 June 1996 (96/582/EC) (OJ L 254 of 08.10.96 p. 62-65), the system of assessment and verification of constancy of performance (see Annex V and Article 65 Paragraph 2 to Regulation (EU) No 305/2011) given in the following table applies.

Product	Intended use	Level or class	System
Metal anchors for use in concrete (heavy-duty type)	For fixing and/or supporting concrete structural elements or heavy units such as cladding and suspended ceilings	—	1

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable European assessment Document

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited at Deutsches Institut für Bautechnik.


Issued in Berlin on 22 August 2014 by Deutsches Institut für Bautechnik

Uwe Bender
Head of Department


beglaubigt:
Baderschneider

Installed conditions

Pre-setting Installation Type SXP (SXP-X) and Type SXP-B (SXP-XB):



Through-setting installation Type SXP-P:




Nobex Heavy-duty anchor SXP


Product description
Installed condition

Annex A 1

Type SXP (SXP-X) ¹⁾ and Type SXP-B (SXP-XB) ²⁾ Type SXP-P




- ① Conical nut
- ② Expander
- ③ Washer
- ④ Hexagonal head bolt



- ① Conical nut
- ② Expander
- ④ Hexagonal head bolt
- ⑤ Spacer ring
- ⑥ Distance sleeve
- ⑦ Washer

- 1) The hexagon head bolt and the washer according to Table A1 and B1 must be purchased by the user.
2) The hexagon head bolt and the washer is provided by the manufacturer together with the anchor.

**Marking:
Anchor identity (SXP)**



- Marking:**
- Identifying mark of manufacturer
 - Drill hole diameter (e.g. Ø10)
 - Thread size (e.g. M6)

Nobex Heavy-duty anchor SXP

Product description
Marking and denomination

Annex A 2

Table A1: Materials

Comp.	Denomination	Type	Material
1	Conical nut	SXP SXP-B SXP-P	Steel, EN 10139:1997 Electrolytic zinc plated, EN ISO 4042:1999 min. 5 µm
		SXP-X SXP-XB	Stainless steel 1.4401, 1.4404 or 1.4571 EN 10088-1:2005
2	Expander	SXP SXP-B SXP-P	Cold formed steel, EN 10111:2008 Electrolytic zinc plated, EN ISO 4042:1999 min. 5 µm
		SXP-X SXP-XB	Stainless steel 1.4401, 1.4404 or 1.4571 EN 10088-1:2005
3 / 7	Washer	SXP SXP-B SXP-P	Steel min. 140 HV Electrolytic zinc plated, EN ISO 4042:1999 min. 5 µm
		SXP-X SXP-XB	Stainless steel 1.4401, 1.4404 or 1.4571 EN 10088-1:2005
4	Hexagonal head bolt	SXP SXP-B SXP-P	Steel, property class 8.8 EN ISO 898-1:2012 Electrolytic zinc plated, EN ISO 4042:1999 min. 5 µm
		SXP-X SXP-XB	Stainless steel 1.4401, 1.4404 or 1.4571 EN 10088-1:2005
5	Spacer ring	SXP-P	Polypropylene
6	Distance sleeve	SXP-P	Cold formed steel, EN 10111:2008 or Drawn pipe E235+C, EN 10305-2:2010 Electrolytic zinc plated, EN ISO 4042:1999 min. 5 µm

Nobex Heavy-duty anchor SXP

Product description
Materials

Annex A 3

Specifications of intended use

Anchorage subject to:

- Static and quasi-static loads.

Base materials:

- Reinforced or unreinforced normal weight concrete according to EN 206-1:2000.
- Strength classes C20/25 to C50/60 according to EN 206-1:2000.
- Non-cracked concrete.

Use conditions (Environmental conditions):

- Structures subject to dry internal conditions (zinc coated steel or stainless steel).
- Structures subject to external atmospheric exposure (including industrial and marine environment) and to permanently damp internal condition, if no particular aggressive conditions exist (stainless steel).

Note: Particular aggressive conditions are e.g. permanent, alternating immersion in seawater or the splash zone of seawater, chloride atmosphere of indoor swimming pools or atmosphere with extreme chemical pollution (e.g. in desulphurization plants or road tunnels where de-icing materials are used).

Design:

- Verifiable calculation notes and drawings are prepared taking account of the loads to be anchored. The position of the anchor is indicated on the design drawings (e. g. position of the anchor relative to reinforcement or to supports, etc.).
- Anchorages are designed under the responsibility of an engineer experienced in anchorages and concrete work.
- Anchorages are designed in accordance with ETAG 001, Annex C, design method A Edition August 2010.

Installation:

- Hole drilling by hammer drilling only.
- Anchor installation carried out by appropriately qualified personnel and under the supervision of the person responsible for technical matters of the site.
- hexagonal head bolt and washer for type SXP / SXP-X may be used if the following requirements are fulfilled:
 - material, dimensions and mechanical properties of the metal parts according to the specifications given in Annex A 3 and B 2,
 - confirmation of material and mechanical properties of the metal parts by inspection certificate 3.1 according to EN 10204:2004, the documents should be stored,
 - Length of hexagonal head bolt according to Table B1 shall be complied with.
- in case of aborted hole: new drilling at a minimum distance away of twice the depth of the aborted hole or smaller distance if the aborted drill hole is filled with high strength mortar and if under shear or oblique tension load it is not in the direction of load application.
- anchor installation such that the effective anchorage depth is complied with. This compliance is ensured, if the leading edge of expander does not more exceed the concrete surface.

Nobex Heavy-duty anchor SXP

**Intended Use
Specifications**

Annex B 1

Table B1: Installation Parameters

Anchor size			M6	M8	M10	M12
Effective anchorage depth	h_{ef}	[mm]	39,5	44,5	51,5	63,0
Nominal drill hole diameter	d_0	[mm]	10	12	14	18
Cutting diameter of drill bit	$d_{cut} \leq$	[mm]	10,45	12,50	14,50	18,50
Drill hole depth	$h_1 \geq$	[mm]	$L_S - t_{fix} + 10$	$L_S - t_{fix} + 10$	$L_S - t_{fix} + 10$	$L_S - t_{fix} + 10$
Clearance hole diameter in the fixture	SXP, SXP-X SXP-B, SXP-XB	$d_f \leq$	7	9	12	14
	SXP-P	$d_f \leq$	12	14	18	20
Torque moment	T_{inst}	[Nm]	10	25	40	75
Min. fixture thickness	SXP, SXP-X SXP-B, SXP-XB SXP-P	$t_{fix,min}$	1	1	1	1
Max. fixture thickness	SXP	$t_{fix,max}$	150	200	250	300
	SXP-X	$t_{fix,max}$	50	65	85	70
	SXP-B, SXP-XB	$t_{fix,max}$	10	14	20	25
	SXP-P	$t_{fix,max}$	30	35	38	43
Hexagonal head bolt length	SXP, SXP-X	$L_S \geq$	$t_{fix}+45$	$t_{fix}+51$	$t_{fix}+60$	$t_{fix}+75$
	SXP-B, SXP-XB	L_S	55	65	80	100
	SXP-P	L_S	80	90	100	120

Table B2: Minimum thickness of concrete member, minimum spacing and edge distances

Anchor size			M6	M8	M10	M12
Minimum thickness member	h_{min}	[mm]	135	135	140	160
Minimum spacing	s_{min}	[mm]	65	90	135	165
Minimum edge distance	c_{min}	[mm]	45	70	85	115

Nobex Heavy-duty anchor SXP


Intended Use

Installation parameters


Minimum thickness of concrete member, minimum spacing and edge distances

Annex B 2

**Pre-setting installation instruction for:
Type SXP (SXP-X) / SXP-B (SXP-XB)**



**Through-setting installation instruction for
Type SXP-P**



Nobex Heavy-duty anchor SXP

Intended Use
Installation instructions

Annex B 3

Table C1: Design method A, Characteristic values for tension loads

Anchor size			M6	M8	M10	M12
Steel failure						
Characteristic resistance, Anchor type SXP, SXP-B, SXP-P	$N_{Rk,s}$	[kN]	16,1	29,3	46,4	67,4
Partial safety factor	γ_{Ms}		1,5			
Characteristic resistance, Anchor type SXP-X, SXP-XB	$N_{Rk,s}$	[kN]	14,1	25,6	40,6	59,0
Partial safety factor	γ_{Ms}		1,87			
Pullout failure						
Characteristic resistance in non-cracked concrete C20/25, Anchor type SXP, SXP-B, SXP-P	$N_{Rk,p}$	[kN]	9	12	16	20
Characteristic resistance in non-cracked concrete C20/25, Anchor type SXP-X, SXP-XB	$N_{Rk,p}$	[kN]	7,5	9	12	16
Increasing factors for concrete	ψ_c	C30/37	[-]	1,17	1,08	1,22
		C40/50	[-]	1,33	1,15	1,41
		C50/60	[-]	1,50	1,23	1,55
Concrete cone failure						
Effective anchoring depth	h_{ef}	[mm]	39,5	44,5	51,5	63,0
Spacing	$s_{cr,N}$	[mm]	3 h_{ef}			
Edge distance	$c_{cr,N}$	[mm]	1,5 h_{ef}			
Splitting failure						
Spacing	$s_{cr,sp}$	[mm]	160	200	260	280
Edge distance	$c_{cr,sp}$	[mm]	80	100	130	140
Installation safety factor, Anchor type SXP, SXP-B, SXP-P	γ_2	[-]	1,2	1,4	1,4	1,0
Installation safety factor, Anchor type SXP-X, SXP-XB	γ_2	[-]	1,0	1,2	1,2	1,2

Table C2: Displacements under tension loads

Anchor size			M6	M8	M10	M12
Tension load	N	[kN]	3,6	4,1	5,4	9,5
Displacement	δ_{N0}	[mm]	0,4	0,3	0,3	0,3
	$\delta_{N\infty}$	[mm]	1,2			

Nobex Heavy-duty anchor SXP

Performances

Design method A, Characteristic values of resistance under tension loads
Displacements under tension loads

Annex C 1

Table C3: Design method A, Characteristic values for shear loads

Anchor size			M6	M8	M10	M12
Steel failure without level arm						
Characteristic resistance, Anchor type SXP, SXP-B, SXP-P	$V_{Rk,s}$	[kN]	8,0	14,6	23,2	33,7
Partial safety factor	γ_{Ms}		1,5			
Characteristic resistance, Anchor type SXP-X, SXP-XB	$V_{Rk,s}$	[kN]	7,0	12,8	20,3	29,5
Partial safety factor	γ_{Ms}		1,87			
Steel failure with level arm						
Characteristic bending moment, Anchor type SXP, SXP-B, SXP-P	$M_{Rk,s}$	[Nm]	12,2	30,0	59,8	104,8
Partial safety factor	γ_{Ms}		1,5			
Characteristic bending moment, Anchor type SXP-X, SXP-XB	$M_{Rk,s}$	[Nm]	10,7	26,2	52,3	91,7
Partial safety factor	γ_{Ms}		1,87			
Concrete pry out failure						
Factor in equation (5.6), ETAG 001, Annex C, 5.2.3.3	k	[-]	1,0	1,0	1,0	2,0
Installation safety factor	γ_2	[-]	1,0			
Concrete edge failure						
Effective length of anchor in shear loading	l_f	[mm]	39,5	44,5	51,5	63,0
Effective external diameter of anchor	d_{nom}	[mm]	10	12	14	18
Installation safety factor	γ_2	[-]	1,0			

Table C4: Displacements under shear loads

Anchor size			M6	M8	M10	M12
Shear load	V	[kN]	5,1	6,9	7,6	9,5
Displacement	δ_{V0}	[mm]	6,0	5,3	5,3	5,0
	$\delta_{V\infty}$	[mm]	9,0	8,0	8,0	7,5

Nobex Heavy-duty anchor SXP

Performances

Design method A, Characteristic values of resistance under shear loads
Displacements under shear loads

Annex C 2