

Approval body for construction products
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and
Laender Governments



European Technical Assessment

ETA-15/0004
of 26 January 2015

General Part

Technical Assessment Body issuing the
European Technical Assessment:

Trade name of the construction product

Product family
to which the construction product belongs

Manufacturer

Manufacturing plant

This European Technical Assessment
contains

This European Technical Assessment is
issued in accordance with Regulation (EU)
No 305/2011, on the basis of

Deutsches Institut für Bautechnik

"TecTem Insulation Board Indoor"

Thermal insulation boards made of expanded perlite,
deviating from EN 13169

KNAUF AQUAPANEL GmbH
Kipperstraße 19
44147 Dortmund
DEUTSCHLAND

KNAUF AQUAPANEL GmbH
Kipperstraße 19
44147 Dortmund
DEUTSCHLAND

7 pages which form an integral part of this assessment

European Assessment Document (EAD)
No 040010-00-1201, "Insulation product made of
expanded perlite (EPB)".

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission according to Article 25 Paragraph 3 of Regulation (EU) No 305/2011.

Specific Part

1 Technical definition of the construction product

This European Technical Assessment applies to the factory-made thermal insulation boards made of expanded perlite (EPB) with the designation "TecTem Insulation Board Indoor", hereafter referred to as thermal insulation boards.

The thermal insulation boards deviate from the standard EN 13169:2013 as they do not contain reinforcing fibres and do not fulfil the minimum value of bending strength stated in the standard.

The thermal insulation boards are manufactured of expanded perlite by adding a binding agent and other additives and they are not coated.

The thermal insulation boards are made with the following dimensions:

Nominal thicknesses:	50 mm to 200 mm
Nominal length:	500 mm to 1250 mm
Nominal widths:	400 mm to 1250 mm

The European Technical Assessment has been issued for the product on the basis of agreed data/ information, deposited with Deutsches Institut für Bautechnik, which identifies the product that has been assessed. The European Technical Assessment applies only to products corresponding to this agreed data/information.

2 Specification of the intended use in accordance with the applicable European Assessment Document (EAD)

The thermal insulation boards can be used as follows:

- internal insulation of walls
- internal insulation of ceilings

The performance according to section 3 only applies if the thermal insulation boards are installed according to the manufacture's installation instructions and if they are protected from precipitation, wetting or weathering in built-in state and during transport, storage and installation.

Concerning the application of the thermal insulation boards, also the respective national regulations shall be observed.

The design value of the thermal conductivity shall be laid down according to relevant national provisions.

When calculating the thermal resistance, the nominal thickness of the insulation materials shall be applied.

Where the thermal insulation boards are fixed by using adhesives and/or anchors, only such adhesions or anchors shall be used, which are suitable for this purpose. The assessment of these fixings is not subject of this European Technical Assessment.

3 Performance of the product and references to the methods used for its assessment

For sampling, conditioning and testing the provisions of the EAD No 040010-00-1201, "Insulation product made of expanded perlite (EPB)" apply.

3.1 Mechanical resistance and stability (BWR 1)

Not applicable

3.2 Safety in case of fire (BWR 2)

Essential characteristic	Performance
Reaction to fire: Test acc. to EN ISO 1182:2010 and EN ISO 1716:2010	Class A1 acc. to EN 13501-1:2010

3.3 Hygiene, health and the environment (BWR 3)

Essential characteristic	Performance
Content and/or release of dangerous substances:	The product does not contain or release dangerous substances according to EOTA TR034 (version April 2014).
Water vapour diffusion resistance coefficient: Test acc. to EN 12086:2013	$\mu = 5$ to 6^1

3.4 Safety and accessibility (BWR 4)

Not applicable

3.5 Protection against noise (BWR 5)

Essential characteristic	Performance
Sound absorption:	No performance determined.

¹ The most unfavorable value for the construction product work shall be applied each.

3.6 Energy economy and heat retention (BWR 6)

Essential characteristic	Performance
Thermal conductivity: Test acc. to EN 12667:2001, acc. to EN 13169:2013: Conversion of humidity acc. to EN ISO 10456:2010 The mass-related moisture content at 23 °C/ 50 % rel. humidity: The mass-related moisture content at 23 °C/ 80 % rel. humidity: The mass-related moisture conversion coefficient: Moisture conversion factor (dry to 23 °C/ 50 % rel. humidity): Moisture conversion factor (23 °C/ 50 % rel. humidity to 23 °C/ 80 % rel. humidity):	Declared value*) for a moisture content of the insulation boards at 23 °C and 50 % relative humidity: $\lambda_{D(23/50)} = 0.045 \text{ W/(m}\cdot\text{K)}$ $u_{23/50} = 0.02 \text{ kg/kg}$ $u_{23/80} = 0.03 \text{ kg/kg}$ $f_u = 0.8$ $F_{m1} = 1.02$ $F_{m2} = 1.01$
Dimensional deviations (individual values): Length and width: Test acc. EN 822:2013 Thickness: Test acc. EN 823:2013 (with a load of 250 Pa) Squareness in direction of length and width: Test acc. EN 824:2013 Flatness:	$\pm 3 \text{ mm}$ $\pm 2 \text{ mm}$ $\leq 3 \text{ mm/m}$ No performance determined.
Water absorption:	No performance determined.

*) The declared value of thermal conductivity is representative for at least 90 % of the production with a confidence level of 90 % and applies to the density range. For the admissible deviation of an individual value of the thermal conductivity from the declared value the method described in EN 13172:2012, annex F, applies.

3.7 Sustainable use of natural resources (BWR 7)

For the sustainable use of natural resources no performance was investigated for this product.

3.8 General aspects relating to the performances of the construction product

Essential characteristic	Performance
Density: Test acc. to EN 1602:2013	Density range: 90 kg/m ³ - 105 kg/m ³
Bending strength (individual value): Test acc. to EN 12089:2013	≥ 120 kPa
Compressive strength (individual value): Test acc. to EN 826:2013	≥ 200 kPa CS(10\Y)200 acc. to EN 13169
Deformation under specified load and temperature: Test acc. to EN 1605:2013 (Test conditions 80 kPa, 60 °C, 168 h)	Relative thickness reduction (compression): ≤ 5% DLT(3)5 acc. to EN 13169:2013
Dimensional stability at 23° C and 90% relative humidity: Test acc. to EN 1604:2013 Conditioning: 48 h, at (23±2) °C and (90±5) % relative humidity	Relative changes in length, width and thickness: max. ± 0.5%
Dimensional stability at 70° C and 50% relative humidity: Test acc. to EN 1604:2013 Conditioning: 48 h, at (70±2) °C and (50±5) % relative humidity	Relative changes in length, width and thickness: max. ± 0.5%
Tensile strength perpendicular to faces (individual value): Test acc. to EN 1607:2013 in accordance with EN 13169: 2013	≥ 80 kPa
Compressive creep:	No performance determined.
Point load:	No performance determined.

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

According to Decision of the Commission 1999/91/EC as amended by Decision of the Commission 2001/596/EC, the systems of assessment and verification of constancy of performance (see Annex V and Article 65 Paragraph 2 to Regulation (EU) No 305/2011) shall be applied according to the following table:

Product	Intended use	System
" TecTem Insulation Board Indoor "	Reaction to fire	1
	all others properties	3

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited at Deutsches Institut für Bautechnik.

Issued in Berlin on 26 January 2015 by Deutschen Institut für Bautechnik

Dirk Brandenburger
Head of Department

beglaubigt:
Koper