

Approval body for construction products
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and
Laender Governments

★ ★ ★ ★ ★
★ ★ ★ ★ ★
Designated
according to
Article 29 of Regula-
tion (EU) No 305/2011
and member of EOTA
(European Organi-
sation for Technical
Assessment)
★ ★ ★ ★ ★

European Technical Assessment

ETA-11/0493
of 3 February 2017

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the
European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

Injection system Hilti HIT-HY 200-A

Product family
to which the construction product belongs

Bonded anchor for use in concrete

Manufacturer

Hilti Aktiengesellschaft
9494 SCHAAN
FÜRSTENTUM LIECHTENSTEIN

Manufacturing plant

Hilti Werke

This European Technical Assessment
contains

36 pages including 3 annexes

This European Technical Assessment is
issued in accordance with Regulation (EU)
No 305/2011, on the basis of

Guideline for European technical approval of "Metal
anchors for use in concrete", ETAG 001 Part 5: "Bonded
anchors", April 2013,
used as European Assessment Document (EAD)
according to Article 66 Paragraph 3 of Regulation (EU)
No 305/2011.

This version replaces

ETA-11/0493 issued on 15 April 2015

European Technical Assessment

ETA-11/0493

English translation prepared by DIBt

Page 2 of 36 | 3 February 2017

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

Specific Part**1 Technical description of the product**

The Injection system Hilti HIT-HY 200-A is a bonded anchor consisting of a foil pack with injection mortar Hilti HIT-HY 200-A and a steel element according to Annex A.

The steel element is placed into a drilled hole filled with injection mortar and is anchored via the bond between metal part, injection mortar and concrete.

The product description is given in Annex A.

2 Specification of the intended use in accordance with the applicable European Assessment Document

The performances given in Section 3 are only valid if the anchor is used in compliance with the specifications and conditions given in Annex B.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the anchor of at least 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and references to the methods used for its assessment**3.1 Mechanical resistance and stability (BWR 1)**

| Essential characteristic | Performance |
|--|----------------------|
| Characteristic resistance under static and quasi-static action for design according to TR 029, displacements | See Annex C1 to C12 |
| Characteristic resistance for seismic performance category C1 for design according to TR 045, displacements | See Annex C13 to C16 |

3.2 Safety in case of fire (BWR 2)

| Essential characteristic | Performance |
|--------------------------|--|
| Reaction to fire | Anchorages satisfy requirements for Class A1 |
| Resistance to fire | No performance determined (NPD) |

3.3 Hygiene, health and the environment (BWR 3)

Regarding dangerous substances there may be requirements (e.g. transposed European legislation and national laws, regulations and administrative provisions) applicable to the products falling within the scope of this European Technical Assessment. In order to meet the provisions of Regulation (EU) No 305/2011, these requirements need also to be complied with, when and where they apply.

3.4 Safety in use (BWR 4)

The essential characteristics regarding Safety in use are included under the Basic Works Requirement Mechanical resistance and stability.

European Technical Assessment

ETA-11/0493

English translation prepared by DIBt

Page 4 of 36 | 3 February 2017

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with guideline for European technical approval ETAG 001, April 2013 used as European Assessment Document (EAD) according to Article 66 Paragraph 3 of Regulation (EU) No 305/2011 the applicable European legal act is: [96/582/EC].

The system to be applied is: 1

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable European Assessment Document

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited at Deutsches Institut für Bautechnik.

Issued in Berlin on 3 February 2017 by Deutsches Institut für Bautechnik

Uwe Bender
Head of Department

beglaubigt:
Lange

Installed condition

Figure A1:

Threaded rod and HIT-V-..., AM 8.8




Figure A2:

Internally threaded sleeve HIS-(R)N





Figure A3:

Reinforcing bar



Injection System Hilti HIT-HY 200-A

Product description
Installed condition

Annex A1

Product description: Injection mortar and steel elements

Injection mortar Hilti HIT-HY 200-A: hybrid system with aggregate

330 ml and 500 ml

Marking:
HILTI-HIT
Production number and
production line
Expiry date mm/yyyy




Product name: "Hilti HIT-HY 200-A"

Static mixer Hilti HIT-RE-M




Steel elements



Threaded rod and HIT-V-...: M8 to M30

washer


nut




Hilti meter rod AM 8.8, electroplated zinc coated M8 to M30, 1m to 3m

Commercial standard threaded rod:

- Materials and mechanical properties according to Table A1.
- Inspection certificate 3.1 according to EN 10204:2004. The document shall be stored.
- Marking of embedment depth.



Internally threaded sleeve: HIS-(R)N M8 to M20



Hilti Tension Anchor: HZA M12 to M27 and HZA-R M12 to M24

Injection System Hilti HIT-HY 200-A

Product description

Injection mortar / Static mixer / Steel elements


Annex A2

Product description: Injection mortar and steel elements



Reinforcing bar (rebar): ϕ 8 to ϕ 32

- Materials and mechanical properties according to Table A1
- Dimensions according to Annex B6



Hilti Filling Set

Injection System Hilti HIT-HY 200-A

Product description

Injection mortar / Static mixer / Steel elements

Annex A3

Table A1: Materials

| Designation | Material |
|---|--|
| Reinforcing bars | |
| Rebar: EN 1992-1-1: 2004 and AC:2010, Annex C | Bars and de-coiled rods class B or C with f_{yk} and k according to NDP or NCL of EN 1992-1-1/NA:2013 $f_{uk} = f_{tk} = k \cdot f_{yk}$, fracture elongation $A_5 > 8\%$ |
| Metal parts made of zinc coated steel | |
| Threaded rod, HIT-V-5.8(F) | Strength class 5.8, $f_{uk} = 500 \text{ N/mm}^2$, $f_{yk} = 400 \text{ N/mm}^2$, Fracture elongation $A_5 > 8\%$, Electroplated zinc coated $\geq 5 \mu\text{m}$, (F) hot dip galvanized $\geq 45 \mu\text{m}$ |
| Threaded rod, HIT-V-8.8(F) | Strength class 8.8, $f_{uk} = 800 \text{ N/mm}^2$, $f_{yk} = 640 \text{ N/mm}^2$, Fracture elongation $A_5 > 12\%$, Electroplated zinc coated $\geq 5 \mu\text{m}$, (F) hot dip galvanized $\geq 45 \mu\text{m}$ |
| Hilti Meter rod, AM 8.8 | Strength class 8.8, $f_{uk} = 800 \text{ N/mm}^2$, $f_{yk} = 640 \text{ N/mm}^2$, Fracture elongation $A_5 > 12\%$, Electroplated zinc coated $\geq 5 \mu\text{m}$ |
| Hilti tension anchor HZA | Round steel with threaded part: electroplated zinc coated $\geq 5 \mu\text{m}$ Rebar: Bars class B according to NDP or NCL of EN 1992-1-1/NA:2013 |
| Internally threaded sleeve HIS-N | Electroplated zinc coated $\geq 5 \mu\text{m}$ |
| Washer | Electroplated zinc coated $\geq 5 \mu\text{m}$, hot dip galvanized $\geq 45 \mu\text{m}$ |
| Nut | Strength class of nut adapted to strength class of threaded rod Electroplated zinc coated $\geq 5 \mu\text{m}$, hot dip galvanized $\geq 45 \mu\text{m}$ |
| Hilti Filling set | Filling washer: Electroplated zinc coated $\geq 5 \mu\text{m}$ Spherical washer: Electroplated zinc coated $\geq 5 \mu\text{m}$ Lock nut: Electroplated zinc coated $\geq 5 \mu\text{m}$ |
| Metal parts made of stainless steel | |
| Threaded rod, HIT-V-R | For $\leq M24$: strength class 70, $f_{uk} = 700 \text{ N/mm}^2$, $f_{yk} = 450 \text{ N/mm}^2$; For $> M24$: strength class 50, $f_{uk} = 500 \text{ N/mm}^2$, $f_{yk} = 210 \text{ N/mm}^2$; Fracture elongation $A_5 > 8\%$ Stainless steel 1.4401, 1.4404, 1.4578, 1.4571, 1.4439, 1.4362 EN 10088-1:2014 |
| Hilti tension anchor HZA-R | Round steel with threaded part: Stainless steel 1.4404, 1.4362, 1.4571 EN 10088-1:2014 Rebar: Bars class B according to NDP or NCL of EN 1992-1-1/NA:2013 |
| Internally threaded sleeve HIS-RN | Stainless steel 1.4401, 1.4571 EN 10088-1:2014 |
| Washer | Stainless steel 1.4401, 1.4404, 1.4578, 1.4571, 1.4439, 1.4362 EN 10088-1:2014 |
| Nut | Strength class of nut adapted to strength class of threaded rod Stainless steel 1.4401, 1.4404, 1.4578, 1.4571, 1.4439, 1.4362 EN 10088-1:2014 |

Injection System Hilti HIT-HY 200-A

Product description
Materials

Annex A4

Metal parts made of high corrosion resistant steel

| | |
|---------------------------|---|
| Threaded rod HIT-V-HCR | For \leq M20: $f_{uk} = 800 \text{ N/mm}^2$, $f_{yk} = 640 \text{ N/mm}^2$, For $>$ M20: $f_{uk} = 700 \text{ N/mm}^2$, $f_{yk} = 400 \text{ N/mm}^2$, Fracture elongation $A_5 > 8\%$ High corrosion resistant steel 1.4529, 1.4565 EN 10088-1:2014 |
| Washer | High corrosion resistant steel 1.4529, 1.4565 EN 10088-1:2014 |
| Nut | Strength class of nut adapted to strength class of threaded rod High corrosion resistant steel 1.4529, 1.4565 EN 10088-1:2014 |

Injection System Hilti HIT-HY 200-A

Product description
Materials

Annex A5

Specifications of intended use

Anchorage subject to:

- Static and quasi static loading
- Seismic performance category C1: HIT-V, rebar, HZA-R, (not HIS-N)
- Seismic performance category C2: HIT-V 8.8, AM 8.8 and commercial standard threaded rod 8.8, zinc coated only, sizes M16 to M24 for hammer drilling and hammer drilling with hollow drill bit (TE-CD or TE-YD).

Base material:-

- Reinforced or unreinforced normal weight concrete according to EN 206-1:2000.
- Strength classes C20/25 to C50/60 according to EN 206-1:2000.
- Cracked and non-cracked concrete.

Temperature in the base material:

• at installation

-10 °C to +40 °C

• in-service

Temperature range I: -40 °C to +40 °C

(max. long term temperature +24 °C and max. short time temperature +40 °C)



Temperature range II: -40 °C to +80 °C

(max. long term temperature +50 °C and max. short time temperature +80 °C)

Temperature range III: -40 °C to +120 °C

(max. long term temperature +72 °C and max. short time temperature +120 °C)

Table B1: Specifications of intended use

| Elements | HIT-HY 200-A with ... | | | |
|---|--|--|--|---|
| | HIT-V ... AM 8.8  | Rebar  | HZA(-R)  | HIS-(R)N  |
| Hammer drilling with hollow drill bit TE-CD or TE-YD  | ✓ | ✓ | ✓ | ✓ |
| Hammer drilling  | ✓ | ✓ | ✓ | ✓ |
| Static and quasi static loading in cracked and non-cracked concrete | M8 to M30 | Ø 8 to Ø 32 | M12 to M27 | M8 to M20 |
| Seismic performance category C1 | M10 to M30 | Ø 10 to Ø 32 | M12 to M27 | - |
| Seismic performance category C2 | M16 to M24 (zinc coated only) | - | - | - |

Injection System Hilti HIT-HY 200-A

Intended Use Specifications

Annex B1

Use conditions (Environmental conditions):

- Structures subject to dry internal conditions (zinc coated steel, stainless steel or high corrosion resistant steel).
- Structures subject to external atmospheric exposure (including industrial and marine environment) and to permanently damp internal conditions, if no particular aggressive conditions exist (stainless steel or high corrosion resistant steel).
- Structures subject to external atmospheric exposure and to permanently damp internal conditions, if other particular aggressive conditions exist (high corrosion resistant steel).

Note: Particular aggressive conditions are e.g. permanent, alternating immersion in seawater or the splash zone of seawater, chloride atmosphere of indoor swimming pools or atmosphere with extreme chemical pollution (e.g. in desulphurization plants or road tunnels where de-icing products are used).

Design:

- Anchorages are designed under the responsibility of an engineer experienced in anchorages and concrete work.
- Verifiable calculation notes and drawings are prepared taking account of the loads to be anchored. The position of the anchor is indicated on the design drawings (e. g. position of the anchor relative to reinforcement or to supports, etc.).
- Anchorages under static or quasi-static loading are designed in accordance with:
“EOTA Technical Report TR 029, Edition September 2010”
- Anchorages under seismic actions (cracked concrete) are designed in accordance with:
“EOTA Technical Report TR 045, Edition February 2013”

Anchorages shall be positioned outside of critical regions (e.g. plastic hinges) of the concrete structure. Fastenings in stand-off installation or with a grout layer under seismic action are not covered in this European technical assessment (ETA).

Installation:

- Use category: dry or wet concrete (not in flooded holes)
- Overhead installation is admissible
- Anchor installation carried out by appropriately qualified personnel and under the supervision of the person responsible for technical matters of the site.

| | |
|--|--|
| Injection System Hilti HIT-HY 200-A | |
|--|--|

| | |
|---------------------------------------|--|
| Intended Use Specifications | |
|---------------------------------------|--|


| |
|-----------------|
| Annex B2 |
|-----------------|

Table B2: Installation parameters of threaded rod and HIT-V-... and AM 8.8

| Threaded rod and HIT-V-... AM 8.8 | M8 | M10 | M12 | M16 | M20 | M24 | M27 | M30 |
|--|---|-----------|-----------|-------------------------------|-----------|-----------|------------|------------|
| Diameter of element d [mm] | 8 | 10 | 12 | 16 | 20 | 24 | 27 | 30 |
| Nominal diameter of drill bit d_0 [mm] | 10 | 12 | 14 | 18 | 22 | 28 | 30 | 35 |
| Effective embedment depth and drill hole depth $h_{\text{ef}} = h_0$ [mm] | 60 to 160 | 60 to 200 | 70 to 240 | 80 to 320 | 90 to 400 | 96 to 480 | 108 to 540 | 120 to 600 |
| Maximum diameter of clearance hole in the fixture ¹⁾ d_f [mm] | 9 | 12 | 14 | 18 | 22 | 26 | 30 | 33 |
| Minimum thickness of concrete member h_{min} [mm] | $h_{\text{ef}} + 30$ $\geq 100 \text{ mm}$ | | | $h_{\text{ef}} + 2 \cdot d_0$ | | | | |
| Maximum torque moment T_{max} [Nm] | 10 | 20 | 40 | 80 | 150 | 200 | 270 | 300 |
| Minimum spacing s_{min} [mm] | 40 | 50 | 60 | 75 | 90 | 115 | 120 | 140 |
| Minimum edge distance c_{min} [mm] | 40 | 45 | 45 | 50 | 55 | 60 | 75 | 80 |


¹⁾ for larger clearance hole see "TR 029 section 1.1"

HIT-V-...



Marking:

- 5.8 - l = HIT-V-5.8 M...x l
- 5.8F - l = HIT-V-5.8F M...x l
- 8.8 - l = HIT-V-8.8 M...x l
- 8.8F - l = HIT-V-8.8F M...x l
- R - l = HIT-V-R M...x l
- HCR - l = HIT-V-HCR M...x l



Hilti meter rod AM 8.8, electroplated zinc coated M8 to M30, 1m to 3m

Injection System Hilti HIT-HY 200-A

Intended Use

Installation parameters of threaded rod and HIT-V-... and AM 8.8


Annex B3

Table B3: Installation parameters of internally threaded sleeve HIS-(R)N

| Internally threaded sleeve HIS-(R)N... | M8 | M10 | M12 | M16 | M20 |
|--|------|-------|-------|-------|-------|
| Outer diameter of sleeve d [mm] | 12,5 | 16,5 | 20,5 | 25,4 | 27,6 |
| Nominal diameter of drill bit d_0 [mm] | 14 | 18 | 22 | 28 | 32 |
| Effective embedment depth and drill hole depth $h_{ef} = h_0$ [mm] | 90 | 110 | 125 | 170 | 205 |
| Maximum diameter of clearance hole in the fixture ¹⁾ d_f [mm] | 9 | 12 | 14 | 18 | 22 |
| Minimum thickness of concrete member h_{min} [mm] | 120 | 150 | 170 | 230 | 270 |
| Maximum torque moment T_{max} [Nm] | 10 | 20 | 40 | 80 | 150 |
| Thread engagement length min-max h_s [mm] | 8-20 | 10-25 | 12-30 | 16-40 | 20-50 |
| Minimum spacing s_{min} [mm] | 60 | 75 | 90 | 115 | 130 |
| Minimum edge distance c_{min} [mm] | 40 | 45 | 55 | 65 | 90 |

¹⁾ for larger clearance hole see "TR 029 section 1.1"

Internally threaded sleeve HIS-(R)N...



Marking:
Identifying mark - HILTI and
embossing "HIS-N" (for C-steel)
embossing "HIS-RN" (for stainless steel)

Table B4: Installation parameters of Hilti tension anchor HZA-R

| Hilti tension anchor HZA-R ... | | M12 | M16 | M20 | M24 |
|--|-----------------------------|--------------------------------|------------|------------|------------|
| Rebar diameter | ϕ [mm] | 12 | 16 | 20 | 25 |
| Nominal embedment depth and drill hole depth | $h_{\text{nom}} = h_0$ [mm] | 170 to 240 | 180 to 320 | 190 to 400 | 200 to 500 |
| Effective embedment depth ($h_{\text{ef}} = h_{\text{nom}} - l_e$) | h_{ef} [mm] | $h_{\text{nom}} - 100$ | | | |
| Length of smooth shaft | l_e [mm] | 100 | | | |
| Nominal diameter of drill bit | d_0 [mm] | 16 | 20 | 25 | 32 |
| Maximum diameter of clearance hole in the fixture ¹⁾ | d_f [mm] | 14 | 18 | 22 | 26 |
| Maximum torque moment | T_{max} [Nm] | 40 | 80 | 150 | 200 |
| Minimum thickness of concrete member | h_{min} [mm] | $h_{\text{nom}} + 2 \cdot d_0$ | | | |
| Minimum spacing | s_{min} [mm] | 65 | 80 | 100 | 130 |
| Minimum edge distance | c_{min} [mm] | 45 | 50 | 55 | 60 |


¹⁾ for larger clearance hole see "TR 029 section 1.1"

Table B5: Installation parameters of Hilti tension anchor HZA

| Hilti tension anchor HZA... | | M12 | M16 | M20 | M24 | M27 |
|--|-----------------------------|--------------------------------|------------|------------|------------|------------|
| Rebar diameter | ϕ [mm] | 12 | 16 | 20 | 25 | 28 |
| Nominal embedment depth and drill hole depth | $h_{\text{nom}} = h_0$ [mm] | 90 to 240 | 100 to 320 | 110 to 400 | 120 to 500 | 140 to 560 |
| Effective embedment depth ($h_{\text{ef}} = h_{\text{nom}} - l_e$) | h_{ef} [mm] | $h_{\text{nom}} - 20$ | | | | |
| Length of smooth shaft | l_e [mm] | 20 | | | | |
| Nominal diameter of drill bit | d_0 [mm] | 16 | 20 | 25 | 32 | 35 |
| Maximum diameter of clearance hole in the fixture ¹⁾ | d_f [mm] | 14 | 18 | 22 | 26 | 30 |
| Maximum torque moment | T_{max} [Nm] | 40 | 80 | 150 | 200 | 270 |
| Minimum thickness of concrete member | h_{min} [mm] | $h_{\text{nom}} + 2 \cdot d_0$ | | | | |
| Minimum spacing | s_{min} [mm] | 65 | 80 | 100 | 130 | 140 |
| Minimum edge distance | c_{min} [mm] | 45 | 50 | 55 | 60 | 75 |

¹⁾ for larger clearance hole see "TR 029 section 1.1"

Marking:
embossing "HZA-R" M .. / t_{fix}



Injection System Hilti HIT-HY 200-A

Intended Use
Installation parameters of Hilti tension anchor HZA-(R)

Annex B5

Table B6: Installation parameters of reinforcing bar

| Reinforcing bar (rebar) | $\phi 8$ | $\phi 10$ | $\phi 12$ | $\phi 14$ | $\phi 16$ | $\phi 20$ | $\phi 25$ | $\phi 26$ | $\phi 28$ | $\phi 30$ | $\phi 32$ |
|--|--------------------------------|-----------------------|------------------------|------------------|-----------|-----------|------------|------------|------------|------------|------------|
| Diameter ϕ [mm] | 8 | 10 | 12 | 14 | 16 | 20 | 25 | 26 | 28 | 30 | 32 |
| Effective embedment depth and drill hole depth $h_{ef} = h_0$ [mm] | 60 to 160 | 60 to 200 | 70 to 240 | 75 to 280 | 80 to 320 | 90 to 400 | 100 to 500 | 104 to 520 | 112 to 560 | 120 to 600 | 128 to 640 |
| Nominal diameter of drill bit d_0 [mm] | 10 / 12 ¹⁾ | 12 / 14 ¹⁾ | 14 ¹⁾ | 16 ¹⁾ | 18 | 20 | 25 | 32 | 32 | 35 | 37 |
| Minimum thickness of concrete member h_{min} [mm] | $h_{ef} + 30$ ≥ 100 mm | | $h_{ef} + 2 \cdot d_0$ | | | | | | | | |
| Minimum spacing s_{min} [mm] | 40 | 50 | 60 | 70 | 80 | 100 | 125 | 130 | 140 | 150 | 160 |
| Minimum edge distance c_{min} [mm] | 40 | 45 | 45 | 50 | 50 | 65 | 70 | 75 | 75 | 80 | 80 |

¹⁾ Each of the two given values can be used.

Reinforcing bar



For rebar bolt

- Minimum value of related rip area $f_{R,min}$ according to EN 1992-1-1:2004+AC:2010
- Rib height of the bar h_{rib} shall be in the range $0,05 \cdot \phi \leq h_{rib} \leq 0,07 \cdot \phi$
(ϕ : Nominal diameter of the bar; h_{rib} : Rip height of the bar)

Injection System Hilti HIT-HY 200-A

Intended Use
Installation parameters of reinforcing bar (rebar)

Annex B6

Table B7: Maximum working time and minimum curing time

| Temperature in the base material T | Maximum working time t_{work} | Minimum curing time t_{cure} |
|------------------------------------|---------------------------------|--------------------------------|
| -10 °C to -5 °C | 1,5 hours | 7 hours |
| > -5 °C to 0 °C | 50 min | 4 hours |
| > 0 °C to 5 °C | 25 min | 2 hours |
| > 5 °C to 10 °C | 15 min | 75 min |
| > 10 °C to 20 °C | 7 min | 45 min |
| > 20 °C to 30 °C | 4 min | 30 min |
| > 30 °C to 40 °C | 3 min | 30 min |

Injection System Hilti HIT-HY 200-A

Intended Use

Maximum working time and minimum curing time

Annex B7

Table B8: Parameters of cleaning and setting tools

| Elements | | | | Drill and clean | | | Installation |
|---------------------|----------|-----------|---------|-------------------------------------|---------------------|-------------|--------------|
| HIT-V-... AM 8.8 | HIS-(R)N | Rebar | HZA(-R) | Hammer drilling hollow drill bit | | Brush | Piston plug |
| HIT-V-... AM 8.8 | HIS-(R)N | Rebar | HZA(-R) | hollow drill bit | Brush | Piston plug | |
| size | size | size | size | d ₀ [mm] | d ₀ [mm] | HIT-RB | HIT-SZ |
| M8 | - | φ8 | - | 10 | - | 10 | - |
| M10 | - | φ8 / φ10 | - | 12 | 12 | 12 | 12 |
| M12 | M8 | φ10 / φ12 | - | 14 | 14 | 14 | 14 |
| - | - | φ12 | M12 | 16 | 16 | 16 | 16 |
| M16 | M10 | φ14 | - | 18 | 18 | 18 | 18 |
| - | - | φ16 | M16 | 20 | 20 | 20 | 20 |
| M20 | M12 | - | - | 22 | 22 | 22 | 22 |
| - | - | φ20 | M20 | 25 | 25 | 25 | 25 |
| M24 | M16 | - | - | 28 | 28 | 28 | 28 |
| M27 | - | - | - | 30 | - | 30 | 30 |
| - | M20 | φ25 / φ26 | M24 | 32 | 32 | 32 | 32 |
| M30 | - | φ28 | M27 | 35 | 35 | 35 | 35 |
| - | - | φ30 | - | 37 | - | 37 | 37 |
| - | - | φ32 | - | 40 | - | 40 | 40 |

Cleaning alternatives

Manual Cleaning (MC):

Hilti hand pump for blowing out drill holes with diameters d₀ ≤ 20 mm and drill hole depths h₀ ≤ 10·d



Compressed air cleaning (CAC):

Air nozzle with an orifice opening of minimum 3,5 mm in diameter.



Automatic Cleaning (AC):

Cleaning is performed during drilling with Hilti TE-CD and TE-YD drilling system including vacuum cleaner.



Injection System Hilti HIT-HY 200-A

Intended Use


Cleaning and setting tools

Annex B8

Installation instruction


Hole drilling

a) Hammer drilling



Drill hole to the required embedment depth with a hammer drill set in rotation-hammer mode using an appropriately sized carbide drill bit.

b) Hammer drilling with Hilti hollow drill bit




Drill hole to the required embedment depth with an appropriately sized Hilti TE-CD or TE-YD hollow drill bit with Hilti vacuum attachment. This drilling system removes the dust and cleans the bore hole during drilling when used in accordance with the user's manual. After drilling is completed, proceed to the "injection preparation" step in the installation instruction.

Drill hole cleaning

Just before setting an anchor, the drill hole must be free of dust and debris.
Inadequate hole cleaning = poor load values.


Manual Cleaning (MC) non-cracked concrete only

for drill hole diameters $d_0 \leq 20$ mm and drill hole depths $h_0 \leq 10 \cdot d$




The Hilti hand pump may be used for blowing out drill holes up to diameters $d_0 \leq 20$ mm and embedment depths up to $h_{ef} \leq 10 \cdot d$.

Blow out at least 4 times from the back of the drill hole until return air stream is free of noticeable dust



Brush 4 times with the specified brush (see Table B8) by inserting the steel brush Hilti HIT-RB to the back of the hole (if needed with extension) in a twisting motion and removing it.

The brush must produce natural resistance as it enters the drill hole (brush $\varnothing \geq$ drill hole \varnothing) - if not the brush is too small and must be replaced with the proper brush diameter.




Blow out again with Hilti hand pump at least 4 times until return air stream is free of noticeable dust.

Injection System Hilti HIT-HY 200-A

Intended Use
Installation instructions


Annex B9

Compressed air cleaning (CAC) for all drill hole diameters d_0 and all drill hole depths h_0




Blow 2 times from the back of the hole (if needed with nozzle extension) over the hole length with oil-free compressed air (min. 6 bar at 6 m³/h) until return air stream is free of noticeable dust.

For drill hole diameters ≥ 32 mm the compressor has to supply a minimum air flow of 140 m³/h.




Brush 2 times with the specified brush (see Table B8) by inserting the steel brush Hilti HIT-RB to the back of the hole (if needed with extension) in a twisting motion and removing it.

The brush must produce natural resistance as it enters the drill hole (brush $\varnothing \geq$ drill hole \varnothing) - if not the brush is too small and must be replaced with the proper brush diameter.



Blow again with compressed air 2 times until return air stream is free of noticeable dust.

Injection preparation




Tightly attach new Hilti mixing nozzle HIT-RE-M to foil pack manifold (snug fit). Do not modify the mixing nozzle.

Observe the instruction for use of the dispenser.

Check foil pack holder for proper function. Do not use damaged foil packs / holders.

Insert foil pack into foil pack holder and put holder into the dispenser.





Discard initial adhesive. The foil pack opens automatically as dispensing is initiated.

Depending on the size of the foil pack an initial amount of adhesive has to be discarded. Discarded quantities are

| | |
|-----------|-----------------------------------|
| 2 strokes | for 330 ml foil pack, |
| 3 strokes | for 500 ml foil pack, |
| 4 strokes | for 500 ml foil pack ≤ 5 °C. |

Installation with Hilti Filling set




Injection System Hilti HIT-HY 200-A


Intended Use
Installation instructions

Annex B10


Inject adhesive from the back of the drill hole without forming air voids.



Inject the adhesive starting at the back of the hole, slowly withdrawing the mixer with each trigger pull.
Fill holes approximately 2/3 full, to ensure that the annular gap between the anchor and the concrete is completely filled with adhesive along the embedment length.




After injection is completed, depressurize the dispenser by pressing the release trigger. This will prevent further adhesive discharge from the mixer.




Overhead installation and/or installation with embedment depth $h_{ef} > 250\text{mm}$.
For overhead installation the injection is only possible with the aid of extensions and piston plugs. Assemble HIT-RE-M mixer, extension(s) and appropriately sized piston plug (see Table B8). Insert piston plug to back of the hole and inject adhesive. During injection the piston plug will be naturally extruded out of the drill hole by the adhesive pressure


Setting the element



Before use, verify that the element is dry and free of oil and other contaminants.
Mark and set element to the required embedment depth until working time t_{work} has elapsed. The working time t_{work} is given in Table B7.



For overhead installation use piston plugs and fix embedded parts with e.g. wedges.



Loading the anchor: After required curing time t_{cure} (see Table B7) the anchor can be loaded.
The applied installation torque shall not exceed the values T_{max} given in Table B2 to Table B5.

Injection System Hilti HIT-HY 200-A


Intended Use
Installation instructions

Annex B11

Table C1: Characteristic values of resistance for threaded rod, HIT-V-... and AM 8.8 under tension loads in concrete

| HIT-HY 200-A with threaded rod, HIT-V-..., AM 8.8 | M8 | M10 | M12 | M16 | M20 | M24 | M27 | M30 |
|--|--------------------------|----------------------|-----|-----|-----|-----|-----|---------------------|
| Installation safety factor γ_2 [-] | | | | | | | | 1,0 |
| Steel failure | | | | | | | | |
| Characteristic steel resistance $N_{Rk,s}$ [kN] | | | | | | | | $A_s \cdot f_{uk}$ |
| Partial safety factor $\gamma_{Ms,N}^{1)}$ [-] | | | | | | | | 1,5 |
| Combined pullout and concrete cone failure | | | | | | | | |
| Characteristic bond resistance in non-cracked concrete C20/25 | | | | | | | | |
| Temperature range I: 40 °C/24 °C $\tau_{Rk,ucr}$ [N/mm ²] | | | | | | | | 18 |
| Temperature range II: 80 °C/50 °C $\tau_{Rk,ucr}$ [N/mm ²] | | | | | | | | 15 |
| Temperature range III: 120 °C/72 °C $\tau_{Rk,ucr}$ [N/mm ²] | | | | | | | | 13 |
| Characteristic bond resistance in cracked concrete C20/25 | | | | | | | | |
| Temperature range I: 40 °C/24 °C $\tau_{Rk,cr}$ [N/mm ²] | 7,5 | | | | | | | 9,0 |
| Temperature range II: 80 °C/50 °C $\tau_{Rk,cr}$ [N/mm ²] | 6,0 | | | | | | | 7,5 |
| Temperature range III: 120 °C/72 °C $\tau_{Rk,cr}$ [N/mm ²] | 5,5 | | | | | | | 6,5 |
| | | | | | | | | |
| Increasing factors for τ_{Rk} in concrete ψ_c | | | | | | | | |
| C30/37 | | | | | | | | 1,04 |
| C40/45 | | | | | | | | 1,07 |
| C50/60 | | | | | | | | 1,1 |
| Splitting failure | | | | | | | | |
| Edge distance $c_{cr,sp}$ [mm] for | $h / h_{ef} \geq 2,0$ | $1,0 \cdot h_{ef}$ | | | | | | |
| | $2,0 > h / h_{ef} > 1,3$ | $4,6 h_{ef} - 1,8 h$ | | | | | | |
| | $h / h_{ef} \leq 1,3$ | $2,26 h_{ef}$ | | | | | | |
| Spacing $s_{cr,sp}$ [mm] | | | | | | | | $2 \cdot c_{cr,sp}$ |

¹⁾ In absence of national regulations.



Injection System Hilti HIT-HY 200-A

Performances

Characteristic values of resistance under tension loads in concrete
Design according to „EOTA Technical Report TR 029, Edition September 2010“

Annex C1

Table C2: Characteristic values of resistance for threaded rod, HIT-V-... and AM 8.8 under shear loads

| HIT-HY 200-A with threaded rod, HIT-V-..., AM 8.8 | M8 | M10 | M12 | M16 | M20 | M24 | M27 | M30 |
|--|----|-----|-----|-----|-----|-----|-----|-----|
| Steel failure without lever arm | | | | | | | | |
| Characteristic steel resistance $V_{Rk,s}$ [kN] | | | | | | | | |
| Characteristic steel resistance $V_{Rk,s}$ [kN] | | | | | | | | |
| Partial safety factor $\gamma_{Ms,V}^{1)}$ [-] | | | | | | | | |
| Steel failure with lever arm | | | | | | | | |
| Characteristic bending moment $M_{Rk,s}^0$ [Nm] | | | | | | | | |
| Concrete pry-out failure | | | | | | | | |
| Factor in equation (5.7) of Technical Report TR 029 for the design of bonded anchors k [-] | | | | | | | | |
| | | | | | | | | |
| Concrete edge failure | | | | | | | | |
| The value of h_{ef} for calculation in equations (5.8a) and (5.8b) of Technical Report TR 029 is limited by: | | | | | | | | |
| Outside diameter of anchor d_{nom} [mm] | 8 | 10 | 12 | 16 | 20 | 24 | 27 | 30 |

¹⁾ In absence of national regulations.

Injection System Hilti HIT-HY 200-A

Performances

Characteristic values of resistance under shear loads in concrete
Design according to „EOTA Technical Report TR 029, Edition September 2010“

Annex C2

Table C3: Characteristic values of resistance for internally threaded sleeve HIS-(R)N under tension loads in concrete

| Hilti HIT-HY 200-A with HIS-(R)N | | M8 | M10 | M12 | M16 | M20 |
|---|-----------------------|--------------------------|----------------------------------|---------------------|------|------|
| Installation safety factor | γ_2 | [-] | | 1,0 | | |
| Steel failure threaded rods | | | | | | |
| Characteristic resistance HIS-N with screw grade 8.8 | $N_{Rk,s}$ | [kN] | 25 | 46 | 67 | 125 |
| Partial safety factor | $\gamma_{Ms,N}^{(1)}$ | [-] | | 1,50 | | |
| Characteristic resistance HIS-RN with screw grade 70 | $N_{Rk,s}$ | [kN] | 26 | 41 | 59 | 110 |
| Partial safety factor | $\gamma_{Ms,N}^{(1)}$ | [-] | | 1,87 | | 2,4 |
| Combined pull-out and Concrete cone failure | | | | | | |
| Effective anchorage depth | h_{ef} | [mm] | 90 | 110 | 125 | 170 |
| Effective anchor diameter | d_1 | [mm] | 12,5 | 16,5 | 20,5 | 25,4 |
| Characteristic bond resistance in non-cracked concrete C20/25 | | | | | | |
| Temperature range I: 40 °C/24 °C | $\tau_{Rk,ucr}$ | [N/mm²] | | 13 | | |
| Temperature range II: 80 °C/50 °C | $\tau_{Rk,ucr}$ | [N/mm²] | | 11 | | |
| Temperature range III: 120 °C/72 °C | $\tau_{Rk,ucr}$ | [N/mm²] | | 9,5 | | |
| Characteristic bond resistance in cracked concrete C20/25 | | | | | | |
| Temperature range I: 40 °C/24 °C | $\tau_{Rk,cr}$ | [N/mm²] | | 7 | | |
| Temperature range II: 80 °C/50 °C | $\tau_{Rk,cr}$ | [N/mm²] | | 5,5 | | |
| Temperature range III: 120 °C/72 °C | $\tau_{Rk,cr}$ | [N/mm²] | | 5 | | |
| Increasing factor for τ_{Rk} in concrete | ψ_c | C30/37 | | 1,04 | | |
| | | C40/45 | | 1,07 | | |
| | | C50/60 | | 1,1 | | |
| Splitting failure relevant for non-cracked concrete | | | | | | |
| Edge distance $c_{cr,sp}$ [mm] for | | $h / h_{ef} \geq 2,0$ | $1,0 \cdot h_{ef}$ | | | |
| | | $2,0 > h / h_{ef} > 1,3$ | $4,6 \cdot h_{ef} - 1,8 \cdot h$ | | | |
| | | $h / h_{ef} \leq 1,3$ | $2,26 \cdot h_{ef}$ | | | |
| Spacing | $s_{cr,sp}$ | [mm] | | $2 \cdot c_{cr,sp}$ | | |

⁽¹⁾ In absence of national regulations.

Injection System Hilti HIT-HY 200-A

Performances

Characteristic values of resistance under tension loads in concrete
Design according to „EOTA Technical Report TR 029, Edition September 2010“

Annex C3

Table C4: Characteristic values of resistance for internally threaded sleeve HIS-(R)N under shear loads in concrete

| Hilti HIT-HY 200-A with HIS-(R)N | M8 | M10 | M12 | M16 | M20 |
|--|------|------|------|------|------|
| Steel failure without lever arm | | | | | |
| Characteristic resistance HIS-N with screw grade 8.8 $V_{Rk,s}$ [kN] | 13 | 23 | 34 | 63 | 58 |
| Partial safety factor $\gamma_{Ms,V}^{1)}$ [-] | | | 1,25 | | |
| Characteristic resistance HIS-RN with screw grade 70 $V_{Rk,s}$ [kN] | 13 | 20 | 30 | 55 | 83 |
| Partial safety factor $\gamma_{Ms,V}^{1)}$ [-] | | | 1,56 | | 2,0 |
| Steel failure with lever arm | | | | | |
| Characteristic resistance HIS-N with screw grade 8.8 $M_{Rk,s}^o$ [Nm] | 30 | 60 | 105 | 266 | 519 |
| Partial safety factor $\gamma_{Ms,V}^{1)}$ [-] | | | 1,25 | | |
| Characteristic resistance HIS-RN with screw grade 70 $M_{Rk,s}^o$ [Nm] | 26 | 52 | 92 | 233 | 454 |
| Partial safety factor $\gamma_{Ms,V}^{1)}$ [-] | | | 1,56 | | |
| Concrete pry-out failure | | | | | |
| Factor in equation (5.7) of Technical Report TR 029 for the design of bonded anchors k [-] | | | 2,0 | | |
| Concrete edge failure | | | | | |
| Outside diameter of anchor d_{nom} [mm] | 12,5 | 16,5 | 20,5 | 25,4 | 27,6 |

¹⁾ In absence of national regulations.

Injection System Hilti HIT-HY 200-A

Performances


Characteristic values of resistance under shear loads in concrete
Design according to „EOTA Technical Report TR 029, Edition September 2010“

Annex C4

Table C5: Characteristic values of resistance for Hilti tension anchor HZA / HZA-R under tension loads in concrete

| Hilti HIT-HY 200-A with HZA, HZA-R | M12 | M16 | M20 | M24 | M27 |
|---|--------------------------|-------|----------------------------------|-----------------|---------------------|
| Installation safety factor γ_2 [-] | | | | 1,0 | |
| Steel failure | | | | | |
| Characteristic resistance HZA $N_{Rk,s}$ [kN] | 46 | 86 | 135 | 194 | 253 |
| Characteristic resistance HZA-R $N_{Rk,s}$ [kN] | 62 | 111 | 173 | 248 | - |
| Partial safety factor $\gamma_{Ms}^{1)}$ [-] | | | 1,4 | | |
| Combined pull-out and concrete cone failure | | | | | |
| Diameter of rebar d [mm] | 12 | 16 | 20 | 25 | 28 |
| Characteristic bond resistance in non-cracked concrete C20/25 | | | | | |
| Temperature range I: 40 °C/24 °C $\tau_{Rk,ucr}$ [N/mm²] | | | | 12 | |
| Temperature range II: 80 °C/50 °C $\tau_{Rk,ucr}$ [N/mm²] | | | | 10 | |
| Temperature range III: 120 °C/72 °C $\tau_{Rk,ucr}$ [N/mm²] | | | | 8,5 | |
| Characteristic bond resistance in cracked concrete C20/25 | | | | | |
| Temperature range I: 40 °C/24 °C $\tau_{Rk,cr}$ [N/mm²] | | | | 7 | |
| Temperature range II: 80 °C/50 °C $\tau_{Rk,cr}$ [N/mm²] | | | | 5,5 | |
| Temperature range III: 120 °C/72 °C $\tau_{Rk,cr}$ [N/mm²] | | | | 5 | |
| | C30/37 | | | 1,04 | |
| Increasing factor for τ_{Rk} in concrete ψ_c | C40/45 | | | 1,07 | |
| | C50/60 | | | 1,1 | |
| Effective anchorage depth h_{ef} [mm] | | | | $h_{nom} - 20$ | |
| for calculation of $N_{Rk,p}^0$ acc. Eq. 5.2a (TR 029, 5.2.2.3 Combined pull-out and concrete cone failure) | HZA | HZA-R | | $h_{nom} - 100$ | - |
| Concrete cone failure | | | | | |
| Effective anchorage depth h_{ef} [mm] | HZA | HZA-R | | h_{nom} | |
| for calculation of $N_{Rk,c}^0$ acc. Eq. 5.3a (TR 029, 5.2.2.4 Concrete cone failure) | | | | | |
| Splitting failure relevant for non-cracked concrete | | | | | |
| Edge distance $c_{cr,sp}$ [mm] for | $h / h_{ef} \geq 2,0$ | | $1,0 \cdot h_{ef}$ | h / h_{ef} | |
| | $2,0 > h / h_{ef} > 1,3$ | | $4,6 \cdot h_{ef} - 1,8 \cdot h$ | 2,0 | |
| | $h / h_{ef} \leq 1,3$ | | $2,26 \cdot h_{ef}$ | 1,3 | |
| Spacing $s_{cr,sp}$ [mm] | | | | | $2 \cdot c_{cr,sp}$ |

¹⁾ In absence of national regulations.



Injection System Hilti HIT-HY 200-A

Performances

Characteristic values of resistance under tension loads in concrete
Design according to „EOTA Technical Report TR 029, Edition September 2010“

Annex C5

Table C6: Characteristic values of resistance for Hilti tension anchor HZA, HZA-R under shear loads in concrete

| Hilti HIT-HY 200-A with HZA, HZA-R | M12 | M16 | M20 | M24 | M27 |
|--|-----|-----|-------------------------------------|-----|-----|
| Steel failure without lever arm | | | | | |
| Characteristic resistance HZA $V_{Rk,s}$ [kN] | 23 | 43 | 67 | 97 | 126 |
| Characteristic resistance HZA-R $V_{Rk,s}$ [kN] | 31 | 55 | 86 | 124 | - |
| Partial safety factor $\gamma_{Ms}^{1)}$ [-] | | | 1,5 | | |
| Steel failure with lever arm | | | | | |
| Characteristic resistance HZA $M_{Rk,s}^0$ [Nm] | 72 | 183 | 357 | 617 | 915 |
| Characteristic resistance HZA-R $M_{Rk,s}^0$ [Nm] | 97 | 234 | 457 | 790 | - |
| Partial safety factor $\gamma_{Ms}^{1)}$ [-] | | | 1,5 | | |
| Concrete pry-out failure | | | | | |
| Factor in equation (5.7) of Technical Report TR 029 for the design of bonded anchors k [-] | | | 2,0 | | |
| Concrete edge failure | | | | | |
| The value of h_{ef} for calculation in equations (5.8a) and (5.8b) of Technical Report TR 029 is limited by: | | | min ($h_{nom}; 12 \cdot d_{nom}$) | | |
| Outside diameter of anchor d_{nom} [mm] | 12 | 16 | 20 | 24 | 27 |

¹⁾ In absence of national regulations.

Injection System Hilti HIT-HY 200-A


Performances

Characteristic values of resistance under shear loads in concrete
Design according to „EOTA Technical Report TR 029, Edition September 2010“

Annex C6

Table C7: Characteristic values of resistance for rebar under tension loads in concrete

| HIT-HY 200-A with rebar | φ 8 | φ 10 | φ 12 | φ 14 | φ 16 | φ 20 | φ 25 | φ 26 | φ 28 | φ 30 | φ 32 |
|---|--------------------------|------|----------------------------------|------|------|------|------|---------------|------|------|------|
| Installation safety factor γ_2 [-] | | | | | | | | | | 1,0 | |
| Steel failure | | | | | | | | | | | |
| Characteristic resistance for rebar B500B acc. to DIN 488:2009-08 ²⁾ $N_{Rk,s}$ [kN] | 28 | 43 | 62 | 85 | 111 | 173 | 270 | 292 | 339 | 388 | 442 |
| Partial safety factor ³⁾ $\gamma_{Ms,N}^{1)}$ [-] | | | | | | | | | | 1,4 | |
| Combined pull-out and Concrete cone failure | | | | | | | | | | | |
| Diameter of rebar d [mm] | 8 | 10 | 12 | 14 | 16 | 20 | 25 | 26 | 28 | 30 | 32 |
| Characteristic bond resistance in non-cracked concrete C20/25 | | | | | | | | | | | |
| Temperature range I: 40°C/24°C $\tau_{Rk,ucr}$ [N/mm²] | | | | | | | | | | 12 | |
| Temperature range II: 80°C/50°C $\tau_{Rk,ucr}$ [N/mm²] | | | | | | | | | | 10 | |
| Temperature range III: 120°C/72°C $\tau_{Rk,ucr}$ [N/mm²] | | | | | | | | | | 8,5 | |
| Characteristic bond resistance in cracked concrete C20/25 | | | | | | | | | | | |
| Temperature range I: 40°C/24°C $\tau_{Rk,cr}$ [N/mm²] | - | 5 | | | | | | | | 7 | |
| Temperature range II: 80°C/50°C $\tau_{Rk,cr}$ [N/mm²] | - | 4 | | | | | | | | 5,5 | |
| Temperature range III: 120°C/72°C $\tau_{Rk,cr}$ [N/mm²] | - | 3,5 | | | | | | | | 5 | |
| Increasing factor for τ_{Rk} in concrete ψ_c | C30/37 | | | | | | 1,04 | | | | |
| | C40/45 | | | | | | 1,07 | | | | |
| | C50/60 | | | | | | 1,1 | | | | |
| Splitting failure relevant for non-cracked concrete | | | | | | | | | | | |
| Edge distance $c_{cr,sp}$ [mm] for | $h / h_{ef} \geq 2,0$ | | 1,0 · h_{ef} | | | | | | | | |
| | $2,0 > h / h_{ef} > 1,3$ | | $4,6 \cdot h_{ef} - 1,8 \cdot h$ | | | | | | | | |
| | $h / h_{ef} \leq 1,3$ | | $2,26 \cdot h_{ef}$ | | | | | | | | |
| Spacing $s_{cr,sp}$ [mm] | | | | | | | | 2 $c_{cr,sp}$ | | | |



¹⁾ In absence of national regulations

²⁾ The characteristic tension resistance $N_{Rk,s}$ for rebars that do not fulfill the requirements acc. to DIN 488 shall be calculated acc. Technical Report TR 029, Equation (5.1).

³⁾ The partial safety factor $\gamma_{Ms,N}$ that do not fulfill the requirements acc. to DIN 488 shall be calculated acc. Technical Report TR 029, Equation (3.3a).

Injection System Hilti HIT-HY 200-A

Performances

Characteristic values of resistance under tension loads in concrete
Design according to „EOTA Technical Report TR 029, Edition September 2010“

Annex C7

Table C8: Characteristic values of resistance for rebar under shear loads in concrete

| HIT-HY 200-A with rebar | $\phi 8$ | $\phi 10$ | $\phi 12$ | $\phi 14$ | $\phi 16$ | $\phi 20$ | $\phi 25$ | $\phi 26$ | $\phi 28$ | $\phi 30$ | $\phi 32$ | | |
|--|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|---------------------------------------|----|----|
| Steel failure without lever arm | | | | | | | | | | | | | |
| Characteristic resistance for rebar B500B acc. to DIN 488:2009-08 ²⁾ $V_{Rk,s}$ [kN] | | | | | | | | | | | | | |
| 14 | 22 | 31 | 42 | 55 | 86 | 135 | 146 | 169 | 194 | 221 | | | |
| Partial safety factor ⁴⁾ $\gamma_{Ms,V}^{1)}$ [-] | | | | | | | | | | | 1,5 | | |
| Steel failure with lever arm | | | | | | | | | | | | | |
| Characteristic resistance for rebar B500B acc. to DIN 488:2009-08 ³⁾ $M_{Rk,s}^0$ [Nm] | | | | | | | | | | | | | |
| 33 | 65 | 112 | 178 | 265 | 518 | 1012 | 1139 | 1422 | 1749 | 2123 | | | |
| Concrete pry-out failure | | | | | | | | | | | | | |
| Factor in equation (5.7) of Technical Report TR 029 for the design of bonded anchors | k | | | | | | | | | | 2,0 | | |
| Concrete edge failure | | | | | | | | | | | | | |
| The value of h_{ef} for calculation in equations (5.8a) and (5.8b) of Technical Report TR 029 is limited by: | | | | | | | | | | | min (h_{ef} ; $12 \cdot d_{nom}$) | | |
| Outside diameter of anchor | d_{nom} | [mm] | 8 | 10 | 12 | 14 | 16 | 20 | 25 | 26 | 28 | 30 | 32 |

¹⁾ In absence of national regulations.

²⁾ The characteristic shear resistance $V_{Rk,s}$ for rebars that do not fulfill the requirements acc. DIN 488 shall be calculated acc. Technical Report TR 029, Equation (5.5).

³⁾ The characteristic bending resistance $M_{Rk,s}^0$ for rebars that do not fulfil the requirements acc. DIN 488 shall be calculated acc. Technical Report TR 029, Equation (5.6b).

⁴⁾ The partial safety factor $\gamma_{Ms,V}$ for rebar that do not fulfill the requirements acc. to DIN 488 shall be calculated acc. Technical Report 029, Equation (3.3b) or (3.3c).

Injection System Hilti HIT-HY 200-A

Performances

Characteristic values of resistance under shear loads in concrete
Design according to „EOTA Technical Report TR 029, Edition September 2010“

Annex C8

Table C9: Displacements under tension load

| Hilti HIT-HY 200-A with threaded rod, HIT-V-..., AM 8.8 | | M8 | M10 | M12 | M16 | M20 | M24 | M27 | M30 |
|---|---------------------------------|------|------|------|------|------|------|------|------|
| Non-cracked concrete temperature range I : 40°C / 24°C | | | | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm²)] | 0,02 | 0,03 | 0,03 | 0,04 | 0,06 | 0,07 | 0,07 | 0,08 |
| | $\delta_{N\infty}$ [mm/(N/mm²)] | 0,04 | 0,05 | 0,06 | 0,08 | 0,10 | 0,13 | 0,14 | 0,16 |
| Non-cracked concrete temperature range II : 80°C / 50°C | | | | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm²)] | 0,03 | 0,04 | 0,05 | 0,06 | 0,08 | 0,09 | 0,10 | 0,12 |
| | $\delta_{N\infty}$ [mm/(N/mm²)] | 0,04 | 0,05 | 0,06 | 0,09 | 0,11 | 0,13 | 0,15 | 0,16 |
| Non-cracked concrete temperature range III : 120°C / 72°C | | | | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm²)] | 0,04 | 0,05 | 0,06 | 0,08 | 0,10 | 0,12 | 0,13 | 0,16 |
| | $\delta_{N\infty}$ [mm/(N/mm²)] | 0,04 | 0,05 | 0,07 | 0,09 | 0,11 | 0,13 | 0,15 | 0,17 |
| Cracked concrete temperature range I : 40°C / 24°C | | | | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm²)] | 0,07 | | | | | | | |
| | $\delta_{N\infty}$ [mm/(N/mm²)] | 0,16 | | | | | | | |
| Cracked concrete temperature range II : 80°C / 50°C | | | | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm²)] | 0,10 | | | | | | | |
| | $\delta_{N\infty}$ [mm/(N/mm²)] | 0,22 | | | | | | | |
| Cracked concrete temperature range III : 120°C / 72°C | | | | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm²)] | 0,13 | | | | | | | |
| | $\delta_{N\infty}$ [mm/(N/mm²)] | 0,29 | | | | | | | |

Table C10: Displacements under shear load

| Hilti HIT-HY 200-A with threaded rod, HIT-V-... | | M8 | M10 | M12 | M16 | M20 | M24 | M27 | M30 |
|---|----------------------------|------|------|------|------|------|------|------|------|
| Displacement | δ_{V0} [mm/kN] | 0,06 | 0,06 | 0,05 | 0,04 | 0,04 | 0,03 | 0,03 | 0,03 |
| | $\delta_{V\infty}$ [mm/kN] | 0,09 | 0,08 | 0,08 | 0,06 | 0,06 | 0,05 | 0,05 | 0,05 |

Table C11: Displacements under tension load

| Hilti HIT-HY 200-A with HIS-(R)N | | M8 | M10 | M12 | M16 | M20 |
|---|--|------|------|------|------|------|
| Non-cracked concrete temperature range I : 40°C / 24°C | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm ²)] | 0,03 | 0,05 | 0,06 | 0,07 | 0,08 |
| | $\delta_{N\infty}$ [mm/(N/mm ²)] | 0,06 | 0,09 | 0,11 | 0,13 | 0,14 |
| Non-cracked concrete temperature range II : 80°C / 50°C | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm ²)] | 0,05 | 0,06 | 0,08 | 0,10 | 0,11 |
| | $\delta_{N\infty}$ [mm/(N/mm ²)] | 0,07 | 0,09 | 0,11 | 0,13 | 0,15 |
| Non-cracked concrete temperature range III : 120°C / 72°C | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm ²)] | 0,06 | 0,08 | 0,10 | 0,13 | 0,14 |
| | $\delta_{N\infty}$ [mm/(N/mm ²)] | 0,07 | 0,09 | 0,11 | 0,14 | 0,15 |
| Cracked concrete temperature range I : 40°C / 24°C | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm ²)] | | | 0,11 | | |
| | $\delta_{N\infty}$ [mm/(N/mm ²)] | | | 0,16 | | |
| Cracked concrete temperature range II : 80°C / 50°C | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm ²)] | | | 0,15 | | |
| | $\delta_{N\infty}$ [mm/(N/mm ²)] | | | 0,22 | | |
| Cracked concrete temperature range III : 120°C / 72°C | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm ²)] | | | 0,20 | | |
| | $\delta_{N\infty}$ [mm/(N/mm ²)] | | | 0,29 | | |

Table C12: Displacements under shear load

| Hilti HIT-HY 200-A with HIS-(R)N | | M8 | M10 | M12 | M16 | M20 |
|----------------------------------|----------------------------|------|------|------|------|------|
| Displacement | δ_{V0} [mm/kN] | 0,06 | 0,06 | 0,05 | 0,04 | 0,04 |
| | $\delta_{V\infty}$ [mm/kN] | 0,09 | 0,08 | 0,08 | 0,06 | 0,06 |

Injection System Hilti HIT-HY 200-A

Performances

Displacements with HIS-(R)N

Annex C10

Table C13: Displacements under tension load

| Hilti HIT-HY 200-A with HZA, HZA-R | | M12 | M16 | M20 | M24 | M27 |
|---|--|------|------|------|------|------|
| Non-cracked concrete temperature range I : 40°C / 24°C | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm ²)] | 0,03 | 0,04 | 0,06 | 0,07 | 0,08 |
| | $\delta_{N\infty}$ [mm/(N/mm ²)] | 0,06 | 0,08 | 0,13 | 0,13 | 0,15 |
| Non-cracked concrete temperature range II : 80°C / 50°C | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm ²)] | 0,05 | 0,06 | 0,08 | 0,10 | 0,11 |
| | $\delta_{N\infty}$ [mm/(N/mm ²)] | 0,06 | 0,09 | 0,14 | 0,14 | 0,15 |
| Non-cracked concrete temperature range III : 120°C / 72°C | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm ²)] | 0,06 | 0,08 | 0,10 | 0,12 | 0,14 |
| | $\delta_{N\infty}$ [mm/(N/mm ²)] | 0,07 | 0,09 | 0,14 | 0,14 | 0,16 |
| Cracked concrete temperature range I : 40°C / 24°C | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm ²)] | | | | 0,11 | |
| | $\delta_{N\infty}$ [mm/(N/mm ²)] | | | | 0,16 | |
| Cracked concrete temperature range II : 80°C / 50°C | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm ²)] | | | | 0,15 | |
| | $\delta_{N\infty}$ [mm/(N/mm ²)] | | | | 0,22 | |
| Cracked concrete temperature range III : 120°C / 72°C | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm ²)] | | | | 0,20 | |
| | $\delta_{N\infty}$ [mm/(N/mm ²)] | | | | 0,29 | |

Table C14: Displacements under shear load

| Hilti HIT-HY 200-A with HZA, HZA-R | | M12 | M16 | M20 | M24 | M27 |
|------------------------------------|----------------------------|------|------|------|------|------|
| Displacement | δ_{V0} [mm/kN] | 0,05 | 0,04 | 0,04 | 0,03 | 0,03 |
| | $\delta_{V\infty}$ [mm/kN] | 0,08 | 0,06 | 0,06 | 0,05 | 0,05 |

Injection System Hilti HIT-HY 200-A

Performances
Displacements with HZA, HZA-R

Annex C11

Table C15: Displacements under tension load

| Hilti HIT-HY 200-A with rebar | φ 8 | φ 10 | φ 12 | φ 14 | φ 16 | φ 20 | φ 25 | φ 26 | φ 28 | φ 30 | φ 32 |
|---|---------------------------------|------|------|------|------|------|------|------|------|------|------|
| Non-cracked concrete temperature range I : 40°C / 24°C | | | | | | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm²)] | 0,02 | 0,03 | 0,03 | 0,04 | 0,04 | 0,06 | 0,07 | 0,08 | 0,08 | 0,09 |
| | $\delta_{N\infty}$ [mm/(N/mm²)] | 0,04 | 0,05 | 0,06 | 0,07 | 0,08 | 0,10 | 0,13 | 0,14 | 0,15 | 0,17 |
| Non-cracked concrete temperature range II : 80°C / 50°C | | | | | | | | | | | |
| | δ_{N0} [mm/(N/mm²)] | 0,03 | 0,04 | 0,05 | 0,05 | 0,06 | 0,08 | 0,10 | 0,11 | 0,11 | 0,12 |
| | $\delta_{N\infty}$ [mm/(N/mm²)] | 0,04 | 0,05 | 0,06 | 0,07 | 0,09 | 0,11 | 0,14 | 0,15 | 0,15 | 0,17 |
| Non-cracked concrete temperature range III : 120°C / 72°C | | | | | | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm²)] | 0,04 | 0,05 | 0,06 | 0,07 | 0,08 | 0,10 | 0,12 | 0,13 | 0,14 | 0,15 |
| | $\delta_{N\infty}$ [mm/(N/mm²)] | 0,04 | 0,05 | 0,07 | 0,08 | 0,09 | 0,11 | 0,14 | 0,15 | 0,16 | 0,18 |
| Cracked concrete temperature range I : 40°C / 24°C | | | | | | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm²)] | 0,11 | | | | | | | | | |
| | $\delta_{N\infty}$ [mm/(N/mm²)] | 0,16 | | | | | | | | | |
| Cracked concrete temperature range II : 80°C / 50°C | | | | | | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm²)] | 0,15 | | | | | | | | | |
| | $\delta_{N\infty}$ [mm/(N/mm²)] | 0,22 | | | | | | | | | |
| Cracked concrete temperature range III : 120°C / 72°C | | | | | | | | | | | |
| Displacement | δ_{N0} [mm/(N/mm²)] | 0,20 | | | | | | | | | |
| | $\delta_{N\infty}$ [mm/(N/mm²)] | 0,29 | | | | | | | | | |

Table C16: Displacements under shear load

| Hilti HIT-HY 200-A with rebar | φ 8 | φ 10 | φ 12 | φ 14 | φ 16 | φ 20 | φ 25 | φ 26 | φ 28 | φ 30 | φ 32 |
|-------------------------------|----------------------------|------|------|------|------|------|------|------|------|------|------|
| Displacement | δ_{V0} [mm/kN] | 0,06 | 0,05 | 0,05 | 0,04 | 0,04 | 0,04 | 0,03 | 0,03 | 0,03 | 0,03 |
| | $\delta_{V\infty}$ [mm/kN] | 0,09 | 0,08 | 0,07 | 0,06 | 0,06 | 0,05 | 0,05 | 0,05 | 0,04 | 0,04 |

Injection System Hilti HIT-HY 200-A

Performances
Displacements with rebar

Annex C12

Seismic design shall be carried out according to the TR 045 „Design of Metal Anchors Under Seismic Action“

Table C17: Characteristic values of resistance for threaded rod, HIT-V-... -..., AM 8.8 under tension loads for seismic performance category C1

| HIT-HY 200-A with threaded rod, HIT-V-..., AM 8.8 | M8 | M10 | M12 | M16 | M20 | M24 | M27 | M30 |
|---|----|-----|-----|-----|-----|-----|-----|-----|
| Steel failure | | | | | | | | |
| HIT-V-5.8(F), threaded rod 5.8 $N_{Rk,s,seis}$ [kN] | - | 29 | 42 | 79 | 123 | 177 | 230 | 281 |
| HIT-V-8.8(F), threaded rod 8.8 $N_{Rk,s,seis}$ [kN] | - | 46 | 67 | 126 | 196 | 282 | 367 | 449 |
| HIT-V-R, threaded rod A4-70 $N_{Rk,s,seis}$ [kN] | - | 41 | 59 | 110 | 172 | 247 | 230 | 281 |
| HIT-V-HCR, threaded rod HCR-80 $N_{Rk,s,seis}$ [kN] | - | 46 | 67 | 126 | 196 | 247 | 321 | 393 |
| Combined pullout and concrete cone failure | | | | | | | | |
| Characteristic bond resistance in cracked concrete C20/25 | | | | | | | | |
| Temperature range I: 40 °C/24 °C $\tau_{Rk,seis}$ [N/mm ²] | - | 5,2 | | | | 7,0 | | |
| Temperature range II: 80 °C/50 °C $\tau_{Rk,seis}$ [N/mm ²] | - | 3,9 | | | | 5,7 | | |
| Temperature range III: 120 °C/72 °C $\tau_{Rk,seis}$ [N/mm ²] | - | 3,5 | | | | 4,8 | | |

Table C18: Characteristic values of resistance for threaded rod, HIT-V-... and AM 8.8 under shear loads for seismic performance category C1

| HIT-HY 200-A with threaded rod, HIT-V-..., AM 8.8 | M8 | M10 | M12 | M16 | M20 | M24 | M27 | M30 |
|---|----|-----|-----|-----|-----|-----|-----|-----|
| Steel failure without lever arm | | | | | | | | |
| HIT-V 5.8(F), threaded rod 5.8 $V_{Rk,s,seis}$ [kN] | - | 11 | 15 | 27 | 43 | 62 | 81 | 98 |
| HIT-V 8.8(F), threaded rod 8.8 $V_{Rk,s,seis}$ [kN] | - | 16 | 24 | 44 | 69 | 99 | 129 | 157 |
| HIT-V R, threaded rod A4-70 $V_{Rk,s,seis}$ [kN] | - | 14 | 21 | 39 | 60 | 87 | 81 | 98 |
| HIT-V HCR, threaded rod HCR-80 $V_{Rk,s,seis}$ [kN] | - | 16 | 24 | 44 | 69 | 87 | 113 | 137 |

Table C19: Displacements under tension load for seismic performance category C1

| HIT-HY 200-A with threaded rod, HIT-V-..., AM 8.8 | M8 | M10 | M12 | M16 | M20 | M24 | M27 | M30 |
|---|----|-----|-----|-----|-----|-----|-----|-----|
| Displacement ¹⁾ $\delta_{N,seis}$ [mm] | - | 0,8 | 0,8 | 0,8 | 0,8 | 0,8 | 0,8 | 0,8 |

¹⁾ Maximum displacement during cycling (seismic event).

Table C20: Displacements under shear load for seismic performance category C1

| HIT-HY 200-A with threaded rod, HIT-V-..., AM 8.8 | M8 | M10 | M12 | M16 | M20 | M24 | M27 | M30 |
|---|----|-----|-----|-----|-----|-----|-----|-----|
| Displacement ¹⁾ $\delta_{V,seis}$ [mm] | - | 3,5 | 3,8 | 4,4 | 5,0 | 5,6 | 6,1 | 6,5 |

¹⁾ Maximum displacement during cycling (seismic event).

Injection System Hilti HIT-HY 200-A

Performances

Characteristic values for seismic performance category C1 and displacements
Design according to „EOTA Technical Report TR045, Edition February 2013“

Annex C13

Table C21: Characteristic values of resistance for Hilti tension anchor HZA, HZA-R under tension loads for seismic performance category C1

| HIT-HY 200-A with Hilti tension anchor HZA, HZA-R | M12 | M16 | M20 | M24 | M27 |
|--|-----|-----|-----|-----|-----|
| Steel failure | | | | | |
| Characteristic resistance HZA $N_{Rk,s,seis}$ [kN] | 46 | 86 | 135 | 194 | 253 |
| Characteristic resistance HZA-R $N_{Rk,s,seis}$ [kN] | 62 | 111 | 173 | 248 | - |
| Partial safety factor $\gamma_{Ms,N,seis}^{1)}$ [-] | | | 1,4 | | |
| Combined pull-out and concrete cone failure¹⁾ | | | | | |
| Diameter of rebar d [mm] | 12 | 16 | 20 | 25 | 28 |
| Characteristic bond resistance in cracked concrete C20/25 | | | | | |
| Temperature range I: 40°C/24°C $\tau_{Rk,cr}$ [N/mm ²] | | | 6,1 | | |
| Temperature range II: 80°C/50°C $\tau_{Rk,cr}$ [N/mm ²] | | | 4,8 | | |
| Temperature range III: 120°C/72°C $\tau_{Rk,cr}$ [N/mm ²] | | | 4,4 | | |

¹⁾ In absence of national regulations.

Table C22: Characteristic values of resistance for Hilti tension anchor HZA, HZA-R under shear loads for seismic performance category C1

| HIT-HY 200-A with Hilti tension anchor HZA, HZA-R | M12 | M16 | M20 | M24 | M27 |
|--|-----|-----|-----|-----|-----|
| Steel failure without lever arm | | | | | |
| Characteristic resistance HZA $V_{Rk,s,seis}$ [kN] | 16 | 30 | 47 | 68 | 88 |
| Characteristic resistance HZA-R $V_{Rk,s,seis}$ [kN] | 22 | 39 | 60 | 124 | - |
| Partial safety factor $\gamma_{Ms,V,seis}^{1)}$ [-] | | | 1,5 | | |

¹⁾ In absence of national regulations.

Table C23: Displacements under tension load for seismic performance category C1

| HIT-HY 200-A with Hilti tension anchor HZA, HZA-R | M12 | M16 | M20 | M24 | M27 |
|---|-----|-----|-----|-----|-----|
| Displacement ¹⁾ $\delta_{N,seis}$ [mm] | 1,3 | 1,3 | 1,3 | 1,3 | 1,3 |

¹⁾ Maximum displacement during cycling (seismic event).

Table C24: Displacements under shear load for seismic performance category C1

| HIT-HY 200-A with Hilti tension anchor HZA, HZA-R | M12 | M16 | M20 | M24 | M27 |
|---|-----|-----|-----|-----|-----|
| Displacement ¹⁾ $\delta_{V,seis}$ [mm] | 3,8 | 4,4 | 5,0 | 5,6 | 6,1 |

¹⁾ Maximum displacement during cycling (seismic event).

Injection System Hilti HIT-HY 200-A

Performances

Characteristic values for seismic performance category C1 and displacements
Design according to „EOTA Technical Report TR 045, Edition February 2013“

Annex C14

Table C25: Characteristic values of resistance for rebar under tension loads for seismic performance category C1

| HIT-HY 200-A with rebar | φ 8 | φ 10 | φ 12 | φ 14 | φ 16 | φ 20 | φ 25 | φ 26 | φ 28 | φ 30 | φ 32 |
|---|---|------|------|------|------|------|------|------|------|------|------|
| Steel failure | | | | | | | | | | | |
| Characteristic resistance for rebar N _{Rk,seis} [kN] B500B acc. to DIN 488:2009-08 ¹⁾ | | | | | | | | | | | |
| - | 43 | 62 | 85 | 111 | 173 | 270 | 292 | 339 | 388 | 442 | |
| Combined pull-out and Concrete cone failure | | | | | | | | | | | |
| Diameter of rebar d [mm] | - | 10 | 12 | 14 | 16 | 20 | 25 | 26 | 28 | 30 | 32 |
| Characteristic bond resistance in cracked concrete C20/25 | | | | | | | | | | | |
| Temperature range I: 40°C/24°C | τ _{Rk,cr} [N/mm ²] | - | 4,4 | | | | 6,1 | | | | |
| Temperature range II: 80°C/50°C | τ _{Rk,cr} [N/mm ²] | - | 3,5 | | | | 4,8 | | | | |
| Temperature range III: 120°C/72°C | τ _{Rk,cr} [N/mm ²] | - | 3 | | | | 4,4 | | | | |

¹⁾ The characteristic tension resistance N_{Rk,s,seis} for rebars that do not fulfil the requirements acc. DIN 488 shall be calculated acc. Technical Report TR 029, Equation (5.1), N_{Rk,s,seis} = N_{Rk,s}.

Table C26: Characteristic values of resistance for rebar under shear loads for seismic performance category C1

| HIT-HY 200-A with rebar | φ 8 | φ 10 | φ 12 | φ 14 | φ 16 | φ 20 | φ 25 | φ 26 | φ 28 | φ 30 | φ 32 |
|---|-----|------|------|------|------|------|------|------|------|------|------|
| Steel failure without lever arm | | | | | | | | | | | |
| Characteristic resistance for rebar V _{Rk,s,seis} [kN] B500B acc. to DIN 488:2009-08 | | | | | | | | | | | |
| - | 15 | 22 | 29 | 39 | 60 | 95 | 102 | 118 | 135 | 165 | |

¹⁾ The characteristic shear resistance V_{Rk,s,seis} for rebars that do not fulfil the requirements acc. DIN 488 shall be calculated acc. Technical Report TR 029, Equation (5.5), V_{Rk,s,seis} = 0,7 × V_{Rk,s}.

Table C27: Displacements under tension load for seismic performance category C1

| Hilti HIT-HY 200-A with rebar | φ 8 | φ 10 | φ 12 | φ 14 | φ 16 | φ 20 | φ 25 | φ 26 | φ 28 | φ 30 | φ 32 |
|---|-----|------|------|------|------|------|------|------|------|------|------|
| Displacement ¹⁾ δ _{N,seis} [mm] | - | 1,3 | 1,3 | 1,3 | 1,3 | 1,3 | 1,3 | 1,3 | 1,3 | 1,3 | 1,3 |

¹⁾ Maximum displacement during cycling (seismic event).

Table C28: Displacements under shear load for seismic performance category C1

| Hilti HIT-HY 200-A with rebar | φ 8 | φ 10 | φ 12 | φ 14 | φ 16 | φ 20 | φ 25 | φ 26 | φ 28 | φ 30 | φ 32 |
|---|-----|------|------|------|------|------|------|------|------|------|------|
| Displacement ¹⁾ δ _{V,seis} [mm] | - | 3,5 | 3,8 | 4,1 | 4,4 | 5,0 | 5,8 | 6,2 | 6,2 | 6,8 | 6,8 |

¹⁾ Maximum displacement during cycling (seismic event).

Injection System Hilti HIT-HY 200-A

Performances

Characteristic values for seismic performance category C1 and displacements
Design according to „EOTA Technical Report TR 045, Edition February 2013“

Annex C15

Table C29: Characteristic values of resistance for threaded rod, HIT-V 8.8 and AM 8.8 under tension loads for seismic performance category C2

| HIT-HY 200-A with threaded rod, HIT-V 8.8, AM 8.8 | M8 | M10 | M12 | M16 | M20 | M24 | M27 | M30 |
|--|----|-----|-----|-----|-----|-----|-----|-----|
| Steel failure | | | | | | | | |
| HIT-V 8.8, AM 8.8 $N_{Rk,s,seis}$ [kN] | | | | | | | | |
| | - | | | 126 | 196 | 282 | | - |
| Combined pullout and concrete cone failure | | | | | | | | |
| Characteristic bond resistance in cracked concrete C20/25 in hammer drilled holes and hammer drilled holes with Hilti hollow drill bit TE-CD or TE-YD | | | | | | | | |
| Temperature range I: 40 °C/24 °C $\tau_{Rk,seis}$ [N/mm ²] | - | | | 3,9 | 4,3 | 3,5 | | - |
| Temperature range II: 80 °C/50 °C $\tau_{Rk,seis}$ [N/mm ²] | - | | | 3,3 | 3,7 | 2,9 | | - |
| Temperature range III: 120 °C/72 °C $\tau_{Rk,seis}$ [N/mm ²] | - | | | 2,8 | 3,2 | 2,5 | | - |

Table C30: Characteristic values of resistance for threaded rod, HIT-V 8.8 and AM 8.8 under shear loads for seismic performance category C2

| HIT-HY 200-A with threaded rod, HIT-V 8.8, AM 8.8 | M8 | M10 | M12 | M16 | M20 | M24 | M27 | M30 |
|--|----|-----|-----|-----|-----|-----|-----|-----|
| Steel failure without lever arm with Hilti Filling set | | | | | | | | |
| HIT-V 8.8, AM 8.8 $V_{Rk,s,seis}$ [kN] | - | | | 46 | 77 | 103 | | - |
| Steel failure without lever arm without Hilti Filling set | | | | | | | | |
| HIT-V 8.8, AM 8.8 $V_{Rk,s,seis}$ [kN] | - | | | 40 | 71 | 90 | | - |
| Commercial standard threaded rod $V_{Rk,s,seis}$ [kN] | - | | | 28 | 50 | 63 | | - |

Table C31: Displacements under tension load for seismic performance category C2

| HIT-HY 200-A with threaded rod, HIT-V 8.8, AM 8.8 | M8 | M10 | M12 | M16 | M20 | M24 | M27 | M30 |
|---|----|-----|-----|-----|-----|-----|-----|-----|
| Displacement DLS $\delta_{N,seis(DLS)}$ [mm] | - | | | 0,2 | 0,5 | 0,4 | | - |
| Displacement ULS $\delta_{N,seis(ULS)}$ [mm] | - | | | 0,6 | 0,8 | 1,0 | | - |

Table C32: Displacements under shear load for seismic performance category C2

| HIT-HY 200-A with threaded rod, HIT-V 8.8, AM 8.8 | M8 | M10 | M12 | M16 | M20 | M24 | M27 | M30 |
|---|----|-----|-----|-----|------|------|-----|-----|
| Installation with Hilti Filling set | | | | | | | | |
| Displacement DLS, HIT-V 8.8, AM 8.8 $\delta_{V,seis(DLS)}$ [mm] | - | | | 1,2 | 1,42 | 1,1 | | - |
| Displacement ULS, HIT-V 8.8, AM 8.8 $\delta_{V,seis(ULS)}$ [mm] | - | | | 3,2 | 3,8 | 2,6 | | - |
| Installation without Hilti Filling set | | | | | | | | |
| Displacement DLS, HIT-V 8.8, AM 8.8 $\delta_{V,seis(DLS)}$ [mm] | - | | | 3,2 | 2,5 | 3,5 | | - |
| Displacement ULS, HIT-V 8.8, AM 8.8 $\delta_{V,seis(ULS)}$ [mm] | - | | | 9,2 | 7,1 | 10,2 | | - |

Injection System Hilti HIT-HY 200-A

Performances

Characteristic values for seismic performance category C2 and displacements
Design according to „EOTA Technical Report TR 045, Edition February 2013“

Annex C16