



Approval body for construction products and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and Laender Governments



European Technical Assessment

ETA-17/0662 of 25 October 2017

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the Deutsches Institut für Bautechnik **European Technical Assessment:** Trade name of the construction product Brandschutzmatte PB-300 Product family Intumescent product for use in penetration seals to which the construction product belongs Manufacturer **Polymerics GmbH** Landsberger Allee 378 12681 Berlin DEUTSCHLAND **Polymerics GmbH** Manufacturing plant Landsberger Allee 378 12681 Berlin DEUTSCHLAND This European Technical Assessment 9 pages including 5 annexes which form an integral part contains of this assessment This European Technical Assessment is ETAG 026 Part 2: "Penetration Seals", issued in accordance with Regulation (EU) used as EAD according to Article 66 Paragraph 3 of No 305/2011, on the basis of Regulation (EU) No 305/2011.

Deutsches Institut für Bautechnik Kolonnenstraße 30 B | 10829 Berlin | GERMANY | Phone: +49 30 78730-0 | Fax: +49 30 78730-320 | Email: dibt@dibt.de | www.dibt.de



European Technical Assessment ETA-17/0662 English translation prepared by DIBt

Page 2 of 9 | 25 October 2017

English translation prepared by Dibt

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.



Page 3 of 9 | 25 October 2017

European Technical Assessment ETA-17/0662 English translation prepared by DIBt

Specific Part

1 Technical description of the products

The construction product "Brandschutzmatte PB-300" consists of an intumescent material.

It is provided in the form of mats, strips or one-sided self-adhesive tapes. When exposed to high temperatures, the material expands creating a foam which seals joints, cracks and openings. It thus prevents the passage and spread of heat, flames and/or smoke.

Detailed specifications and fire safety related performance criteria in relation to the construction product are given in Annex 1.

NOTE:

The characteristics listed are suitable both for identifying the construction products as well as for performing the manufacturer's factory production control.

2 Specification of the intended use in accordance with the applicable European Assessment Document

The construction product "Brandschutzmatte PB-300" is intended for use as a component with a fire protection effect in penetration seals that are subject to fire safety requirements. In the event of fire, the intumescent effect helps prevent the passage of heat and the spread of fire. The construction product "Brandschutzmatte PB-300" is intended for use in penetration seals.

Construction products for penetration seals are used to seal openings in fire-resistant walls and ceilings, which are penetrated by services.

This ETA served to verify the resistance to fire of penetration seals consisting of the construction products listed in Annex 1.

Their function is to preserve the walls' or floors' resistance to fire in the area of openings where services were fed through walls.

The construction product "Brandschutzmatte PB-300" may be used for penetration seals in interiors with high humidity and temperatures above 0° C (use category type Z1).

The performance data in Section 3 relates only to the cable and pipe penetration seals tested as part of this assessment (e.g. regarding the design and arrangement of the penetration seal components and the type and position of the services).

3 Performance of the product and references to the methods used for its assessment

3.1 Safety in case of fire (BWR 2)

| Essential characteristic | Performance |
|---|---|
| Reaction to fire | Class E in accordance with EN 13501-1 |
| Resistance to fire of a penetration seal containing the product | The resistance to fire depends on the design and installation of the penetration seal and on the other components forming the penetration seal. |
| | More details on the tested penetration seals and the related fire resistance classes are given in Annexes 1 to 5. |



European Technical Assessment ETA-17/0662

Page 4 of 9 | 25 October 2017

English translation prepared by DIBt

3.2 Hygiene, health and the environment (BWR 3)

| Essential characteristic | Performance |
|---|--------------------------------------|
| Content and release of dangerous substances | No dangerous substances ¹ |

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with the European Technical Approval Guideline "Fire Stopping and Fire Sealing Products", ETAG 026, Part 2: "Penetration Seals", August 2011, which is used as European Assessment Document (EAD), the following legal base shall apply: 1999/454/EC. The system to be applied is: system 1.

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with Deutsches Institut für Bautechnik.

Issued in Berlin on 25 October 2017 by Deutsches Institut für Bautechnik

Prof. Gunter Hoppe Head of Department *beglaubigt*: Bisemeier

In accordance with Regulation (EC) No 1272/2008 of the European Parliament and the European Council of 16 December 2008 (published in the Official Journal of the European Communities L 353 of 31 December 2008, p. 1)

1

English translation prepared by DIBt



| Properties and performances criteria of the construction product "Brandschutzmatte PB-300" | | | | | | |
|--|---------------------------------|---|--|--|--|--|
| Properties | Test method | Characteristic value | | | | |
| Thickness | | 2,0 mm ± 0,2 mm | | | | |
| Density (delivery state) | EN ISO 2811-1 | 1,20 g/cm ³ ± 10% | | | | |
| Mass loss during heating* | EN ISO 3451-1; EOTA TR 024:2009 | 49 % to 59 % | | | | |
| Expansion ratio | ETAG 026-2** | 15,5 to 20,5 (tested with samples of a thickness of ~ 1,9 mm) | | | | |
| Expansion pressure | ETAG 026-2** | 0,75 to 1,2 N/mm ² | | | | |
| Fire behavior | EN 13501-1 | Classification of fire behavior according to EN 13501-1: Class E | | | | |

The properties listed can be used both for the identification of the construction product and for the implementation of the factory production control of the manufacturer.

Implementation details for the factory production control are included in the inspection plan.

Description of the additional components of the tested sealings in accordance to Annexes 3 to 5

| "Halogenfreier Brandschutzschaum PB-165" | Material: Polyurethane-based two-component foam according to ETA-12/0279 | |
|---|---|--|
| | Classification of fire behavior according to EN 13501-1: Class E | |
| Gypsum mortar | Classification of fire behavior: Class A1 according to the commission decision 96/603/EC (in the amended version) | |
| Boards for frames | The frames consist of gypsum plasterboard according to EN 520, Typ F with a minimum thickness of 20 mm. Classification of fire behavior according to EN 13501-1: Class A2 | |
| additional panels | The additional panels consist of strips of building boards Type "PROMATECT H" according to ETA-06/0206 with a minimum thickness of 250 mm. Classification of fire behavior according to EN 13501-1: Class A1 | |

The composition of the materials is deposited at DIBt.

** tested according to ETAG 026-2 (also see TR 024)

Brandschutzmatte PB-300

Properties and performances

Annex 1

Page 6 of European Technical Assessment ETA-17/0662 of 25 October 2017

English translation prepared by DIBt



| F | Performances of penetration seals, comprising the construction product "Brandschutzmatte PB-300" | | | | | | |
|---|--|-----------------------|-------------|---|-----------------------------------|--|--|
| | | Essential requirement | Test method | Construction of the sample | Performance acc. to EN 13501-2 | | |
| | 1 | Resistance to fire | EN 1366-3 | 100 mm thick flexible wall; design and layout of the penetration seal according to Annex 3* | EI 90 | | |
| | 2 | Resistance to fire | EN 1366-3 | 100 mm thick rigid wall; design and layout of the penetration seal according to Annex 3* | EI 90 | | |
| | 3 | Resistance to fire | EN 1366-3 | 100 mm thick flexible wall; design and layout of the penetration seal according to Annex 4* | EI 90 | | |
| | 4 | Resistance to fire | EN 1366-3 | 150 mm thick rigid floor; design and layout of the penetration seal according to Annex 5* | EI 90 | | |

* Illustrations without guarantee for completness

The use of the construction product "Brandschutzmatte PB-300" in penetration seals shall be in accordance with national requirements for planning, design and execution and in accordance with the installation instruction of the manufacturer.

The tested/illustrated seals are only examples fort he use.


Brandschutzmatte PB-300

Properties and performances

Annex 2

English translation prepared by DIBt






Page 8 of European Technical Assessment ETA-17/0662 of 25 October 2017

English translation prepared by DIBt





Page 9 of European Technical Assessment ETA-17/0662 of 25 October 2017

English translation prepared by DIBt



