

Approval body for construction products
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and
Laender Governments

★ ★ ★
★ Designated
according to
Article 29 of Regula-
tion (EU) No 305/2011
and member of EOTA
(European Organi-
sation for Technical
Assessment)
★ ★ ★
★ ★

European Technical Assessment

ETA-17/0438
of 12 December 2017

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the
European Technical Assessment:

Trade name of the construction product

Product family
to which the construction product belongs

Manufacturer

Manufacturing plant

This European Technical Assessment
contains

This European Technical Assessment is
issued in accordance with Regulation (EU)
No 305/2011, on the basis of

Deutsches Institut für Bautechnik

fischer Injection system Anchorstar Plus

Injection system for use in concrete

fischerwerke GmbH & Co. KG
Klaus-Fischer-Straße 1
72178 Waldachtal
DEUTSCHLAND

fischerwerke

21 pages including 3 annexes which form an integral part
of this assessment

ETAG 001 Part 5: "Bonded anchors", April 2013,
used as EAD according to Article 66 Paragraph 3 of
Regulation (EU) No 305/2011.

European Technical Assessment

ETA-17/0438

English translation prepared by DIBt

Page 2 of 21 | 12 December 2017

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

Specific Part**1 Technical description of the product**

The fischer injection system Anchorstar Plus is a bonded anchor consisting of a cartridge with injection mortar Anchorstar Plus, Anchorstar Plus High Speed or Anchorstar Plus Low Speed and a steel element.

The steel element is placed into a drilled hole filled with injection mortar and is anchored via the bond between metal part, injection mortar and concrete.

The product description is given in Annex A.

2 Specification of the intended use in accordance with the applicable European Assessment Document

The performances given in Section 3 are only valid if the anchor is used in compliance with the specifications and conditions given in Annex B.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the anchor of at least 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and references to the methods used for its assessment**3.1 Mechanical resistance and stability (BWR 1)**

Essential characteristic	Performance
Characteristic values for static and quasi-static action, displacements	See Annex C 1 to C 6

3.2 Safety in case of fire (BWR 2)

Essential characteristic	Performance
Reaction to fire	Anchorage satisfies requirements for Class A1
Resistance to fire	No performance assessed

3.3 Hygiene, health and the environment (BWR 3)

Regarding dangerous substances there may be requirements (e.g. transposed European legislation and national laws, regulations and administrative provisions) applicable to the products falling within the scope of this European Technical Assessment. In order to meet the provisions of Regulation (EU) No 305/2011, these requirements need also to be complied with, when and where they apply.

3.4 Safety in use (BWR 4)

The essential characteristics regarding Safety in use are included under the Basic Works Requirement Mechanical resistance and stability.

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with guideline for European technical approval ETAG 001, April 2013 used as European Assessment Document (EAD) according to Article 66 Paragraph 3 of Regulation (EU) No 305/2011 the applicable European legal act is: [96/582/EC].

The system to be applied is: 1

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable European Assessment Document


Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited at Deutsches Institut für Bautechnik.

Issued in Berlin on 12 December 2017 by Deutsches Institut für Bautechnik

Dr.-Ing. Lars Eckfeldt
p.p. Head of Department

beglaubigt:
Baderschneider

Installation conditions



Anchor rod
Pre-positioned anchor

Anchor rod
Push through anchor
(annular gap filled with mortar)

fischer
internal threaded anchor RG MI
Pre-positioned anchor only




Table A1: Materials

Part	Designation	Material		
1	Mortar cartridge	Mortar, hardener, filler		
	Steel grade	Steel, zinc plated	Stainless steel A4	High corrosion resistant steel C
2	Anchor rod	Property class 5.8 or 8.8; EN ISO 898-1:2013 zinc plated $\geq 5 \mu\text{m}$, EN ISO 4042:1999 A2K or hot-dip galvanised EN ISO 10684:2004 $f_{uk} \leq 1000 \text{ N/mm}^2$ $A_5 > 8 \%$ fracture elongation	Property class 50, 70 or 80 EN ISO 3506-1:2009 1.4401; 1.4404; 1.4578; 1.4571; 1.4439; 1.4362; 1.4062, 1.4662, 1.4462 EN 10088-1:2014 $f_{uk} \leq 1000 \text{ N/mm}^2$ $A_5 > 8 \%$ fracture elongation	Property class 50 or 80 EN ISO 3506-1:2009 or property class 70 with $f_{yk} = 560 \text{ N/mm}^2$ 1.4565; 1.4529 EN 10088-1:2014 $f_{uk} \leq 1000 \text{ N/mm}^2$ $A_5 > 8 \%$ fracture elongation
3	Washer ISO 7089:2000	zinc plated $\geq 5 \mu\text{m}$, EN ISO 4042:1999 A2K or hot-dip galvanised EN ISO 10684:2004	1.4401; 1.4404; 1.4578; 1.4571; 1.4439; 1.4362 EN 10088-1:2014	1.4565; 1.4529 EN 10088-1:2014
4	Hexagon nut	Property class 5 or 8; EN ISO 898-2:2012 zinc plated $\geq 5 \mu\text{m}$, ISO 4042:1999 A2K or hot-dip galvanised EN ISO 10684:2004	Property class 50, 70 or 80 EN ISO 3506-1:2009 1.4401; 1.4404; 1.4578; 1.4571; 1.4439; 1.4362 EN 10088-1:2014	Property class 50, 70 or 80 EN ISO 3506-1:2009 1.4565; 1.4529 EN 10088-1:2014
5	fischer internal threaded anchor RG MI	Property class 5.8 ISO 898-1:2013 zinc plated $\geq 5 \mu\text{m}$, ISO 4042:1999 A2K	Property class 70 EN ISO 3506-1:2009 1.4401; 1.4404; 1.4578; 1.4571; 1.4439; 1.4362 EN 10088-1:2014	Property class 70 EN ISO 3506-1:2009 1.4565; 1.4529 EN 10088-1:2014
6	Commercial standard screw or anchor / threaded rod for fischer internal threaded anchor RG MI	Property class 5.8 or 8.8; EN ISO 898-1:2013 zinc plated $\geq 5 \mu\text{m}$, ISO 4042:1999 A2K fracture elongation $A_5 > 8 \%$	Property class 70 EN ISO 3506-1:2009 1.4401; 1.4404; 1.4578; 1.4571; 1.4439; 1.4362 EN 10088-1:2014 fracture elongation $A_5 > 8 \%$	Property class 70 EN ISO 3506-1:2009 1.4565; 1.4529 EN 10088-1:2014 fracture elongation $A_5 > 8 \%$
fischer injection system Anchorstar Plus				
Product description Materials				Annex A 3

Specifications of intended use (part 1)

Table B1: Overview use and performance categories

Anchorage subject to		Anchorstar Plus, Anchorstar Plus High Speed or Anchorstar Plus Low Speed with ...		
		Anchor rod		fischer internal threaded anchor RG MI
				
Hammer drilling with standard drill bit		all sizes		
Hammer drilling with hollow drill bit (Heller "Duster Expert" or Hilti "TE-CD, TE-YD")		Nominal drill bit diameter (d_0) 12 mm to 35 mm		
Static and quasi static load, in	uncracked concrete	M6 to M30	Tables: C1, C3, C4, C6	M8 to M20
	cracked concrete	M10 to M20		not assessed
Use category	dry or wet concrete	M6 to M30	M8 to M20	
	flooded hole ¹⁾	M12 to M30	M8 to M20	
Installation temperature	-10 °C to +40 °C			
In-service temperature	Temperature range I	-40 °C to +80 °C	(max. long term temperature +50 °C and max. short term temperature +80 °C)	
	Temperature range II	-40 °C to +120 °C	(max. long term temperature +72 °C and max. short term temperature +120 °C)	
¹⁾ Only with coaxial cartridges: 380 ml, 400 ml, 410 ml				
fischer injection system Anchorstar Plus				
Intended Use Specifications (part 1)				Annex B 1

Specifications of intended use (part 2)

Base materials:

- Reinforced or unreinforced normal weight concrete Strength classes C20/25 to C50/60 according to EN 206-1:2000

Use conditions (Environmental conditions):

- Structures subject to dry internal conditions (zinc coated steel, stainless steel or high corrosion resistant steel)
- Structures subject to external atmospheric exposure (including industrial and marine environment) and to permanently damp internal condition, if no particular aggressive conditions exist (stainless steel or high corrosion resistant steel)
- Structures subject to external atmospheric exposure, to permanently damp internal conditions or in other particular aggressive conditions (high corrosion resistant steel)

Note: Particular aggressive conditions are e. g. permanent, alternating immersion in seawater or the splash zone of seawater, chloride atmosphere of indoor swimming pools or atmosphere with extreme chemical pollution (e. g. in desulphurization plants or road tunnels where de-icing materials are used)

Design:

- Anchorages have to be designed by a responsible engineer with experience of concrete anchor design
- Verifiable calculation notes and drawings are to be prepared taking account of the loads to be anchored. The position of the anchor is indicated on the design drawings (e. g. position of the anchor relative to reinforcement or to supports, etc.)
- Anchorages under static or quasi-static actions are designed in accordance with EOTA Technical Report TR 029 "Design of bonded anchors" Edition September 2010 or CEN/TS 1992-4: 2009

Installation:

- Anchor installation is to be carried out by appropriately qualified personnel and under the supervision of the person responsible for technical matters of the site
- In case of aborted hole: The hole shall be filled with mortar
- Anchorage depth should be marked and adhered to on installation
- Overhead installation is allowed

fischer injection system Anchorstar Plus

Intended Use
Specifications (part 2)

Annex B 2


Table B2: Installation parameters for anchor rods

Size		M6	M8	M10	M12	M16	M20	M24	M27	M30		
Width across flats	SW	[mm]	10	13	17	19	24	30	36	41	46	
Nominal drill bit diameter	d_0		8	10	12	14	18	24	28	30	35	
Drill hole depth	h_0		$h_0 = h_{\text{ef}}$									
Effective anchorage depth	$h_{\text{ef,min}}$		50	60	60	70	80	90	96	108	120	
	$h_{\text{ef,max}}$		72	160	200	240	320	400	480	540	600	
Minimum spacing and minimum edge distance	s_{\min} = c_{\min}		40	40	45	55	65	85	105	125	140	
Diameter of clearance hole in the fixture ¹⁾	pre-positioned anchorage		7	9	12	14	18	22	26	30	33	
	push through anchorage		9	11	14	16	20	26	30	32	40	
Minimum thickness of concrete member	h_{\min}		$h_{\text{ef}} + 30$ (≥ 100)				$h_{\text{ef}} + 2d_0$					
Maximum installation torque	$T_{\text{inst,max}}$	[Nm]	5	10	20	40	60	120	150	200	300	


¹⁾ For larger clearance holes in the fixture see TR 029, 4.2.2.1 or CEN/TS 1992-4-1:2009, 5.2.3.1

Anchor rods:

fischer
FIS A



fischer
RG M



Marking (on random place) fischer anchor rod:

Property class 8.8, stainless steel A4 property class 80 and high corrosion resistant steel C property class 80: •

Stainless steel A4 property class 50 and high corrosion resistant steel C property class 50: ••
Or colour coding according to DIN 976-1

Commercial standard threaded rods, washers and hexagon nuts may also be used if the following requirements are fulfilled:

- Materials, dimensions and mechanical properties according Annex A 3, Table A1
- Inspection certificate 3.1 according to EN 10204:2004, the documents have to be stored
- Setting depth is marked

fischer injection system Anchorstar Plus

Intended Use
Installation parameters anchor rods


Annex B 3

Table B3: Installation parameters for fischer internal threaded anchors RG MI


Size		M8	M10	M12	M16	M20	
Diameter of anchor	d_H	[mm]	12	16	18	22	28
Nominal drill bit diameter	d_0		14	18	20	24	32
Drill hole depth	h_0		$h_0 = h_{ef} = L_H$				
Effective anchorage depth ($h_{ef} = L_H$)	h_{ef}		90	90	125	160	200
Minimum spacing and minimum edge distance	$s_{min} = c_{min}$		55	65	75	95	125
Diameter of clearance hole in the fixture ¹⁾	d_f		9	12	14	18	22
Minimum thickness of concrete member	h_{min}		120	125	165	205	260
Maximum screw-in depth	$l_{E,max}$		18	23	26	35	45
Minimum screw-in depth	$l_{E,min}$		8	10	12	16	20
Maximum installation torque	$T_{inst,max}$	[Nm]	10	20	40	80	120

¹⁾ For larger clearance holes in the fixture see TR 029, 4.2.2.1 or CEN/TS 1992-4-1: 2009, 5.2.3.1

fischer internal threaded anchor RG MI



Marking



Marking: Anchor size
e. g.: M10

Stainless steel additional **A4**
e. g.: M10 A4

High corrosion resistant steel
additional **C**
e. g.: M10 C

Retaining bolt or threaded rods (including nut and washer) must comply with the appropriate material and strength class of Annex A 3, Table A1

fischer injection system Anchorstar Plus

Intended Use

Installation parameters fischer internal threaded anchors RG MI

Annex B 4

Table B4: Diameters of cleaning brush BS (steel brush)

The size of the steel brush refers to the nominal drill bit diameter

Nominal drill bit diameter	d_0	[mm]	8	10	12	14	16	18	20	24	25	28	30	35
Steel brush diameter	d_b		9	11	14	16		20	25	26	27	30		40




Table B5: Maximum processing time of the mortar and minimum curing time

(During the curing time of the mortar the concrete temperature may not fall below the listed minimum temperature)

System temperature [°C]	Maximum processing time t_{work}			Minimum curing time ¹⁾ t_{cure}		
	Anchorstar Plus High Speed	Anchorstar Plus	Anchorstar Plus Low Speed	Anchorstar Plus High Speed	Anchorstar Plus	Anchorstar Plus Low Speed
-10 to -5	---	---	---	12 h	---	---
> -5 to ± 0	5 min	---	---	3 h	24 h	---
> ± 0 to +5	5 min	13 min	---	3 h	3 h	6 h
> +5 to +10	3 min	9 min	20 min	50 min	90 min	3 h
> +10 to +20	1 min	5 min	10 min	30 min	60 min	2 h
> +20 to +30	---	4 min	6 min	---	45 min	60 min
> +30 to +40	---	2 min	4 min	---	35 min	30 min

¹⁾ In wet concrete or flooded holes the curing times must be doubled

fischer injection system Anchorstar Plus

Intended Use
Cleaning tools
Processing times and curing times

Annex B 5

Installation instructions part 1

Drilling and cleaning the hole (hammer drilling with standard drill bit)

1		Drill the hole. Drill hole diameter d_0 and drill hole depth h_0 see Tables B2, B3		
2		Clean the drill hole: For $h_{ef} \leq 12d$ and $d_0 < 18 \text{ mm}$ blow out the hole four times by hand		For $h_{ef} > 12d$ and / or $d_0 \geq 18 \text{ mm}$ blow out the hole four times with oil-free compressed air ($p \geq 6 \text{ bar}$)
3		Brush the drill hole four times. For deep holes use an extension. Corresponding brushes see Table B4		
4		Clean the drill hole: For $h_{ef} \leq 12d$ and $d_0 < 18 \text{ mm}$ blow out the hole four times by hand		For $h_{ef} > 12d$ and / or $d_0 \geq 18 \text{ mm}$ blow out the hole four times with oil-free compressed air ($p \geq 6 \text{ bar}$)

Go to step 5

Drilling and cleaning the hole (hammer drilling with hollow drill bit)

1		Check a suitable hollow drill (see Table B1) for correct operation of the dust extraction
2		Use a suitable dust extraction system, e. g. Bosch GAS 35 M AFC or a comparable dust extraction system with equivalent performance data Drill the hole with hollow drill bit. The dust extraction system has to extract the drill dust nonstop during the drilling process and must be adjusted to maximum power. Diameter of drill hole d_0 and drill hole depth h_0 see Tables B2, B3

Go to step 5



fischer injection system Anchorstar Plus

Intended use
Installation instructions part 1

Annex B 6


Installation instructions part 2

Preparing the cartridge

5		Remove the sealing cap Screw on the static mixer (the spiral in the static mixer must be clearly visible)
6		Place the cartridge into the dispenser
7		Extrude approximately 10 cm of material until the resin is evenly grey in colour. Do not use mortar that is not uniformly grey

Go to step 8

Mörtelinjektion

8		Fill approximately 2/3 of the drill hole with mortar. Always begin from the bottom of the hole and avoid bubbles For drill hole depth ≥ 150 mm use an extension tube For overhead installation, deep holes ($h_0 > 250$ mm) or drill hole diameter ($d_0 \geq 40$ mm) use an injection-adapter
---	---	---

Go to step 9

Installation instructions part 3

Installation of anchor rods or fischer internal threaded anchors RG MI





9		<p>Only use clean and oil-free anchor elements. Mark the setting depth of the anchor. Push the anchor rod or fischer internal threaded RG MI anchor down to the bottom of the hole, turning it slightly while doing so. After inserting the anchor element, excess mortar must be emerged around the anchor element.</p>
	 <p>For overhead installations support the anchor rod with wedges. (e. g. fischer centering wedges)</p>	 <p>For push through installation fill the annular gap with mortar</p>
10	 <p>Wait for the specified curing time t_{cure} see Table B5</p>	11  <p>Mounting the fixture $T_{inst,max}$ see Tables B2 and B3</p>
fischer injection system Anchorstar Plus		
Intended use Installation instructions part 3		Annex B 8

Table C1: Characteristic values for the **steel bearing capacity** of anchor rods under tensile / shear load

Size		M6	M8	M10	M12	M16	M20	M24	M27	M30											
Bearing capacity under tensile load, steel failure																					
Charact.bearing capacity $N_{Rk,s}$	Steel zinc plated	5.8	[kN]	10	19	29	43	79	123	177											
				16	29	47	68	126	196	282											
				10	19	29	43	79	123	177											
	Stainless steel A4 and High corrosion resistant steel C	50		14	26	41	59	110	172	247											
				16	30	47	68	126	196	282											
				16	30	47	68	126	196	282											
Partial safety factors¹⁾																					
Partial safety factor $\gamma_{Ms,N}$	Steel zinc plated	5.8	[-]	1,50																	
				1,50																	
				2,86																	
	Stainless steel A4 and High corrosion resistant steel C	70		1,50 ²⁾ / 1,87																	
				1,60																	
Bearing capacity under shear load, steel failure																					
without lever arm																					
Charact.bearing capacity $V_{Rk,s}$	Steel zinc plated	5.8	[kN]	5	9	15	21	39	61	89											
				8	15	23	34	63	98	141											
				5	9	15	21	39	61	89											
	Stainless steel A4 and High corrosion resistant steel C	70		7	13	20	30	55	86	124											
				8	15	23	34	63	98	141											
				8	15	23	34	63	98	141											
Ductility factor acc. to CEN/TS 1992-4-5:2009 Section 6.3.2.1		k ₂		1,0																	
with lever arm																					
Charact.bending moment $M_{Rk,M}$	Steel zinc plated	5.8	[Nm]	7	19	37	65	166	324	560											
				12	30	60	105	266	519	896											
				7	19	37	65	166	324	560											
	Stainless steel A4 and High corrosion resistant steel C	70		10	26	52	92	232	454	784											
				12	30	60	105	266	519	896											
				12	30	60	105	266	519	896											
Partial safety factors¹⁾																					
Partial safety factor $\gamma_{Ms,V}$	Steel zinc plated	5.8	[-]	1,25																	
				1,25																	
				2,38																	
	Stainless steel A4 and High corrosion resistant steel C	70		1,25 ²⁾ / 1,56																	
				1,33																	
¹⁾ In absence of other national regulations																					
²⁾ Only for fischer FIS A and RG M made of high corrosion-resistant steel C																					
fischer injection system Anchorstar Plus								Annex C 1													
Performances Characteristic steel bearing capacity anchor rods								Annex C 1													

Table C2: Characteristic values for the steel bearing capacity of fischer internal threaded anchors RG MI under tensile / shear load

Size	M8	M10	M12	M16	M20		
Bearing capacity under tensile load, steel failure							
Characteristic bearing capacity $N_{Rk,s}$ with screw	Property class 5.8 8.8	[kN]	19 29 26 26	29 47 41 41	43 68 59 59	79 108 110 110	123 179 172 172
Partial safety factors¹⁾							
Partial safety factor $\gamma_{Ms,N}$	Property class 5.8 8.8 A4 class 70	[γ]					1,50 1,50 1,87 1,87
Bearing capacity under shear load, steel failure							
without lever arm							
Characteristic bearing capacity $V_{Rk,s}$ with screw	Property class 5.8 8.8 A4 class 70	[kN]	9,2 14,6 12,8 12,8	14,5 23,2 20,3 20,3	21,1 33,7 29,5 29,5	39,2 54,0 54,8 54,8	62,0 90,0 86,0 86,0
Ductility factor acc. to CEN/TS 1992-4-5:2009 Section 6.3.2.1	k_2	[γ]					1,0
with lever arm							
Characteristic bending moment $M_{Rk,s}^0$ with screw	Property class 5.8 8.8 A4 class 70	[Nm]	20 30 26 26	39 60 52 52	68 105 92 92	173 266 232 232	337 519 454 454
Partial safety factors¹⁾							
Partial safety factor $\gamma_{Ms,V}$	Property class 5.8 8.8 A4 class 70	[γ]					1,25 1,25 1,56 1,56
¹⁾ In absence of other national regulations							
fischer injection system Anchorstar Plus							
Performances Characteristic steel bearing capacity of fischer internal threaded anchors RG MI							
Annex C 2							

Table C3: General design factors for the bearing capacity under tensile / shear load; uncracked or cracked concrete

Size	All sizes					
Bearing capacity under tensile load						
Factors acc. to CEN/TS 1992-4:2009 Section 6.2.2.3						
Uncracked concrete k_{ucr} [-] 10,1						
Cracked concrete k_{cr}			7,2			
Factors for the compressive strength of concrete > C20/25						
Increasing factor for τ_{RK}	C25/30	Ψ_c [-]	1,05			
	C30/37		1,10			
	C35/45		1,15			
	C40/50		1,19			
	C45/55		1,22			
	C50/60		1,26			
Splitting failure						
Edge distance	$h / h_{ef} \geq 2,0$	[mm]	1,0 h_{ef}			
	$2,0 > h / h_{ef} > 1,3$		4,6 h_{ef} - 1,8 h			
	$h / h_{ef} \leq 1,3$		2,26 h_{ef}			
Spacing	$s_{cr,sp}$		2 $c_{cr,sp}$			
Concrete cone failure acc. to CEN/TS 1992-4-5:2009 Section 6.2.3.2						
Edge distance	$c_{cr,N}$	[mm]	1,5 h_{ef}			
Spacing	$s_{cr,N}$		2 $c_{cr,N}$			
Bearing capacity under shear load						
Installation safety factors						
All installation conditions	$\gamma_2 = \gamma_{inst}$ [-]		1,2			
Concrete pry-out failure						
Factor k acc. to TR029 Section 5.2.3.3 resp. k_3 acc. to CEN/TS 1992-4-5:2009 Section 6.3.3	$k_{(3)}$ [-]		2,0			
Concrete edge failure						
The value of h_{ef} (= l_f) under shear load	[mm]	min (h_{ef} ; 8d)				
Calculation diameters						
Size		M6 M8 M10 M12 M16 M20 M24 M27 M30				
Anchor rods	d	6 8 10 12 16 20 24 27 30				
fischer internal threaded anchors RG MI	d_{nom}	[mm] --- 12 16 18 22 28 --- --- ---				
fischer injection system Anchorstar Plus						
Performances General design factors relating to the characteristic bearing capacity under tensile / shear load						
			Annex C 3			

Table C4: Characteristic values of resistance for anchor rods
in hammer drilled holes; uncracked or cracked concrete

Size		M6	M8	M10	M12	M16	M20	M24	M27	M30	
Combined pullout and concrete cone failure											
Calculation diameter	d [mm]	6	8	10	12	16	20	24	27	30	
Uncracked concrete											
Characteristic bond resistance in uncracked concrete C20/25											
Hammer-drilling with standard drill bit or hollow drill bit (dry and wet concrete)											
Tem- perature	I: 50 °C / 80 °C II: 72 °C / 120 °C	$\tau_{Rk,ucr}$	[N/mm ²]	9,0 6,5	11,0 9,5	11,0 9,5	11,0 9,0	10,0 8,5	9,5 8,0	9,0 7,5	8,5 7,0
Hammer-drilling with standard drill bit or hollow drill bit (flooded hole) ¹⁾											
Tem- perature	I: 50 °C / 80 °C II: 72 °C / 120 °C	$\tau_{Rk,ucr}$	[N/mm ²]	---	---	---	9,5 7,5	8,5 7,0	8,0 7,5	7,5 7,0	7,0 7,0
Installation safety factors											
Dry and wet concrete	$\gamma_2 = \gamma_{inst}$	[\cdot]								1,2	
Flooded hole				---						1,4 ¹⁾	
Cracked concrete											
Characteristic bond resistance in cracked concrete C20/25											
Hammer-drilling with standard drill bit or hollow drill bit (dry and wet concrete)											
Tem- perature	I: 50 °C / 80 °C II: 72 °C / 120 °C	$\tau_{Rk,cr}$	[N/mm ²]	---	---	6,0 5,0	6,0 5,0	6,0 5,0	5,5 5,0	---	---
Hammer-drilling with standard drill bit or hollow drill bit (flooded hole) ¹⁾											
Tem- perature	I: 50 °C / 80 °C II: 72 °C / 120 °C	$\tau_{Rk,cr}$	[N/mm ²]	---	---	---	5,0 4,0	5,0 4,0	4,5 4,0	---	---
Installation safety factors											
Dry and wet concrete	$\gamma_2 = \gamma_{inst}$	[\cdot]								1,2	
Flooded hole				---						1,4 ¹⁾	
¹⁾ Only with coaxial cartridges: 380 ml, 400 ml, 410 ml											
fischer injection system Anchorstar Plus											
Performances											
Characteristic values for static or quasi-static action under tensile load for anchor rods (uncracked or cracked concrete)											
Annex C 4											

Table C5: Characteristic values of resistance for fischer internal threaded anchors RG MI in hammer drilled holes; uncracked concrete

Size	M8	M10	M12	M16	M20			
Combined pullout and concrete cone failure								
Calculation diameter d [mm]	12	16	18	22	28			
Uncracked concrete								
Characteristic bond resistance in uncracked concrete C20/25								
Hammer-drilling with standard drill bit or hollow drill bit (dry and wet concrete)								
Tem- perature range	I: 50 °C / 80 °C II: 72 °C / 120 °C	$\tau_{RK,ucr}$	[N/mm ²]	10,5 9,0	10,0 8,0	9,5 8,0	9,0 7,5	8,5 7,0
Hammer-drilling with standard drill bit or hollow drill bit (flooded hole) ¹⁾								
Tem- perature range	I: 50 °C / 80 °C II: 72 °C / 120 °C	$\tau_{RK,ucr}$	[N/mm ²]	10,0 7,5	9,0 6,5	9,0 6,5	8,5 6,0	8,0 6,0
Installation safety factors								
Dry and wet concrete						1,2		
Flooded hole		$\gamma_2 = \gamma_{inst}$	[-]			1,4 ¹⁾		

¹⁾ Only with coaxial cartridges: 380 ml, 400 ml, 410 ml

fischer injection system Anchorstar Plus

Performances

Characteristic values for static or quasi-static action under tensile load for fischer internal threaded anchors RG MI and reinforcing bars (uncracked concrete)

Annex C 5

Table C6: Displacements for anchor rods

Size	M6	M8	M10	M12	M16	M20	M24	M27	M30
Displacement-Factors for tensile load¹⁾									
Uncracked concrete; Temperature range I, II									
δ_{N0} -Faktor	[mm/(N/mm ²)]	0,09	0,09	0,09	0,10	0,10	0,10	0,10	0,12
$\delta_{N\infty}$ -Faktor		0,10	0,10	0,10	0,12	0,12	0,12	0,13	0,14
Cracked concrete; Temperature range I, II									
δ_{N0} -Faktor	[mm/(N/mm ²)]	---	---	0,12	0,12	0,13	0,13	---	---
$\delta_{N\infty}$ -Faktor		---	---	0,27	0,30	0,30	0,30	---	---
Displacement-Factors for shear load²⁾									
Uncracked or cracked concrete; Temperature range I, II									
δ_{V0} -Faktor	[mm/kN]	0,11	0,11	0,11	0,10	0,10	0,09	0,09	0,08
$\delta_{V\infty}$ -Faktor		0,12	0,12	0,12	0,11	0,11	0,10	0,09	0,09

¹⁾ Calculation of effective displacement:

$$\delta_{N0} = \delta_{N0}\text{-Factor} \cdot \tau_{Ed}$$

$$\delta_{N\infty} = \delta_{N\infty}\text{-Factor} \cdot \tau_{Ed}$$

(τ_{Ed} : Design value of the applied tensile stress)

²⁾ Calculation of effective displacement:

$$\delta_{V0} = \delta_{V0}\text{-Factor} \cdot V_{Ed}$$

$$\delta_{V\infty} = \delta_{V\infty}\text{-Factor} \cdot V_{Ed}$$

(V_{Ed} : Design value of the applied shear force)

Table C7: Displacements for fischer internal threaded anchors RG MI

Size	M8	M10	M12	M16	M20
Displacement-Factors for tensile load¹⁾					
Uncracked concrete; Temperature range I, II					
δ_{N0} -Faktor	[mm/(N/mm ²)]	0,10	0,11	0,12	0,13
$\delta_{N\infty}$ -Faktor		0,13	0,14	0,15	0,16
Displacement-Factors for shear load²⁾					
Uncracked concrete; Temperature range I, II					
δ_{V0} -Faktor	[mm/kN]	0,12	0,12	0,12	0,12
$\delta_{V\infty}$ -Faktor		0,14	0,14	0,14	0,14

¹⁾ Calculation of effective displacement:

$$\delta_{N0} = \delta_{N0}\text{-Factor} \cdot \tau_{Ed}$$

$$\delta_{N\infty} = \delta_{N\infty}\text{-Factor} \cdot \tau_{Ed}$$

(τ_{Ed} : Design value of the applied tensile stress)

²⁾ Calculation of effective displacement:

$$\delta_{V0} = \delta_{V0}\text{-Factor} \cdot V_{Ed}$$

$$\delta_{V\infty} = \delta_{V\infty}\text{-Factor} \cdot V_{Ed}$$

(V_{Ed} : Design value of the applied shear force)

fischer injection system Anchorstar Plus

Performances

Displacements for anchor rods and fischer internal threaded anchors RG MI

Annex C 6