

Approval body for construction products  
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and  
Laender Governments



## European Technical Assessment

**ETA-05/0093**  
**of 7 June 2018**

English translation prepared by DIBt - Original version in German language

### General Part

Technical Assessment Body issuing the  
European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

Multipor Mineraldämmplatte 042  
Multipor Mineraldämmplatte 045  
Multipor Mineraldämmplatte 047

Product family  
to which the construction product belongs

Thermal insulating board made of mineral material

Manufacturer

Xella Deutschland GmbH  
Werksweg 2  
92551 Stulln  
DEUTSCHLAND

Manufacturing plant

WERK 1, Deutschland  
WERK 2, Deutschland  
WERK 3, Deutschland  
WERK 4, Bulgarien  
WERK 5, Österreich

This European Technical Assessment  
contains

7 pages which form an integral part of this assessment

This European Technical Assessment is  
issued in accordance with Regulation (EU)  
No 305/2011, on the basis of

EAD 040012-00-1201

This version replaces

ETA-05/0093 issued on 17 July 2015

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

## Specific Part

### 1 Technical description of the product

This European Technical Assessment applies to the thermal insulating boards made of mineral material with the designations "Multipor Mineraleämmplatte 042", "Multipor Mineraleämmplatte 045" and "Multipor Mineraleämmplatte 047".

The thermal insulating boards are manufactured of quartz powder, calcium hydrate, cement and aggregates by adding of aluminium as a pore forming agent and are high-pressure steam cured (autoclaved).

The thermal insulating boards are produced of different compositions and densities. Depending on composition and density the boards have a compressive strength of at least 200 kPa in conjunction with a declared value of thermal conductivity of  $\lambda_{D23/50} = 0.040 \text{ W/(m}\cdot\text{K)}$ , a compressive strength of at least 300 kPa in conjunction with a declared value of thermal conductivity of  $\lambda_{D23/50} = 0.043 \text{ W/(m}\cdot\text{K)}$  or a compressive strength of at least 350 kPa in conjunction with a declared value of thermal conductivity of  $\lambda_{D23/50} = 0.045 \text{ W/(m}\cdot\text{K)}$ .

The surface of the thermal insulating boards can also be provided in the factory with a priming coat ("XELLA Grundierung") on both sides.

The boards are made with the following dimensions:

Nominal thicknesses: 20 mm to 300 mm

Nominal lengths: 350 mm to 1000 mm

Nominal widths: 200 mm to 750 mm

The thermal insulating boards can show a gradient of up to 9° in longitudinal direction.

The European Technical Assessment has been issued for the products on the basis of agreed data/ information, deposited with Deutsches Institut für Bautechnik, which identifies the products that has been assessed. The European Technical Assessment applies only to products corresponding to this agreed data/information.

### 2 Specification of the intended use in accordance with the applicable European assessment Document

The thermal insulating boards can be used for the following intended uses:

Area of application for walls

- External insulation of walls
- Internal insulation of walls (including added facing shells without substructure)
- Insulation of cavity walls (two-leaf walls), core insulation
- Cavity insulation in walls, insulation of timber frame and wood panel construction

Area of application for pitched roofs/flat roofs

- External insulation of the roof below the roofing and below waterproofing
- Insulation between rafters

Area of application for floors/ceilings

- Internal insulation of ceilings (e.g. ceiling insulation in cellars and underground parking garages)
- Internal insulation of floors or bedplates (on the top) below screeds

The performance according to section 3 only applies if the insulation materials are installed according to the manufacture's installation instructions and if they are protected from precipitation, wetting or weathering in built-in state and during transport, storage and installation.

This European technical assessment does not cover the use of the thermal insulating boards in thermal insulation systems. In this regard separate European technical assessments are necessary for certain intended uses (e.g. in the case of a use in external thermal insulation composite systems).

Where the thermal insulation boards are fixed by using adhesives and/or anchors, only such adhesions or anchors shall be used, which are suitable for this purpose. The assessment of these fixings is not subject of this European Technical Assessment.

As to the application of the insulation product, the respective national regulations shall be additionally observed.

The design value of the thermal conductivity shall be laid down according to relevant national provisions.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the thermal insulating boards of at least 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

### 3 Performance of the product and references to the methods used for its assessment

For sampling, conditioning and testing the provisions of the EAD No 040012-00-1201, "Thermal insulation board made of mineral material" apply.

#### 3.1 Mechanical resistance and stability (BWR 1)

Not applicable

#### 3.2 Safety in case of fire (BWR 2)

Essential characteristic	Performance
<b>Reaction to fire:</b> Test acc. to EN ISO 1182:2010 und EN ISO 1716:2010	Class A1 accordance to EN 13501-1: 2007+A1:2009

#### 3.3 Hygiene, health and the environment (BWR 3)

Essential characteristic	Performance
<b>Content and/or release of dangerous substances:</b>	The construction product does not contain or release dangerous substances according to EOTA TR 034 (version October 2014).
<b>Water vapour diffusion resistance coefficient:</b> Test acc. to EN 12086:2013, climate condition A, Conditioning: 23 °C / 50 % rel. humidity to constant mass	
Multipor Mineraldämmplatten 042	$\mu = 2$
Multipor Mineraldämmplatten 045, Multipor Mineraldämmplatten 047	$\mu = 3$

#### 3.4 Safety and accessibility (BWR 4)

Not applicable

### 3.5 Protection against noise (BWR 5)

Essential characteristic	Performance
Sound absorption:	No performance assessed

### 3.6 Energy economy and heat retention (BWR 6)

Essential characteristic	Performance
<b>Thermal conductivity:</b> at a reference temperature of 10 °C Test acc. EN 12667:2001	Declared values for a moisture content of the insulating boards at 23 °C/50 % relative humidity
Multipor Minerale Dämmplatte 042	$\lambda_{D23/50} = 0.040 \text{ W/(m} \cdot \text{K)}^*$
Multipor Minerale Dämmplatte 045	$\lambda_{D23/50} = 0.043 \text{ W/(m} \cdot \text{K)}^*$
Multipor Minerale Dämmplatte 047	$\lambda_{D23/50} = 0.045 \text{ W/(m} \cdot \text{K)}^*$
Conversion of humidity accordance to EN ISO 10456: 2007 + AC:2009	
mass-related moisture content at 23 °C/50 % rel. humidity	$u_{23/50} = 0.028 \text{ kg/kg}$
mass-related moisture content at 23 °C/80 % rel. humidity	$u_{23/80} = 0.032 \text{ kg/kg}$
mass-related moisture conversion coefficient: (dry to 23 °C/50 % rel. humidity)	$f_{u1} = 0.42$
mass-related moisture conversion coefficient: (23 °C/50 % to 23 °C/80 % rel. humidity)	$f_{u2} = 1.98$
Moisture conversion factor (dry to 23 °C/50 % rel. humidity)	$F_{m1} = 1.012$
Moisture conversion factor (23 °C/50 % to 23 °C/80 % rel. humidity)	$F_{m2} = 1.01$
<b>Dimensional deviations (individual values):</b>	maximum deviation:
Length and width: Test acc. EN 822:2013	$\pm 2 \text{ mm}$ Class L(2) and W(2) acc. EN 13163:2012+A2:2016
Thickness: Test acc. EN 823:2013 (with a load of 250 Pa)	$\pm 2 \text{ mm}$
Squareness in direction of length and width: Test acc. EN 824:2013	$S_b \leq 4 \text{ mm/m}$
Flatness: Test acc. EN 825:2013	$S_{\max} \leq 2 \text{ mm}$

\* The declared value is representative for at least 90 % of the production with a confidence level of 90 % and applies to the above-named density range. For the admissible deviation of an individual value of the thermal conductivity from the declared value the method described in EN 13172:2012, Annex F, applies.

<b>Water absorption (individual values):</b> Test acc. EN 1609:2013, Method B Conditioning: 40 °C to constant mass	≤ 2 kg/m <sup>2</sup>
Test acc. EN 12087:2013, Method 1B Conditioning: 40 °C to constant mass	≤ 3 kg/m <sup>2</sup>
<b>Density:</b> Test acc. to EN 1602:2013 Conditioning: 105 °C to constant mass	Density range (each individual value):
Multipor Mineraleämmplatte 042	85 kg/m <sup>3</sup> - 95 kg/m <sup>3</sup>
Multipor Mineraleämmplatte 045, Multipor Mineraleämmplatte 047	100 kg/m <sup>3</sup> - 115 kg/m <sup>3</sup>
<b>Bending strength (individual value):</b> Test acc. to EN 12089:2013, Method B Conditioning: 40 °C to constant mass	
Multipor Mineraleämmplatte 042	No performance assessed
Multipor Mineraleämmplatte 045, Multipor Mineraleämmplatte 047	≥ 80 kPa
<b>Compressive strength :</b> Test acc. to EN 826:2013 Conditioning: 40 °C to constant mass	Mean value of the compressive strength Individual values may fall below these values up to 10 %.
Multipor Mineraleämmplatte 042	≥ 200 kPa
Multipor Mineraleämmplatte 045	≥ 300 kPa
Multipor Mineraleämmplatte 047	≥ 350 kPa
<b>Dimensional stability at specified temperature</b> Test acc. to EN 1604:2013 Conditioning: 48 h, bei (70 ± 2) °C	Relative changes in length, width and thickness: max ± 0.5 %
<b>Dimensional stability at specified temperature and humidity</b> Test acc. to EN 1604:2013 Conditioning: 48 h, (23 ± 2) °C, (90 ± 5) % relative humidity	Relative changes in length, width and thickness: max ± 0.5 %
<b>Tensile strength perpendicular to faces (individual value):</b> Test acc. to EN 1607:2013 Conditioning: 40 °C to constant mass	
Multipor Mineraleämmplatte 042	No performance assessed
Multipor Mineraleämmplatte 045, Multipor Mineraleämmplatte 047	≥ 80 kPa
<b>Point load:</b> Test acc. to EN 12430:2013 Conditioning: 40 °C to constant mass	Deformation under a point load of 1000 N
Multipor Mineraleämmplatte 042	No performance assessed
Multipor Mineraleämmplatte 045, Multipor Mineraleämmplatte 047	≤ 1.0 mm PL(P)1 acc. EN 13167:2012+A1:2015

English translation prepared by DIBt

**3.7 Sustainable use of natural resources (BWR 7)**

For the sustainable use of natural resources no performance was investigated for this product.

**4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base**

According to Decision of the Commission 1999/91/EC as amended by Decision of the Commission 2001/596/EC, the systems of assessment and verification of constancy of performance (see Annex V and Article 65 Paragraph 2 to Regulation (EU) No 305/2011) shall be applied according to the following table:

Product	Intended use	System
Multipor Mineraleämmplatte 042 Multipor Mineraleämmplatte 045 Multipor Mineraleämmplatte 047	All	3

**5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD**

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited at Deutsches Institut für Bautechnik.

Issued in Berlin on 7 June 2018 by Deutsches Institut für Bautechnik

Gunter Hoppe  
Head of Department

*beglaubigt:*  
Stopp