



Approval body for construction products and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and Laender Governments



European Technical Assessment

ETA-10/0232 of 8 February 2018

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the **European Technical Assessment:**

Trade name of the construction product

Product family

to which the construction product belongs

Manufacturer

Manufacturing plant

This European Technical Assessment contains

This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of

This version replaces

Deutsches Institut für Bautechnik

Diessner WDV-System Mineralfaser

Product area code: 4

External Thermal Insulation Composite System with rendering on mineral wool for the use as external insulation of building walls

Diessner GmbH & Co KG Lack- und Farbenfabrik Tempelhofer Weg 38-42

12347 Berlin

Diessner GmbH & Co KG Lack- und Farbenfabrik Tempelhofer Weg 38-42 12347 Berlin

SAKRET GmbH Osterhagener Straße 2 37431 Bad Lauterberg

18 pages including 3 annexes which form an integral part of this assessment

Annex 4 Control Plan contains confidential information and is not included in the European Technical Assessment when that assessment is publicly available

ETAG 004, edition 2000, amended 2013, used as EAD according to Article 66 Paragraph 3 of Regulation (EU) No 305/2011.

ETA-10/0232 issued on 2 November 2012



Page 2 of 18 | 8 February 2018

English translation prepared by DIBt

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.



Page 3 of 18 | 8 February 2018

English translation prepared by DIBt

Specific Part

1 Technical description of the product

1.1 Definition of the kit

This product is an ETICS (External Thermal Insulation Composite System) with rendering - a kit comprising components which are factory-produced by the manufacturer or component suppliers. It's made up on site from these. The ETICS manufacturer is ultimately responsible for all components of the ETICS specified in this ETA.

The ETICS kit comprises a prefabricated insulation product of mineral wool (MW) to be bonded and if it necessary additional mechanically fixed onto a wall. The methods of fixing and the relevant components are specified in the table below.

The insulation product is faced with a rendering system consisting of one base coat and key coat (site applied), in which the base coat contains reinforcement. The rendering is applied directly to the insulating panels, without any air gap or disconnecting layer.

The ETICS may include special fittings (e.g. base profiles, corner profiles ...) for connection to adjacent building elements (apertures, corners, parapets ...). Assessment and performance of these components is not addressed in this ETA, however the ETICS manufacturer is responsible for adequate compatibility and performance within the ETICS when the components are delivered as a part of the kit.

1.2 Composition of the ETICS

	Components National application documents shall be taken into account	Coverage [kg/m²]	Thickness [mm]
Insulation material with associated method of fixing	Bonded ETICS: • Insulation product (see annex 1 for product characteristics) factory-prefabricated mineral wool (MW) product - MW lamella	_	≤ 300
	 Adhesives Diessner Klebe- und Armierungsmörtel KAM (cement based powder requiring addition of about 20 - 25 % of water) 	4.0 - 5.0 (prepared)	-
	 Diessner Systemklebe- und Spachtelmasse SKS (cement based powder requiring addition of about 20 - 25 % of water) 	4.0 – 5.0 (prepared)	-
	 Diessner Baukleber BK (cement based powder requiring addition of about 20 - 25 % of water) 	ca. 4.0 (prepared)	-
	 Diessner Klebe- und Armierungsmörtel leicht KAM-I (cement based powder requiring addition of about 20 - 30 % of water) 	3.0 – 4.0 (prepared)	1
	Mechanically fixed ETICS with anchors and supplementary adhesive:		
	Insulation product (see annex 1 for product characteristics) factory-prefabricated mineral wool (MW) product		
	- MW panel - MW lamella	_ 	60 to 340 60 to 200



Page 4 of 18 | 8 February 2018

English translation prepared by DIBt

	Components National application documents shall be taken into account	Coverage [kg/m²]	Thickness [mm]
Insulation	Supplementary adhesive (equal to bonded ETICS)		
	Anchors for insulation product		
	all anchors with ETA according to EAD330196-00-0604 ¹ with characteristics defined in annex 2		
Base coat	Diessner Klebe- und Armierungsmörtel KAM	6.0 – 10.0	3.5 - 6.0
	Diessner Systemklebe- und Spachtelmasse SKS	6.0 – 10.0	3.5 - 6.0
	Diessner Klebe- und Armierungsmörtel leicht KAM-I	4.5 - 7.0	3.5 - 6.0
	Identical with the equally named adhesive(s) given above.	(prepared)	
Glass fibre	Diessner Armierungsgewebe	_	_
mesh	(see annex 3 for product characteristics)		
	Alkali- and slide-resistant glass fibre mesh with mass per unit area of about 160 g/m² and mesh size of about 4.0 mm x 4.0 mm.		
Key coat	Diessner Putzgrund	ca. 0,15 l/m²	_
	Ready to use pigmented acrylic-resin dispersion liquid		
	To be used with all thin layered finishing coats indicated hereafter.		
Finishing coat	To use with key coat "Diessner Putzgrund" if applicable *:		
	Ready to use paste – acrylic-silicate binder:		
	Diessner Silikatputz		
	 Rillen-Reibeputz (R) (particle size 1.5 – 2 and 3 mm) Kratzputzstruktur (K) (particle size 1.5 – 2 and 3 mm) 	2.5 – 4.5 2.5 – 4.5	
	 Thin layered cement based powders requiring addition of about 25 % of water: 		
	Diessner Modellierputz (particle size 1 and 2 mm)	3.0 – 6.0 (prepared)	
	Diessner Scheibenputz	2.7 - 5.5	regulated by
	(particle size 2 – 3 and 5 mm)	(prepared)	particle size
	Diessner Edelleichtputz		
	- Rillenputzstruktur (R) (particle size 2 and 3 mm)	2.3 – 3.3	
	- Scheibenputz-Struktur (K) (particle size 2 and 3 mm)	1.8 – 2.5	
	Discover Münchner Doung-t-	(prepared)	
	Diessner Münchner Rauputz (particle size 2 – 3 and 5 mm)	2.7 – 6.0 (prepared)	
	Diessner Klebe- und Armierungsmörtel KAM**	2.5 – 3.0	1.5 – 2.5
	Application without key coat:	2.0 - 0.0	1.0 – 2.0
	Thick layered cement based powder requiring addition of about 25% of water:		

EAD330196-00-0604

Plastic anchors for fixing of external thermal insulation composite systems with rendering

Z55606.17



Page 5 of 18 | 8 February 2018

English translation prepared by DIBt

	Components National application documents shall be taken into account	Coverage [kg/m²]	Thickness [mm]
	Diessner Kratzputz KP (particle size 3 mm)	about 22.5 (prepared before scraping) about 14.0 (finished)	15 mm 8 – 12 mm
Ancillary material	Remains the responsibility of the manufacturer.		

- * The instruction to the installer concerning the use of a key coat remains the responsibility of the manufacturer.
- ** The finishing coat "Diessner Klebe- und Armierungsmörtel KAM" has to be used with the equally named base coat exclusively.

2. Specification of the intended use in accordance with the applicable European assessment Document (hereinafter called EAD)

2.1 Intended use

This ETICS is intended to be used as external insulation to the walls of buildings made of masonry (bricks, blocks, stones ...) or concrete (cast on site or as prefabricated panels) with and without rendering. The characteristics of the walls shall be verified prior to use of the ETICS, especially regarding conditions for reaction to fire classification and for fixing of the ETICS either by bonding or mechanically. It shall be designed to give the wall to which it is applied satisfactory thermal insulation.

The ETICS is non load-bearing construction element. It does not contribute directly to the stability of the wall on which it is installed, but it can contribute to durability by providing enhanced protection from the effects of weathering.

The ETICS can be used on new or existing (retrofit) vertical walls.

The ETICS is not intended to ensure the air tightness of the building structure.

The choice of the method of fixing depends on the characteristics of the substrate, which could need preparation (see clause 7.2.1 of ETAG 004) and on the national instructions.

The verifications and assessment methods on which this European Technical Assessment (hereinafter called ETA) is based lead to the assumption of a working life of the ETICS "Diessner WDV-System Mineralfaser" of at least 25 years. The indications given on the working life cannot be interpreted as a guarantee given by the manufacturer, but are to be regarded only as a means for choosing the right products in relation to the assumed economically reasonable working life of the works.

2.2 Manufacturing

The ETA is issued for the ETICS on the basis of agreed data/information, deposited with the DIBt, which identifies the ETICS that has been assessed and judged. Changes to the ETICS or the components or their production process, which could result in this deposited data/information being incorrect, should be notified to the DIBt before the changes are introduced. The DIBt will decide whether such changes affect the approval and consequently the validity of the CE marking on the basis of the approval and if so whether further assessment or alterations to the approval shall be necessary.



Page 6 of 18 | 8 February 2018

English translation prepared by DIBt

2.3 Design and installation

The installation instructions including special installation techniques and provisions for the qualification of the personnel are given in the manufacturer's technical documentation.

Design, installation and execution of ETICS are to be in conformity with national documents. Such documents and the level of their implementation in Member States' legislation are different. Therefore, the assessment and declaration of performance are done taking into account general assumptions introduced in the chapters 7.1 and 7.2 of ETAG 004 used as EAD, which summarize how information introduced in the ETA and related documents is intended to be used in the construction process and gives advice to all parties interested when normative documents are missing.

2.4 Packing, transport and storage

The information on packaging, transport and storage is given in the manufacturer's technical documentation. It is the responsibility of the manufacturer to ensure that this information is made know to the concerned people.

2.5 Use, maintenance, repair

The finishing coat shall normally be maintained in order to fully preserve the ETICS performance. Maintenance includes at least:

- visual inspection of the ETICS
- the repairing of localized damaged areas due to accidents
- the aspect maintenance with products adapted and compatible with the ETICS (possibly after washing or ad hoc preparation)

Only products which are compatible with the ETICS shall be used.

Necessary repairs should be performed as soon as the need has been identified.

The information on use, maintenance and repair is given in the manufacturer's technical documentation.

It is the responsibility of the manufacturer to ensure that this information is made know to the concerned people.

3 Characteristics of products and methods of verification

3.0 General

The performances of the kit as described in this chapter are valid provided that the components of the kit comply with Annexes 1 to 3.

3.1 Mechanical resistance and stability (BWR 1)

not relevant



Page 7 of 18 | 8 February 2018

English translation prepared by DIBt

3.2 Safety in case of fire (BWR 2) Reaction to fire (ETAG 004 - clause 5.1.2)

Configurations	Organic content	Flame retardant content	Euroclass according to EN 13501-1:2007
Base coat	max. 2.8 %	no flame retardant	
Mineral wool insulation product	in quantity ensuring Euroclass E according to EN 13501-1	no flame retardant	
Anchors	-	-	
rendering system : Base coat with finishing coat and 1.2:			
Cement based powders Diessner Modellierputz, Diessner Scheibenputz, Diessner Edelleichtputz. Diessner Münchner Rauputz, Diessner Klebe- und Armierungsmörtel KAM, Diessner Kratzputz KP	max. 2.8 %	no flame retardent	A2 - s1,d0
ready to use pastes Diessner Silikatputz	max. 5.0 %	no flame retardant	A2 – s2,do

3.3 Hygiene, health and environment (BWR 3)

3.3.1 Water absorption (capillarity test) (ETAG 004 - clause 5.1.3.1)

Base coat:

Base coat	Water absorption after 1 h < 1.0 kg/m²	Water absorption after 24 h < 0.5 kg/m ²
Diessner Klebe- und Armierungsmörtel KAM	х	Х
Diessner Systemklebe- und Spachtelmasse SKS	х	Х
Diessner Klebe- und Armierungsmörtel leicht KAM-I	х	Х



Page 8 of 18 | 8 February 2018

English translation prepared by DIBt

Rendering system:

		Water absorption after 24 hours	
		< 0.5 kg/m ²	≥ 0.5 kg/m²
Rendering systems:	Diessner Silikatputz	х	
Base coat with finishing coat and compatible key coat indicated in clause 1.2:	Diessner Modellierputz	х	
	Diessner Scheibenputz	х	
	Diessner Edelleichtputz	х	
	Diessner Münchner Rauputz	х	
	Diessner Klebe- und Armierungsmörtel KAM	х	
	Diessner Kratzputz KP	х	

3.3.2 Hygrothermal behaviour (ETAG 004 - clause 5.1.3.2)

Pass (without defects)

3.3.3 Impact resistance (ETAG 004 – clause 5.1.3.3)

Rendering system:	
Base coat Diessner Klebe- und Armierungsmörtel KAM" oder "Diessner Systemklebe- und Spachtelmasse SKS" with finishing coat indicated in clause 1.2:	Single standard mesh: "Diesser Armierungsgewebe"
Diessner Silikatputz (2 mm)	category I
Diessner Modellierputz (3 mm)	category II
Diessner Scheibenputz (3 mm)	category II
Diessner Edelleichtputz (3 mm)	category II
Diessner Münchner Rauputz (3 mm)	category II
Diessner Kratzputz KP (10 mm)	category II

Rendering system: Base coat "Diessner Klebe- und Armierungsmörtel leicht KAM-I" with finishing coat indicated in clause 1.2:	Single standard mesh: "Diesser Armierungsgewebe"
Diessner Silikatputz (3 mm)	category III
Diessner Modellierputz (3 mm)	category III
Diessner Scheibenputz (3 mm)	category III
Diessner Edelleichtputz (3 mm)	category III
Diessner Münchner Rauputz (3 mm)	category III
Diessner Kratzputz KP (10 mm)	category III

The impact resistance of all other combinations was unproved.



Page 9 of 18 | 8 February 2018

English translation prepared by DIBt

3.3.4 Water vapour permeability (ETAG 004 – clause 5.1.3.4)

Rendering system: Base coat with finishing coat and compatible key coat indicated in clause 1.2:	Equivalent air thickness s _d
Diessner Silikatputz	≤ 1.0 m (Test result obtained with a layer thickness 2 mm: 0.2 m)
Diessner Modellierputz	≤ 1.0 m (Test result obtained with a layer thickness 1 mm: 0.1 m)
Diessner Scheibenputz	≤ 1.0 m (Test result obtained with a layer thickness 3 mm: 0.2 m)
Diessner Edelleichtputz	≤ 1.0 m (Test result obtained with a layer thickness 3 mm: 0.2 m)
Diessner Münchner Rauputz	≤ 1.0 m (Test result obtained with a layer thickness 3 mm: 0.3 m)
Diessner Klebe- und Armierungsmörtel KAM	≤ 1.0 m (Test result obtained with a layer thickness 5 mm: 0.1 m)
Diessner Kratzputz KP	≤ 1.0 m (Test result obtained with a layer thickness 10 mm: 0.3 m)

3.3.5 Release of dangerous substances (ETAG 004 - clause 5.1.3.5, EOTA TR 034)

Essential characteristic	Performance
Release of dangerous substances	no performance assessed

3.4 Safety and accessibility in use (BWR 4)

3.4.1 Bond strength between base coat and insulation product (MW) (ETAG 004 - clause 5.1.4.1.1)

Conditioning				
Initial state		After hygrothermal cycles	After freeze/thaw test	
MW Lamella	MW panel			
≥ 0,08 MPa	< 0,08 MPa but failure in the insulation product	< 0,08 MPa but failure in the insulation product	Test not required because freeze/thaw cycles not necessary	



Page 10 of 18 | 8 February 2018

English translation prepared by DIBt

3.4.2 Bond strength between adhesive and substrate resp. insulation product (MW lamella) (ETAG 004 – clauses 5.1.4.1.2 and 5.1.4.1.3)

		Conditioning			
Adhesive	Substrate resp. insulation product	Initial state	2 d immersion in water and 2 h drying	2 d immersion in water and 7 d drying	
Diagona Walaha	Concrete	≥ 0.25 MPa	≥ 0.08 MPa	≥ 0.25 MPa	
Diessner Klebe- und	MW lamella	≥ 0.08 MPa	≥ 0.03 MPa	≥ 0.08 MPa	
Armierungsmörtel KAM	MW panel	< 0.08 MPa but failure in the insulation product	< 0.03 MPa but failure in the insulation product	< 0.08 MPa but failure in the insulation product	
Diessner	Concrete	≥ 0.25 MPa	≥ 0.08 MPa	≥ 0.25 MPa	
Systemklebe-	MW lamella	≥ 0.08 MPa	≥ 0.03 MPa	≥ 0.08 MPa	
und Spachtelmasse SKS	MW panel	< 0.08 MPa but failure in the insulation product	< 0.03 MPa but failure in the insulation product	< 0.08 MPa but failure in the insulation product	
	Concrete	≥ 0.25 MPa	≥ 0.08 MPa	≥ 0.25 MPa	
Diessner	MW lamella	≥ 0.08 MPa	≥ 0.03 MPa	≥ 0.08 MPa	
Baukleber BK	MW panel	< 0.08 MPa but failure in the insulation product	< 0.03 MPa but failure in the insulation product	< 0.08 MPa but failure in the insulation product	
Diagona Wolaha	Concrete	≥ 0.25 MPa	≥ 0.08 MPa	≥ 0.25 MPa	
Diessner Klebe- und	MW lamella	≥ 0.08 MPa	≥ 0.03 MPa	≥ 0.08 MPa	
Armierungsmörte leicht KAM-I	MW panel	< 0.08 MPa but failure in the insulation product	< 0.03 MPa but failure in the insulation product	< 0.08 MPa but failure in the insulation product	

Bonded surface:

For the adhesives "Diessner Klebe- und Armierungsmörtel KAM", "Diessner Systemklebe- und Spachtelmasse SKS" and "Diessner Baukleber BK" the formula given in clause 6.1.4.1.3 of ETAG 004 is fulfilled with a bonded surface of 50 % and the use as bonded ETICS is possible.

For the adhesive "Diessner Klebe- und Armierungsmörtel leicht KAM-I" the formula given in clause 6.1.4.1.3 of ETAG 004 is fulfilled with a bonded surface of 60 % and the use as bonded ETICS is possible.



Page 11 of 18 | 8 February 2018

English translation prepared by DIBt

3.4.3 Bond strength after ageing (ETAG 004 – clause 5.1.7.1):

	Diessner Silikatputz	
Rendering system: Base coat with finishing coat and compatible key coat indicated in clause 1.2	Diessner Modellierputz	
	Diessner Scheibenputz	
	Diessner Edelleichtputz	≥ 0.08 MPa
	Diessner Münchner Rauputz	
	Diessner Klebe- und Armierungsmörtel KAM	
	Diessner Kratzputz KP	

3.4.4 Fixing strength (displacement test) (ETAG 004 - clause 5.1.4.2)

Test not required therefore no limitation of ETICS length required.

3.4.5 Wind load resistance (ETAG 004 - clause 5.1.4.3)

The following failure loads only apply to the listed combination of component characteristics and the characteristics of the insulation product given in annex 1.

3.4.5.1 Safety in use of mechanically fixed ETICS using anchors

Failure loads - Table 1

Apply to all anchors listed in the clause 1.2 mounted on the insulation panels surface				
Characteristics of the MW panels		Thickness		≥ 60 mm
		Tensile strength perpendicular to the faces		≥ 14 kPa
[N] (Str		chors not placed at the panel joints atic Foam Block Test)	R _{panel}	Mindestwert: 650 Mittelwert: 740
		nchors placed at the panel joints static Foam Block Test)		Mindestwert: 590 Mittelwert: 610
		chors not placed at the panel joints Il-through test, dry conditions)	R _{panel}	Mindestwert: 640 Mittelwert: 690
	(Pu	chors not placed at the panel joints Il-through test, wet conditions) eries 2*	R _{panel}	Mindestwert: 360 Mittelwert: 390 Mindestwert: 410 Mittelwert: 450
* according to ETAG 004 clause 5.2.4.1.2 test method (2)				



Page 12 of 18 | 8 February 2018

English translation prepared by DIBt

Failure loads - Table 2

Apply to all anchors listed in the clause 1.2 mounted on the insulation panels surface					
Characteristics of the MW panels		Thickness		≥ 80 mm	
		Tensile strength perpendicular to the faces		≥ 5.0 kPa	
Plate diameter	Plate diameter of anchor			≥ Ø 90 mm	≥ Ø 140 mm
Failure loads [N]		nchors not placed at the panel joints Static Foam Block Test)		Minimal: 480 Average: 490	Minimal: 56 Average: 69
		Anchors placed at the panel joints (Static Foam Block Test)		Minimal: 380 Average: 390	Minimal: 44 Average: 54
	Anchors not placed at the panel joints (Pull-through test, dry conditions)		R _{panel}	Minimal: 540 Average: 610	npd
	Anchors not placed at the panel joints (Pull-through test, wet conditions) - series 2*		Minimal: 400 Average: 460	npd	
* according to ETAG 004 clause 5.2.4.1.2 test method (2)					

Failure loads - Table 3

Apply to all anchors listed in clause 1.2 mounted on the insulation panels surface					
Characteristics of the MW lamella		Thickness		≥ 60 mm	
		Tensile strength perpendicular to the faces		≥ 80 kPa	
Plate diameter of anchor			≥ Ø 140 mm		
Failure loads [N]	Anchors placed at the panel joints (Pull-through test, dry condition)		R _{joint}	Minimal: 620 Average: 660	
		s placed at the panel joints rough test, wet condition)	R _{joint}	Minimal: 510 Average: 570	
		s placed at the panel joints Foam Block Test)	R _{joint}	Minimal: 710	

The failure loads of table 1 specified above only apply to the following anchors with deep mounting under the given conditions of installation:

Anchor	Thickness of the MW panel [d]	Conditions of installation *	
ejotherm STR U ejotherm STR U 2G (ETA-04/0023)	100 mm > d ≥ 80 mm	 Maximum installation depth of the anchor plate: 15 mm (≜ thickness of insulation cover) Maximum depth of die: 5 mm 	
	≥ 100 mm	 Maximum installation depth of the anchor plate: 15 mm (≜ thickness of insulation cover) Maximum depth of die: 20 mm 	
TERMOZ 8 SV (ETA-06/0180)	≥ 80 mm	 Maximum installation depth of the anchor plate: 15 mm (≜ thickness of insulation cover) 	
* according to the appropriate ETA of anchor			



Page 13 of 18 | 8 February 2018

English translation prepared by DIBt

3.4.6 Render strip tensile test (ETAG 004 - clause 5.5.4.1)

The average value of crack width of the base coat "Diessner Systemklebe- und Spachtelmasse SKS" reinforced with the glass fibre mesh "Diessner Armierungsgewebe" measured at a render strain value of 0.5 % is about 0.08 mm.

The average value of crack width of the base coat coat "Diessner Klebe- und Armierungsmörtel leicht KAM-I" reinforced with the glass fibre mesh "Diessner Armierungsgewebe" measured at a render strain value of 1 % is about 0.11 mm

3.5 Protection against noise (BWR 5)

For the protection against noise no performance was assessed for this product.

3.6 Energy economy and heat retention (BWR 6)

3.6.1 Thermal resistance

The nominal value of the additional thermal resistance R provided by the ETICS to the substrate wall is calculated in accordance with EN ISO 6946:2007 from the nominal value of the insulation product's thermal resistance R_D given accompanied to the CE marking and from the thermal resistance of the rendering system R_{render} which is about 0.02 ($m^2 \cdot K$)/W.

$$R = R_D + R_{render}$$

The thermal bridges caused by mechanical fixing devices increase the thermal transmittance U. This influence had to take into account according to EN ISO 6946: 2007.

 $U_c = U + \Delta U$ corrected thermal transmittance [W/(m²·K)] $\Delta U = \Delta U_{anchor}$ correction term for mechanical fixing devices

 χ_p local influence of thermal bridge caused by an anchor. The values

listed below can be taken into account, if not specified in the

anchor's technical approval

 $\chi_p = 0.004 \text{ W/K}$ for anchors with a galvanized steel screw with the head covered by

a plastic material

 $\chi_p = 0.002 \text{ W/K}$ for anchors with a stainless steel screw with the head covered by

plastic material, and for anchors with an air gap at the head of the

screw



Page 14 of 18 | 8 February 2018

English translation prepared by DIBt

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

According to the European Commission decision 97/556/EC amended by the European Commission decision 2001/596/EC, the assessment and verification of constancy of performance system (AVCP) applies suitable following table (see Annex V to Regulation (EU) No 305/2011).

Product	Intended use	Levels or classes (Reaction to fire)	Systems
"Diessner WDV- System	in external wall subject to fire regulations	A1 ⁽¹⁾ , A2 ⁽¹⁾ , B ⁽¹⁾ , C ⁽¹⁾	1
Mineralfaser"		A1 ⁽²⁾ , A2 ⁽²⁾ , B ⁽²⁾ , C ⁽²⁾ , D, E, (A1 to E) ⁽³⁾ , F	2+
	in external wall not subject to fire regulations	any	2+

⁽¹⁾ Products/materials for which a clearly identifiable stage in the production process results in an improvement of the reaction to fire classification (e.g. an addition of fire retardants or a limiting of organic material)

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable European Assessment Document (EAD)

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited at Deutsches Institut für Bautechnik.

Issued in Berlin on 8 February by Deutsches Institut für Bautechnik

Wolfgang Misch beglaubigt:
p. p. Head of Department Hartstock

⁽²⁾ Products/materials not covered by footnote (1)

⁽³⁾ Products/materials that do not require to be tested for reaction to fire (e.g. products/materials of Classes A1 according to Commission Decision 96/603/EC)



English translation prepared by DIBt

Annexes:

Annex 1: Thermal insulation product characteristic

Annex 2: Anchors

Annex 4: Reinforcement

Page 15 of 18 | 8 February 2018



Page 16 of 18 | 8 February 2018

English translation prepared by DIBt

Annex 1: Thermal insulation product characteristic

Factory-prefabricated panels and lamella made of mineral wool (MW) to EN 13162:2015 with the following designation code and the other properties having the description in the Table below shall be used, provided that the manufacturer and the trade name of the MW are deposited with the DIBt.

MW - EN 13162 - T5 - DS(T+) - WS - WL(P) - MU1

Description and characteristics	MW panel	MW panel	MW lamella
Reaction to fire; EN 13501-1:2007	Class A1		
Gross heat of combustion [MJ/kg]; EN ISO 1716:2010		PCS ≤ 1.02	
Thermal resistance [(m² · K)/W]	Defined in the CE marking in reference to EN 13162:2008		
Tensile strength perpendicular to the faces [kPa]; EN 1607:2013 - in dry conditions*	$\sigma_{mt} \geq 14$	$\sigma_{mt} \geq 5$	$\sigma_{mt} \geq 80$
- in wet conditions** Average value - series 2 - series 3	≥ 33 % of average value in dry conditions ≥ 50 % of average value in dry conditions		
Compressive strength [*] [kPa]; EN 826:2013	$\sigma_m \geq 40$	$\sigma_m \geq 4$	$\sigma_m \geq 40$
Apparent density [kg/m³]; EN 1602:2013	$120 \le \rho_a \le 150$	$100 \le \rho_a \le 150$	$80 \le \rho_a \le 150$
Shear strength [*] [kPa]; EN 12090:2013	$20 \le f_{\tau k} \le 100$	$6 \leq f_{\tau k} \leq 100$	$20 \le f_{\tau k} \le 100$
Shear modulus [MPa]; EN 12090:2013	$1.0 \leq G_m \leq 2.0$	$0.3 \leq G_m \leq 2.0$	$1.0 \leq G_m \leq 2.0$
* Minimal value of all single values ** According to ETAG 004 clause 5.2.4.1.2 test method (2)			



Page 17 of 18 | 8 February 2018

English translation prepared by DIBt

Annex 2: Anchors

All anchors with ETA according to EAD330196-00-0604¹ with characteristics having the description below shall be used in the mechanically fixed ETICS:

- plate diameter of anchor ≥ 60 mm resp. ≥ 90 mm or ≥ 140 mm
- plate stiffness ≥ 0.3 kN/mm
- load resistance of the anchor plate ≥ 1.0 kN

These characteristics and the characteristic tension resistance of the anchors shall be taken from the corresponding ETA.



Page 18 of 18 | 8 February 2018

English translation prepared by DIBt

Annex 3: Reinforcement (glass fibre mesh) Characteristics (alkali resistance): Pass

	Description	Residual strength after ageing [N/mm]	Relative residual strength after ageing, of the strength in the as-delivered state [%]
"Diessner Armierungsge webe"	Alkali- and slide-resistant glass fibre mesh with mass per unit area of about 160 g/m² and mesh size of about 4.0 mm x 4.0 mm	≥ 20	≥ 50