

Approval body for construction products  
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and  
Laender Governments



## European Technical Assessment

ETA-13/0075  
of 6 June 2018

English translation prepared by DIBt - Original version in German language

### General Part

Technical Assessment Body issuing the  
European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

Insulation support - nail KEW TSD-V KN

Product family  
to which the construction product belongs

Nailed-in plastic anchor for fixing of external thermal  
insulation composite systems with rendering in concrete  
and masonry

Manufacturer

Kunststoffzeugnisse GmbH Wilthen  
Dresdener Straße 19  
02681 Wilthen  
DEUTSCHLAND

Manufacturing plant

Kunststoffzeugnisse GmbH Wilthen  
Dresdener Straße 19  
02681 Wilthen  
DEUTSCHLAND

This European Technical Assessment  
contains

13 pages including 3 annexes which form an integral part  
of this assessment

This European Technical Assessment is  
issued in accordance with Regulation (EU)  
No 305/2011, on the basis of

EAD 330196-01-0604

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

## Specific Part

### 1 Technical description of the product

The nailed-in anchor KEW TSD-V KN and KEW TSD-V WS KN consists of an anchor sleeve made of polypropylene (virgin material) and an accompanying specific nail of polyamide, reinforced with glass fibres.

The anchor type KEW TSDV-KN may in addition be combined with the insulation discs DSB 90, DSB 110 or DSB 140.

An illustration and the description of the product are given in Annex A.

### 2 Specification of the intended use in accordance with the applicable European Assessment Document

The performances given in Section 3 are only valid if the anchor is used in compliance with the specifications and conditions given in Annex B.

The verification and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the anchor of at least 25 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

### 3 Performance of the product and references to the methods used for its assessment

#### 3.1 Safety and accessibility in use (BWR 4)

Essential characteristic	Performance
Characteristic tension resistance	See Annex C 1
Edge distances and spacing	See Annex B 2
Plate stiffness	See Annex C 2
Displacements	See Annex C 2

#### 3.2 Energy economy and heat retention (BWR 6)

Essential characteristic	Performance
Point thermal transmittance	See Annex C 2

### 4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with EAD No. 330196-01-00-0604, the applicable European legal act is: [97/463/EC].

The system to be applied is: 2+

**5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD**


Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with Deutsches Institut für Bautechnik.

Issued in Berlin on 6 June 2018 by Deutsches Institut für Bautechnik


BD Dipl.-Ing. Andreas Kummerow  
Head of Department

*beglaubigt:*  
Ziegler

**TSD-V KN**



**TSD-V WS KN**



**Legend**


- $h_{ef}$  = effective anchorage depth
- $h_1$  = depth of drill hole
- $h$  = thickness of base material
- $h_D$  = thickness of insulation material
- $t_{tol}$  = thickness of equalizing layer or non-load bearing coating

**Insulation support KEW TSD-V KN and KEW TSD-V KN WS**

**Product description**  
Intended use

**Annex A 1**


### TSD-V KN



### Marking

Company logo – (KEW)  
Anchor type – (TSD-V KN; )  
diameter – (ø8)  
Length of anchor – (e.g. 160)

### Special nail with special head



**Table A1: Dimensions TSD-V KN**


Anchor type	Anchor sleeve				Special nail		
	L <sub>a</sub> min [mm]	L <sub>a</sub> max [mm]	d <sub>d</sub> [mm]	h <sub>ef</sub> [mm]	d <sub>s</sub> [mm]	c [mm]	l <sub>s</sub> [mm]
KEW TSD-V KN	100	300	8	30	3,9	37	L <sub>a</sub>
Determination of max. Thickness of insulation [mm]: $h_{Dmax} = L_a - h_{ef} - t_{tot}$							
e.g.:	L <sub>a</sub> = 160		h <sub>ef</sub> = 30		t <sub>tot</sub> = 10		
TSD-V 8x160 KN	Thickness of insulation material $h_{Dmax} = 120$						

### Insulation support KEW TSD-V KN and KEW TSD-V KN WS

**Product description**  
Marking and dimensions of the anchor sleeve TSD-V KN  
spreading element / special nail

**Annex A 2**

### TSD-V KN WS



$B \geq 2,5\text{mm}$   
 $D \geq 16\text{mm}$

marking of effective anchorage depth

### Special nail




Table A2: Dimensions TSD-V KN WS

Anchor type	Anchor sleeve				Special nail		
	$L_a$ min [mm]	$L_a$ max [mm]	$d_d$ [mm]	$h_{ef}$ [mm]	$d_s$ [mm]	$c$ [mm]	$l_s$ [mm]
KEW - TSD-V KN WS	50	250	8	30	3,9	37	$L_a$

Insulation support KEW TSD-V KN and KEW TSD-V KN WS

**Product description**

Marking and dimensions of the anchor sleeve TSD-V KN WS  
spreading element / special nail


Annex A 3

**Table A3: Materials**


Member	Material
Anchor sleeve	Polypropylen (virgin material), colour: papyrus white
Special nail	PA GF

**Table A4: Insulation discs, diameters and material**


DSB 90



DSB 110



DSB 140



Insulation discs	Ø D [mm]	Ø d <sub>d</sub> [mm]	d [mm]	Material
<b>DSB 90</b>	90	20	5	PA 6, PP
<b>DSB 110</b>	110	20	5	PA 6, PP
<b>DSB 140</b>	140	20	5	PA 6, PP

**Insulation support KEW TSD-V KN and KEW TSD-V KN WS**

**Product description**  
Materials  
Additional plates in combination with TSD-V KN

**Annex A 4**

## Specifications of intended use

### Anchorage subject to:

- The anchor may only be used for transmission of wind suction loads and shall not be used for the transmission of dead loads of the thermal insulation composite system.

### Base materials:

- Normal weight concrete (use category A) according to Annex C 1.
- Solid masonry (use category B), according to Annex C 1.
- Hollow or perforated masonry (use category C), according to Annex C 1.
- For other base materials of the use categories A, B or C the characteristic resistance of the anchor may be determined by job site tests according to EOTA Technical Report TR 051 edition December 2016.

### Temperature Range:

- 0°C to +40°C (max. short term temperature +40°C and max. long term temperature +24°C)

### Design:

- The anchorages are designed under the responsibility of an engineer experienced in anchorages and masonry work with the partial safety factors  $\gamma_M = 2,0$  and  $\gamma_F = 1,5$ , if there are no other national regulations.
- Verifiable calculation notes and drawings are prepared taking account of the loads to be anchored. The position of the anchor is indicated on the design drawings.
- Fasteners are only to be used for multiple fixings of thermal insulation composite systems.

### Installation:

- Hole drilling by the drill modes according to Annex C 1.
- Anchor installation carried out by appropriately qualified personnel and under the supervision of the person responsible for technical matters of the site.
- Installation temperature from 0°C to +40°C.
- Exposure to UV due to solar radiation of the anchor not protected by rendering  $\leq 6$  weeks.

**Insulation support KEW TSD-V KN and KEW TSD-V KN WS**

**Intended use  
Specifications**


**Annex B 1**

**Table B1: Installation parameters**

Anchor type		KEW TSD-V KN KEW TSD-V KN WS
Drill hole diameter	$d_0 =$ [mm]	8
Cutting diameter of drill bit	$d_{cut} \leq$ [mm]	8,45
Depth of drill hole	$h_1 \geq$ [mm]	40
Effective anchorage depth	$h_{ef} =$ [mm]	30

**Table B2: Minimum distances and dimensions**

		KEW TSD-V KN KEW TSD-V KN WS
Minimum thickness of member	$h \geq$ [mm]	100
Minimum spacing	$s_{min} =$ [mm]	100
Minimum edge distance	$c_{min} =$ [mm]	100




**Insulation support KEW TSD-V KN and KEW TSD-V KN WS**


**Intended use**  
Installation parameters,  
Edge distances and spacing

**Anhang B 2**


## Montageanleitung




Create a hole about observation of the drill method according Annex C 1




Holes to be cleaned of drilling dust.



Insert the anchor into the hole until the plate rests on the insulation.



Hammer in the Nail with a matching hammer




Mounted

**Insulation support KEW TSD-V KN and KEW TSD-V KN WS**

**Intended use**  
Installation instructions

**Anhang B 3**

**Table C1: Characteristic resistance  $N_{Rk}$  in concrete and masonry for a single anchor in kN**

Base material	Bulk density $\rho$ [kg/dm <sup>3</sup> ]	Minimum Compressive strength $f_b$ [N/mm <sup>2</sup> ]	Remarks	Drill method	$N_{Rk}$ [kN]
Concrete C12/15			EN 206-1:2000	Hammer drilling	<b>0,4</b>
Concrete C16/20 – C50/60			EN 206-1:2000	Hammer drilling	<b>0,6</b>
Sand-lime solid bricks, KS e.g. in accordance with EN 771-2:2011	$\geq 1.8$	12	Vertically perforation up to 15%	Hammer drilling	<b>0,6</b>
Clay bricks, Mz e.g. in accordance with EN 771-1:2011	$\geq 1.7$	12	Vertically perforation up to 15%	Hammer drilling	<b>0,6</b>
Vertically perforated clay bricks, HLz e.g. in accordance with EN 771-1:2011	$\geq 1.0$	12	Vertically perforation more than 15% and less than 50% with outer web thickness $\geq 12\text{mm}$	Rotary drilling	<b>0,3</b>
Vertically perforated sand-lime bricks KS L, e.g. in accordance with EN 771-2:2011	$\geq 1.4$	12	Vertically perforation more than 15% with outer web thickness $\geq 22\text{mm}$	Rotary drilling	<b>0,5</b>
Lightweight concrete hollow blocks; Hbl e.g. in accordance with EN 771-3:2011	$\geq 0.8$	2	 with outer web thickness $\geq 50\text{mm}$	Rotary drilling	<b>0,3</b>
Vertically perforated clay bricks; HLz e.g. in accordance with EN 771-1:2011	$\geq 0.9$	12	 with outer web thickness $\geq 10\text{mm}$	Rotary drilling	<b>0,3</b>

**Insulation support KEW TSD-V KN and KEW TSD-V KN WS**

**Performances**  
Characteristic tension resistance of the anchor in concrete and masonry

**Anhang C 1**

**Table C2: Displacements**

Base material	Bulk-density $\rho$ [kg/dm <sup>3</sup> ]	Minimum compressive strength $f_b$ [N/mm <sup>2</sup> ]	Tension load <b>N</b> [kN]	Displacements $\delta_m(N)$ [mm]
Concrete C12/15 (EN 206-1:2000)			0,13	0,02
Concrete C16/20 – C50/60 (EN 206-1:2000)			0,2	0,02
Sand-lime solid bricks, KS (EN 771-2:2011)	≥1.8	12	0,2	0,04
Clay bricks, Mz (EN 771-1:2011)	≥1.7	12	0,2	0,03
Vertically perforated clay bricks, HLz (EN 771-1:2011)	≥1.0	12	0,1	0,04
Vertically perforated sand-lime bricks KS L (EN 771-2:2011)	≥1.4	12	0,17	0,02
Lightweight concrete hollow blocks; Hbl (EN 771-3:2011)	≥0.8	2	0,1	0,02
Vertically perforated clay bricks; HLz (EN 771-1:2011)	≥0.9	12	0,1	0,01

**Table C3: Point thermal transmittance according to EOTA Technical Report TR 025: 2016-05**

Anchor type	Thickness of insulation $h_D$ [mm]	Point thermal transmittance $\chi$ [W/K]
KEW TSD-V KN	60 - 260	0,000

**Table C4: Plate stiffness according to EOTA Technical Report TR 026: 2016-05**

Anchor type	Diameter of anchor plates [mm]	Load resistance of anchor plates [kN]	Plate stiffness [kN/mm]
KEW TSD-V KN	60	1,75	1,24

**Insulation support KEW TSD-V KN and KEW TSD-V KN WS**

**Performances**  
Displacements, point thermal transmittance, plate stiffness

**Anhang C 2**