



Approval body for construction products and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and Laender Governments



European Technical Assessment

ETA-17/0488 of 18 October 2018

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the European Technical Assessment:

Trade name of the construction product

Product family to which the construction product belongs

Manufacturer

Manufacturing plant

This European Technical Assessment contains

This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of

Deutsches Institut für Bautechnik

HALFEN HLX Lift-Box

Elevator lifting device

HALFEN GmbH Liebigstraße 14 40764 Langenfeld DEUTSCHLAND

Plant 1 Plant 2

9 pages including 3 annexes which form an integral part of this assessment

EAD 330075-01-0601



European Technical Assessment ETA-17/0488

Page 2 of 9 | 18 October 2018

English translation prepared by DIBt

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

Z40479.18 8.06.01-533/16



European Technical Assessment ETA-17/0488

Page 3 of 9 | 18 October 2018

English translation prepared by DIBt

Specific part

1 Technical description of the product

The HALFEN HLX Lift-Box is a pre-installed elevator lifting device consisting of an anchor and a wire loop or a chain link located in a plastic housing. The anchor is realised by pressed threaded pipe (T-Fixx) or an internal threaded socket with washer and bolt or a threaded rod with washer and nut.

The elevator lifting device is fully embedded in concrete and anchored by bonding and mechanical interlock.

The product description is given in Annex A.

2 Specification of the intended use in accordance with the applicable European Assessment Document

The performances given in Section 3 are only valid if the HALFEN HLX Lift-Box is used in compliance with the specifications and conditions given in Annex B.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the HALFEN HLX Lift-Box of at least 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and references to the methods used for its assessment

3.1 Safety in case of fire (BWR 2)

Essential characteristic	Performance		
Reaction to fire	Class A1		

3.2 Safety and accessibility in use (BWR 4)

Essential characteristic	Performance	
Load bearing capacity	See Annex C 1	
Minimum edge distances and spacing	See Annex C 1	

Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with EAD No. 330075-01-0601, the applicable European legal act is: [97/161/EC].

The system to be applied is: 2+

Z40479.18 8.06.01-533/16





European Technical Assessment ETA-17/0488

Page 4 of 9 | 18 October 2018

English translation prepared by DIBt

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with Deutsches Institut für Bautechnik.

Issued in Berlin on 18 October 2018 by Deutsches Institut für Bautechnik

BD Dipl.-Ing. Andreas Kummerow Head of Department beglaubigt:


Tempel

Z40479.18 8.06.01-533/16

English translation prepared by DIBt



installed condition






Table 1: product versions

Туре	load step	description	h _{nom}	minimum concrete strength	anchor (1)	box (2)	receiver (3)
[-]	[-]	[-]	[mm]	[MPa]	[-]	[-]	[-]
HLX15 Lo	1,5	HALFEN HLX Lift-Box 1500 loop	133,0	C25/30	T-Fixx	HALFEN LB 2.0	wire loop
HLX20 Lo	2,0	HALFEN HLX Lift-Box 2000 loop	139,5	C25/30	sleeve anchor	HALFEN LB 2.0	wire loop
HLX20 Li	2,0	HALFEN HLX Lift-Box 2000 link	139,0	C25/30	sleeve anchor	HALFEN LB 2.0	chain link
HLX20 Li N	2,0	HALFEN HLX Lift-Box 2000 link	140,5	C25/30	spacer sleeve with nut	HALFEN LB 2.0	chain link
HLX40 Li	4,0	HALFEN HLX Lift-Box 4000 link	209,5	C25/30	sleeve anchor	HALFEN LB 2.0	chain link
HLX40 Li S	4,0	HALFEN HLX Lift-Box 4000 link	189,5	C30/37	sleeve anchor	HALFEN LB 2.0	chain link
HLX40 Li N	4,0	HALFEN HLX Lift-Box 4000 link	218,0	C25/30	spacer sleeve with nut	HALFEN LB 2.0	chain link
HLX40 Li S N	4,0	HALFEN HLX Lift-Box 4000 link	198,0	C30/37	spacer sleeve with nut	HALFEN LB 2.0	chain link

HALFEN HLX Lift-Box	Annex A1
Product description Installed condition, product versions	

Z51882.18 8.06.01-533/16

English translation prepared by DIBt



product versions HLX20 Li HLX40 Li HLX40 Li S HLX20Li N HLX40Li N HLX20 Lo HLX15 Lo HLX40Li SN anchor with steel sleeve anchor with steel sleeve and bolt anchor with T-Fixx continous threa anchor and bolt wire loop wire loop chain link chain link

Table 2a: anchoring in concrete

Туре		box + cover		
[-]	sleeve	bolt / nut	washer	[-]
HLX15 Lo	T-Fixx 20x65	-	-	HALFEN Lift-Box
HLX20 Lo	threaded sleeve 20x55	bolt M20x25 8.8 GV	M20 60x4 GV	HALFEN Lift-Box
HLX20 Li	threaded sleeve 21x58	bolt M16x20 8.8 GV	M16 50x3 GV	HALFEN Lift-Box
HLX20 Li N	spacer sleeve 21x58	nut M16 12.9 GV	M16 50x3 GV	HALFEN Lift-Box
HLX40 Li	threaded sleeve 28x125	bolt M20x30 8.8 GV	M20 60x4 GV	HALFEN Lift-Box
HLX40 Li S	threaded sleeve 28x105	bolt M20x30 8.8 GV	M20 60x4 GV	HALFEN Lift-Box
HLX40 Li N	spacer sleeve 28x125	nut M20 12.9 GV	M20 60x4 GV	HALFEN Lift-Box
HLX40 Li S N	spacer sleeve 28x105	nut M20 12.9 GV	M20 60x4 GV	HALFEN Lift-Box

Table 2b: load transfer by wire loop or chain link

Type	description	receiver		thread
HLX15 Lo	HALFEN HLX Lift-Box 1500 loop	wire loop	Ø10 6x19 WC1770A	pressed tube M20x45
HLX20 Lo	HALFEN HLX Lift-Box 2000 loop	wire loop	Ø10 6x19 WC1770A	pressed tube M20x45
HLX20 Li	HALFEN HLX Lift-Box 2000 link	chain link	Ø11 chain link grade 8	eye bolt M16x75 12.9
HLX20 Li N	HALFEN HLX Lift-Box 2000 link	chain link	Ø11 chain link grade 8	eye bolt M16x121 12.9
HLX40 Li	HALFEN HLX Lift-Box 4000 link	chain link	Ø13 chain link grade 8	eye bolt M20x80 12.9
HLX40 Li S	HALFEN HLX Lift-Box 4000 link	chain link	Ø13 chain link grade 8	eye bolt M20x80 12.9
HLX40 Li N	HALFEN HLX Lift-Box 4000 link	chain link	Ø13 chain link grade 8	eye bolt M20x195 12.9
HLX40 Li S N	HALFEN HLX Lift-Box 4000 link	chain link	Ø13 chain link grade 8	eye bolt M20x175 12.9

HALFEN HLX Lift-Box	Annex A2
Product description Assembled system	

Z51882.18 8.06.01-533/16



Specifications of intended use

Anchorages subject to:

- Cast-in into the roof of an elevator shaft to transfer the load from the elevator car to the concrete slab during the elevator installation.
- Static and quasi-static loads

Base materials

- Reinforced and unreinforced normal concrete without fibres according to EN 206:2013
- Strength class C25/30 to C50/60 according to EN 206:2013
- Cracked or uncracked concrete

Use conditions (environmental conditions)

Anchorages subject to dry internal conditions

Design


- Anchorages are designed under the responsibility of an engineer experienced in the field of anchorages and concrete work.
- Verifiable calculations and design drawings must be prepared taking into account the loads to be anchored

Installation

- Anchor installation carried out by appropriately qualified personnel and under the supervision of the technical site manager.
- Use of the box only as supplied by the manufacturer, without alterations or replacement of components.
- The box is fixed to the formwork in such a way that it cannot move when the reinforcement is laid or when the concrete is placed and compacted.
- Adequate compaction of the concrete around the anchor and especially around the head of the anchor, e.g. without significant voids.

HALFEN HLX Lift-Box	Annex B1
Intended use	

Z51882.18 8.06.01-533/16





installation, edge distances and design values of resistance





Table 3: installation parameter and load bearing capacity values

Туре	load step	h _{nom}	min h	minimum concrete strength	min c ₁ min c ₂	min s	characteristic capacity F _{Rk}	design capacity F _{Rd}
[-]	[-]	[mm]	[mm]	[-]	[mm]	[mm]	[kN]	[kN]
HLX15 Lo	1,5	133,0	150	C25/30	250	500	59,2	14,8
HLX20 Lo	2,0	139,5	150	C25/30	250	500	78,8	19,7
HLX20 Li	2,0	139,0	150	C25/30	250	500	78,8	19,7
HLX20 Li N	2,0	140,5	150	C25/30	250	500	78,8	19,7
HLX40 Li	4,0	209,5	220	C25/30	350	700	157,2	39,3
HLX40 Li S	4,0	189,5	200	C30/37	350	700	157,2	39,3
HLX40 Li N	4,0	218,0	220	C25/30	350	700	157,2	39,3
HLX40 Li S N	4,0	198,0	200	C30/37	350	700	157,2	39,3



HALFEN HLX Lift-Box Annex C1

Product description

Installation parameter and load bearing capacity

Z51882.18