

Approval body for construction products  
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and  
Laender Governments



## European Technical Assessment

**ETA-18/0972**  
**of 10 May 2019**

English translation prepared by DIBt - Original version in German language

### General Part

Technical Assessment Body issuing the  
European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

Injection System Hilti HIT-HY 200 with HAS-D

Product family  
to which the construction product belongs

Bonded fastener for use in concrete

Manufacturer

Hilti Entwicklungsgesellschaft mbH  
Hiltistraße 6  
86916 Kaufering  
DEUTSCHLAND

Manufacturing plant

Hilti Werke

This European Technical Assessment  
contains

21 pages including 3 annexes which form an integral part  
of this assessment

This European Technical Assessment is  
issued in accordance with Regulation (EU)  
No 305/2011, on the basis of

EAD 330499-00-0601

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

## Specific Part

### 1 Technical description of the product

The "Injection System Hilti HIT-HY 200 with HAS-D" is a bonded anchor consisting of a cartridge with injection mortar Hilti HIT-HY 200-A or Hilti HIT-HY 200-R and a steel element Hilti HAS-D with Hilti sealing washer, a calotte nut and a lock nut in the range of M12, M16 and M20. The steel element is placed into a drilled hole filled with injection mortar and is anchored via the bond between metal part, injection mortar and concrete. The product description is given in Annex A.

### 2 Specification of the intended use in accordance with the applicable European Assessment Document

The performances given in Section 3 are only valid if the anchor is used in compliance with the specifications and conditions given in Annex B.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the anchor of at least 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

### 3 Performance of the product and references to the methods used for its assessment

#### 3.1 Mechanical resistance and stability (BWR 1)

Essential characteristic	Performance
Characteristic resistance to static and quasi-static tension load	See Annex C1 and C2
Characteristic resistance to static and quasi-static shear load	See Annex C3
Displacements for static and quasi-static load	See Annex C4
Characteristic resistance for seismic category C1 and C2	No performance assessed

#### 3.2 Hygiene, health and the environment (BWR 3)

Essential characteristic	Performance
Content, emission and/or release of dangerous substances	No performance assessed

English translation prepared by DIBt

**4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base**

In accordance with the European Assessment Document EAD 330499-00-0601 the applicable European legal act is: [96/582/EC].

The system to be applied is: 1

**5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable European Assessment Document**


Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited at Deutsches Institut für Bautechnik.

Issued in Berlin on 10 May 2019 by Deutsches Institut für Bautechnik

BD Dipl.-Ing. Andreas Kummerow  
Head of Department

*beglaubigt:*  
Lange

### Installed condition



Injection system Hilti HIT-HY 200 with HAS-D

Product description  
Installed condition

Annex A1

**Product description: Injection mortar and steel element**

Injection mortar Hilti HIT-HY 200-A and Hilti HIT-HY 200-R: hybrid system with aggregate  
Foil pack 330 ml and 500 ml

Marking:  
HILTI HIT  
Production number and  
production line  
Expiry date mm/yyyy



Product name: "Hilti HIT-HY 200-A"



Product name: "Hilti HIT-HY 200-R"

**Static mixer Hilti HIT-RE-M**




electronic copy of the eta by dibt: eta-18/0972

Injection system Hilti HIT-HY 200 with HAS-D


**Product description**  
Injection mortar / Static mixer

**Annex A2**

**Steel element: Hilti HAS-D: M12, M16 and M20 with sealing washer**



**Marking:**  
HAS-D M..x L Bonded expansion anchor type as well as bonded expansion anchor size and length



**Table A1: Letter code for identification of fastener length<sup>1)</sup>**

Letter code		I	J	K	L	M	N	O	P	Q	R
Fastener length l	≥ [mm]	139,7	<b>152,4</b>	165,1	<b>177,8</b>	<b>190,5</b>	203,2	<b>215,9</b>	228,6	241,3	254,0
	< [mm]	152,4	<b>165,1</b>	177,8	<b>190,5</b>	<b>203,2</b>	215,9	<b>228,6</b>	241,3	254,0	279,4

Letter code		S	T	U	V	W	X	Y	Z	>Z
Fastener length l	≥ [mm]	<b>279,4</b>	304,8	330,2	355,6	381,0	406,4	431,8	457,2	482,6
	< [mm]	<b>304,8</b>	330,2	355,6	381,0	406,4	431,8	457,2	482,6	

<sup>1)</sup> Fastener length in bold is standard item. For selection of other fastener lengths, check availability of the items.

**Table A2: Dimensions**

HAS-D...			M12	M16	M20
Shaft diameter	d <sub>k</sub>	[mm]	12,5	16,5	22,0
Fastener length l	≥	[mm]	143	180	242
	≤	[mm]	531	565	623
Calotte nut	SW	[mm]	18/19	24	30
Lock nut	SW	[mm]	19	24	30

Injection system Hilti HIT-HY 200 with HAS-D

Product description  
Steel element

**Annex A3**

Hilti sealing washer to fill the annular gap between anchor and fixture




Table A3: Geometry of Hilti sealing washer

Size	M12	M16	M20
Diameter of sealing washer $d_{vs}$ [mm]	44	52	60
Thickness of sealing washer $h_{vs}$ [mm]	5	6	

Injection system Hilti HIT-HY 200 with HAS-D

Product description  
Steel element

Annex A4

**Table A4: Materials**

<b>Designation</b>	<b>Material</b>
Fastener HAS-D	Steel acc. to EN 10087:1998, galvanized and coated
Sealing washer	Steel, electroplated zinc coated $\geq 5 \mu\text{m}$
Calotte nut	Steel, electroplated zinc coated $\geq 5 \mu\text{m}$
Lock nut	Steel, electroplated zinc coated $\geq 5 \mu\text{m}$

Injection system Hilti HIT-HY 200 with HAS-D

**Product description**  
Materials

**Annex A5**

## Specifications of intended use

### Anchorage subject to:

- Static and quasi static loading.

### Base material:

- Compacted reinforced or unreinforced normal weight concrete without fibres according to EN 206:2013 + A1:2016.
- Strength classes C20/25 to C50/60 according to EN 206:2013 + A1:2016.
- Cracked and uncracked concrete.

### Temperature in the base material:

- **at installation**  
0 °C to +40 °C
- **in-service**  
Temperature range: -40 °C to +80 °C  
(max. long term temperature +50 °C and max. short term temperature +80 °C)

### Use conditions (Environmental conditions):

- Structures subject to dry internal conditions.

### Design:

- Anchorages are designed under the responsibility of an engineer experienced in anchorages and concrete work.
- Verifiable calculation notes and drawings are prepared taking account of the loads to be anchored. The position of the anchor is indicated on the design drawings (e. g. position of the anchor relative to reinforcement or to supports, etc.).
- Anchorages under static or quasi-static loading are designed in accordance with: EN 1992-4:2018 and EOTA Technical Report TR 055.

### Installation:

- Concrete condition I1: dry or wet concrete (not in flooded holes).
- Drilling technique: hammer drilling, hammer drilling with hollow drill bit TE-CD, TE-YD or diamond coring.
- Installation direction D3: downward, horizontal and upwards (e.g. overhead) installation.
- Anchor installation carried out by appropriately qualified personnel and under the supervision of the person responsible for technical matters of the site.

Injection system Hilti HIT-HY 200 with HAS-D

Intended Use  
Specifications

Annex B1

**Table B1: Installation parameters**

HAS-D...		M12	M16	M20
Diameter of fastener	$d = d_{nom}$ [mm]	12	16	20
Nominal diameter of drill bit	$d_0$ [mm]	14	18	24
Effective embedment depth	$h_{ef}$ [mm]	100	125	170
Minimum drill hole depth	$h_0$ [mm]	105	133	180
Minimum thickness of concrete member	$h_{min}$ [mm]	130	160 <sup>1)</sup> / 170	220 <sup>1)</sup> / 230
<u>Pre-setting:</u>				
Maximum diameter of clearance hole in the fixture	$d_f$ [mm]	14	18	24
<u>Through-setting:</u>				
Maximum diameter of clearance hole in the fixture	$d_f$ [mm]	16	20	26
Installation torque moment	$T_{inst}$ [Nm]	30	50	80
Uncracked concrete	Minimum spacing	$s_{min,ucr}$ [mm]	80 <sup>2)</sup>	60
	Minimum edge distance	$c_{min,ucr}$ [mm]	55 <sup>2)</sup>	60
Cracked concrete	Minimum spacing	$s_{min,cr}$ [mm]	50	60
	Minimum edge distance	$c_{min,cr}$ [mm]	50	60

1) The reverse side of the concrete member shall have no break-through after drilling.

2) for min. edge distance  $c_{min} \geq 80$  mm, min. spacing  $s_{min} = 55$  mm

Injection system Hilti HIT-HY 200 with HAS-D

**Intended Use**  
Installation parameters

**Annex B2**

**Table B2: Maximum working time and minimum curing time HIT-HY 200-A**

Temperature in the base material T	Maximum working time $t_{work}$	Minimum curing time $t_{cure}$
$\geq 0\text{ °C}$ to $5\text{ °C}$	25 min	2 h
$> 5\text{ °C}$ to $10\text{ °C}$	15 min	75 min
$> 10\text{ °C}$ to $20\text{ °C}$	7 min	45 min
$> 20\text{ °C}$ to $30\text{ °C}$	4 min	30 min
$> 30\text{ °C}$ to $40\text{ °C}$	3 min	30 min

**Table B3: Maximum working time and minimum curing time HIT-HY 200-R**

Temperature in the base material T	Maximum working time $t_{work}$	Minimum curing time $t_{cure}$
$\geq 0\text{ °C}$ to $5\text{ °C}$	1 h	4 h
$> 5\text{ °C}$ to $10\text{ °C}$	40 min	2,5 h
$> 10\text{ °C}$ to $20\text{ °C}$	15 min	1,5 h
$> 20\text{ °C}$ to $30\text{ °C}$	9 min	1 h
$> 30\text{ °C}$ to $40\text{ °C}$	6 min	1 h

**Injection system Hilti HIT-HY 200 with HAS-D**

**Intended Use**  
Maximum working time and minimum curing time

**Annex B3**

**Table B4: Parameters of drilling, cleaning and setting tools**

Steel element	Drill and clean				Installation
	Hammer drilling		Diamond coring	Brush	
HAS-D		Hollow drill bit TE-CD, TE-YD			
					
Size	d <sub>0</sub> [mm]	d <sub>0</sub> [mm]	d <sub>0</sub> [mm]	HIT-RB	HIT-SZ
M12	14	14	14	14	14
M16	18	18	18	18	18
M20	24	24	24	24	24

**Table B5: Cleaning alternatives**

<p><b>Compressed Air Cleaning (CAC):</b> Air nozzle with an orifice opening of minimum 3,5 mm in diameter.</p>	
<p><b>Automatic Cleaning (AC):</b> Cleaning is performed during drilling with Hilti TE-CD and TE-YD drilling system including vacuum cleaner.</p>	

Injection system Hilti HIT-HY 200 with HAS-D


**Intended Use**  
Drilling, cleaning and setting tools

**Annex B4**

## Installation instruction

### Hole drilling


#### a) Hammer drilling



**Through-setting:** Drill hole through the clearance hole in the fixture to the required drilling depth with a hammer drill set in rotation-hammer mode using an appropriately sized carbide drill bit.

**Pre-setting:** Drill hole to the required drilling depth with a hammer drill set in rotation-hammer mode using an appropriately sized carbide drill bit.  
After drilling is complete, proceed to the "injection preparation" step in the installation instruction.


#### b) Hammer drilling with Hilti hollow drill bit (AC)



**Pre- / Through-setting:** Drill hole to the required embedment depth with an appropriately sized Hilti TE-CD or TE-YD hollow drill bit with Hilti vacuum attachment. This drilling system removes the dust and cleans the drill hole during drilling when used in accordance with the user's manual.

After drilling is completed, proceed to the "injection preparation" step in the installation instruction.

#### c) Diamond coring




Diamond coring is permissible when suitable diamond core drilling machines and corresponding core bits are used.

**Through-setting:** Drill hole through the clearance hole in the fixture to the required drilling depth.


**Pre-setting:** Drill hole to the required embedment depth.

**Drill hole cleaning:** just before setting an anchor, the drill hole must be free of dust and debris.

#### a) Compressed Air Cleaning (CAC): for all drill hole diameters $d_0$ and all drill hole depths $h_0$ .




Blow 2 times from the back of the hole (if needed with nozzle extension) over the whole length with oil-free compressed air (min. 6 bar at 6 m<sup>3</sup>/h) until return air stream is free of noticeable dust.



Brush 2 times with the specified brush (see Table B4) by inserting the steel brush Hilti HIT-RB to the back of the hole (if needed with extension) in a twisting motion and removing it.

The brush must produce natural resistance as it enters the drill hole (brush  $\varnothing \geq$  drill hole  $\varnothing$ ) - if not the brush is too small and must be replaced with the proper brush diameter.




Blow again with compressed air 2 times until return air stream is free of noticeable dust.

Injection system Hilti HIT-HY 200 with HAS-D


Intended use  
Installation instructions

Annex B5

**b) Cleaning of diamond cored holes:** for all drill hole diameters  $d_0$  and all drill hole depths  $h_0$ .




Flush 2 times by inserting a water hose (water-line pressure) to the back of the hole until water runs clear.




Blow 2 times from the back of the hole (if needed with nozzle extension) with oil-free compressed air (min. 6 bar at 6 m³/h) until return air stream is free of noticeable dust and water.

**Injection preparation**




Tightly attach Hilti mixing nozzle HIT-RE-M to foil pack manifold. Do not modify the mixing nozzle.  
Observe the instruction for use of the dispenser.  
Check foil pack holder for proper function. Insert foil pack into foil pack holder and put holder into dispenser.




The foil pack opens automatically as dispensing is initiated. Depending on the size of the foil pack an initial amount of adhesive must be discarded. Discarded quantities are:

2 strokes	for 330 ml foil pack,
3 strokes	for 500 ml foil pack
4 strokes	for 500 ml foil pack ≤ 5°C.

**Inject adhesive** from the back of the drill hole without forming air voids.




Inject the adhesive starting at the back of the hole, slowly withdrawing the mixer with each trigger pull.



Pre-setting: Fill approximately 2/3 of the drill hole.

Through-setting: Fill 100% of the drill hole.




After injection is completed, depressurize the dispenser by pressing the release trigger. This will prevent further adhesive discharge from the mixer.

Injection system Hilti HIT-HY 200 with HAS-D


Intended use  
Installation instructions

Annex B6




For overhead installation, the injection is only possible with the aid of extensions and piston plugs. Assemble HIT-RE-M mixer, extension(s) and appropriately sized piston plug (see Table B4). Insert piston plug to back of the hole and inject adhesive. During injection, the piston plug will be naturally extruded out of the drill hole by the adhesive pressure.


### Setting the element



Before use, verify that the element is dry and free of oil and other contaminants. Set element to the required embedment depth before working time  $t_{work}$  (see Table B2 and B3) has elapsed. After setting the element the annular gap between the anchor and the fixture (through-setting) or concrete (pre-setting) has to be filled with mortar.




For overhead installation fix embedded parts with e.g. wedges.




After required curing time  $t_{cure}$  (see Table B2 and B3) remove excess mortar.


### Setting the element with clearance between concrete and anchor plate (only if the fastener is loaded in axial direction)



Set element to the required embedment depth before working time  $t_{work}$  (see Table B2 and B3) has elapsed.



Check if mortar excess from the borehole. The annular gap in the fixture does not have to be filled.




After required curing time  $t_{cure}$  (see Table B2 and B3) backfill the anchor plate.

Injection system Hilti HIT-HY 200 with HAS-D


Intended use  
Installation instructions

Annex B7


**Final assembly with sealing washer**




Orient round part of the calotte nut to the sealing washer and install.



The required installation torque moment is given in Table B1.



Apply the lock nut and tighten with a  $\frac{1}{4}$  to  $\frac{1}{2}$  turn.



Pre-setting: Fill the annular gap between the anchor rod and fixture with 1-3 strokes of Hilti injection mortar HIT-HY 200. The static mixer nozzle must be put orthogonally on the filling hole.  
Follow the installation instructions supplied with the HIT-HY 200 foil pack.  
After required curing time  $t_{cure}$  (see Table B2 and B3), the anchor can be loaded.

**Injection system Hilti HIT-HY 200 with HAS-D**

**Intended use**  
Installation instructions

**Annex B8**

**Table C1: Essential characteristics under tension load in concrete**

HAS-D...			M12	M16	M20		
Effective embedment depth	$h_{ef}$	[mm]	100	125	170		
Installation sensitivity factor	$\gamma_{inst}$	[-]	1,0				
<b>Steel failure</b>							
Characteristic resistance	$N_{Rk,s}$	[kN]	57	111	188		
Partial factor	$\gamma_{Ms,N}^{1)}$	[-]	1,5				
<b>Pull-out failure</b>							
Characteristic bond resistance in uncracked concrete C20/25							
Temperature range: 80 °C / 50 °C	$N_{Rk,p,ucr}$	[kN]	49,2	68,8	109		
Characteristic resistance in cracked concrete C20/25							
Temperature range: 80 °C / 50 °C	$N_{Rk,p,cr}$	[kN]	34,4	48,1	76,3		
Increasing factor for $N_{Rk,p}$ in concrete	$\psi/c$	C30/37	1,22				
		C40/50	1,41				
		C50/60	1,58				
<b>Concrete cone failure</b>							
Factor for uncracked concrete	$k_1 = k_{ucr,N}$	[-]	11,0				
Factor for cracked concrete	$k_1 = k_{cr,N}$	[-]	7,7				
Edge distance	$c_{cr,N}$	[mm]	$1,5 \cdot h_{ef}$				
Spacing	$s_{cr,N}$	[mm]	$3,0 \cdot h_{ef}$				
<b>Splitting failure for standard thickness of concrete member</b> (higher resistance of case 1 and case 2 may be applied)							
Standard thickness of concrete member			$h$	[mm]	200	250	340
Case 1	Characteristic resistance in concrete C20/25		$N_{Rk,sp}^0$	[kN]	40	50	109
	Edge distance		$c_{cr,sp}$	[mm]	$1,5 \cdot h_{ef}$		
	Spacing		$s_{cr,sp}$	[mm]	$2 \cdot c_{cr,sp}$		
Case 2	Edge distance		$c_{cr,sp}$	[mm]	$2,0 \cdot h_{ef}$	$2,0 \cdot h_{ef}$	$1,5 \cdot h_{ef}$
	Spacing		$s_{cr,sp}$	[mm]	$2 \cdot c_{cr,sp}$		

Injection system Hilti HIT-HY 200 with HAS-D

**Performances**  
Essential characteristics under tension load in concrete

**Annex C1**

**Table C1 continued**

<b>Splitting failure for minimum thickness of concrete member</b> (higher resistance of case 1 and case 2 may be applied)						
Minimum thickness of concrete member		$h_{min}$	[mm]	130	160	220
Case 1	Characteristic resistance in concrete C20/25	$N^0_{Rk,sp}$	[kN]	30	40	75
	Edge distance	$c_{cr,sp}$	[mm]	$1,5 \cdot h_{ef}$		
	Spacing	$s_{cr,sp}$	[mm]	$2 \cdot c_{cr,sp}$		
Case 2	Edge distance	$c_{cr,sp}$	[mm]	$3,0 \cdot h_{ef}$		$2,6 \cdot h_{ef}$
	Spacing	$s_{cr,sp}$	[mm]	$2 \cdot c_{cr,sp}$		

1) In absence of national regulations.

**Injection system Hilti HIT-HY 200 with HAS-D**

**Performances**  
Essential characteristics under tension load in concrete

**Annex C2**

**Table C2: Essential characteristics under shear load in concrete**

HAS-D...			M12	M16	M20
Installation sensitivity factor	$\gamma_{inst}$	[-]	1,0		
<b>Steel failure without lever arm</b>					
Characteristic resistance	$V_{Rk,s}$	[kN]	34	63	149
Partial factor	$\gamma_{Ms,V}$	<sup>1)</sup> [-]	1,25		
Ductility factor	$k_2$		1,0		
<b>Steel failure with lever arm</b>					
Characteristic resistance	$M^0_{Rk,s}$	[Nm]	105	266	519
Partial factor	$\gamma_{Ms,V}$	<sup>1)</sup> [-]	1,25		
<b>Concrete pry-out failure</b>					
Pry-out factor	$k_8$	[-]	2,0		
<b>Concrete edge failure</b>					
Effective length of fastener	$l_f$	[mm]	100	125	170
Effective outside diameter of fastener	$d_{nom}$	[mm]	14	18	24
Partial factor	$\gamma_{Mc}$	<sup>1)</sup> [-]	1,5		

<sup>1)</sup> In absence of national regulations.

Injection system Hilti HIT-HY 200 with HAS-D

**Performances**  
Essential characteristics under shear load in concrete

**Annex C3**

**Table C3: Displacements under tension load in concrete**

HAS-D...		M12	M16	M20	
<b>Uncracked concrete</b>					
Displacement	$\delta_{N0}$ -Factor	[mm/kN]	0,017	0,018	0,011
Displacement	$\delta_{N\infty}$ -Factor	[mm/kN]	0,054	0,039	0,024
<b>Cracked concrete</b>					
Displacement	$\delta_{N0}$ -Factor	[mm/kN]	0,035	0,029	0,021
Displacement	$\delta_{N\infty}$ -Factor	[mm/kN]	0,076	0,054	0,034

1) Calculation of the displacement:

$$\delta_{N0} = \delta_{N0}\text{-Faktor} \cdot N; \quad \delta_{N\infty} = \delta_{N\infty}\text{-Faktor} \cdot N; \quad (N: \text{applied tension force}).$$

**Table C4: Displacements under shear load in concrete**

HAS-D...		M12	M16	M20	
Displacement	$\delta_{V0}$ -Factor	[mm/kN]	0,17	0,11	0,057
Displacement	$\delta_{V\infty}$ -Factor	[mm/kN]	0,26	0,16	0,087

1) Calculation of the displacement:

$$\delta_{V0} = \delta_{V0}\text{-factor} \cdot V; \quad \delta_{V\infty} = \delta_{V\infty}\text{-factor} \cdot V; \quad (V: \text{applied shear force}).$$

**Injection system Hilti HIT-HY 200 with HAS-D**

**Performances**  
Displacements under tension and shear load in concrete

**Annex C4**