

Approval body for construction products
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and
Laender Governments



European Technical Assessment

ETA-19/0199
of 29 November 2019

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the
European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

PURATHERM, PURATHERM E 30

Product family
to which the construction product belongs

thermal insulation board made of pressed rigid
polyurethane foam

Manufacturer

ISO-Chemie GmbH
Röntgenstraße 12
73431 Aalen
DEUTSCHLAND

Manufacturing plant

Plant 1

This European Technical Assessment
contains

6 pages which form an integral part of this assessment

This European Technical Assessment is
issued in accordance with Regulation (EU)
No 305/2011, on the basis of

EAD 040419-00-1201

This version replaces

ETA-19/0199 issued on 3 April 2019

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

Specific part

1 Technical description of the product

This European Technical Assessment applies to the thermal insulation board made of pressed rigid polyurethane foam with smooth, rigid surfaces and without additional coating, designated as "PURATHERM" and "PURATHERM E 30" hereinafter referred to as thermal insulation board.

The polyurethane (PU) rigid foam is made of ground PU residual materials (milling and cutting waste) generated during production and free from impurities.

Residual materials resulting from the production of PU foam blocks and strips laminated with a mineral fleece or aluminium are used for the thermal insulation boards.

The European Technical Assessment has been issued for the products on the basis of agreed data/ information, deposited with Deutsches Institut für Bautechnik, which identifies the product that has been assessed. The European Technical Assessment applies only to products corresponding to this agreed data/information.

2 Specification of the intended use in accordance with the applicable European Assessment Document

The thermal insulation board is intended for use in buildings as follows:

- internal insulation of walls
- internal insulation of ceilings
- internal insulation of roofs

The performance according to section 3 only applies if the thermal insulation board is installed according to the manufacture's installation instructions and if they are protected from precipitation, wetting or weathering in built-in state and during transport, storage and installation.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the thermal insulation boards of at least 25 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and references to the methods used for its assessment

For sampling, conditioning and testing the provisions of the EAD No 040419-00-1201 "Thermal insulation board made of pressed rigid polyurethane foam" apply.

3.1 Mechanical resistance and stability (BWR 1)

Not applicable

English translation prepared by DIBt

3.2 Safety in case of fire (BWR 2)

Essential characteristic	Performance
Reaction to fire test acc. to EN ISO 11925-2:2011	Class E ^{a)} acc. to EN 13501-1:2007 + A1:2009
a) The given classification is valid on substrates class A1 or A2-s1, d0 acc. to EN 13501-1, density $\geq 600 \text{ kg/m}^3$ and thickness $\geq 12 \text{ mm}$, fixed mechanically and with adhesive.	

3.3 Hygiene, health and the environment (BWR 3)

Not applicable

3.4 Safety and accessibility in use (BWR 4)

Not applicable

3.5 Protection against noise (BWR 5)

Not applicable

3.6 Energy economy and heat retention (BWR 6)

Essential characteristic	Performance
Thermal conductivity test acc. to EN 12667:2001	Declared value of the thermal conductivity ^{a)}
20 mm < d ≤ 40 mm	$\lambda_{D(23/50)} = 0.083 \text{ W/(m}\cdot\text{K)}$
40 mm < d ≤ 60 mm	$\lambda_{D(23/50)} = 0.085 \text{ W/(m}\cdot\text{K)}$
60 mm < d ≤ 80 mm	$\lambda_{D(23/50)} = 0.088 \text{ W/(m}\cdot\text{K)}$
Conversion of humidity acc. to EN ISO 10456:2007 + AC:2009 mass-related moisture content at 23 °C/50 % rel. humidity	$u_{23/50} = 0.017$
mass-related moisture content at 23 °C/80 % rel. humidity	$u_{23/80} = 0.028$
mass-related moisture conversion coefficient	$f_u = 2.86$
moisture conversion factor (23 °C/ 50 % rel. humidity to 23 °C/ 80 % rel. humidity)	$F_{m(23/50-23/80)} = 1.03$
Compressive strength test acc. to EN 826:2013	$\geq 7100 \text{ kPa}$
Water absorption test acc. to EN 1609:2013 (by short term, partial immersion)	$W_p \leq 0.5 \text{ kg/m}^2$
Hygroscopic sorption properties test acc. to EN ISO 12571:2013 moisture absorption (desorption) at 23 °C/80 % rel. humidity	$u \leq 3.0 \text{ Mass-\%}$

Essential characteristic	Performance
Water vapour diffusion resistance coefficient	$\mu = 8$
Dimensional stability	No performance assessed
Tensile strength perpendicular to faces	No performance assessed
Density test acc. to EN 1602:2013	510 kg/m ³ to 590 kg/m ³
Nominal thickness test acc. to EN 823:2013 Deviation	20 mm to 80 mm ± 1 mm
Nominal length test acc. to EN 822:2013 Deviation	≤ 6000 mm ± 8 mm
Nominal width test acc. to EN 822:2013 Deviation	≤ 1350 mm ± 5 mm
Squareness test acc. to EN 824:2013 Deviation	$S_b \leq 2$ mm/m
Flatness test acc. to EN 825:2013 Deviation	≤ 2 mm
Bending strength	No performance assessed
Shear strength	No performance assessed
Deformation under specified compressive load and temperature conditions	No performance assessed
Compressive creep	No performance assessed
Flatness after one-sided wetting	No performance assessed
Water absorption (by long term immersion)	No performance assessed
a) Declared value of the thermal conductivity for a moisture content of the insulation material at 23 °C and 50 % relative humidity, representative for at least 90 % of the production with a confidence level of 90 %.	

3.7 Sustainable use of natural resources (BWR 7)

For the sustainable use of natural resources no performance was investigated for this product.

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with the European Assessment Document EAD No. 040419-00-1201 "Thermal insulation board made of pressed rigid polyurethane foam" the applicable European legal act is: 1999/91/EC.

The system to be applied is: 3

English translation prepared by DIBt

In addition, with regard to reaction to fire the applicable European legal act is: 2001/596/EC for products covered by this European Assessment Document.

The system to be applied is: System 1, 3 or 4

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with Deutsches Institut für Bautechnik.

Issued in Berlin 29 November 2019 by Deutsches Institut für Bautechnik

Maja Tiemann
Head of Department

beglaubigt:
Getzlaff