

Approval body for construction products
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and
Laender Governments



European Technical Assessment

ETA-19/0467
of 11 October 2019

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the
European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

BMI Sealoflex Protecta

Product family
to which the construction product belongs

Liquid applied roof waterproofing on the basis of water
dispersible polymers

Manufacturer

BMI Group Management UK Limited
20 Air Street, 5th Floor
LONDON W1B 5AN
GROSSBRITANNIEN

Manufacturing plant

Produktionsanlage 205

This European Technical Assessment
contains

7 pages including 2 annexes which form an integral part
of this assessment

This European Technical Assessment is
issued in accordance with Regulation (EU)
No 305/2011, on the basis of

ETAG 005 Part 6: "Specific stipulations for kits based on
polyurethane",
used as EAD according to Article 66 Paragraph 3 of
Regulation (EU) No 305/2011.

European Technical Assessment

ETA-19/0467

English translation prepared by DIBt

Page 2 of 7 | 11 October 2019

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

Specific part

1 Technical description of the product

The liquid applied roof waterproofing "BMI Sealoflex Protecta" is a kit, which consists of the components:

- Primer "Sealoflex Protecta Primer", depending on the type of substrate
- liquid applied roof waterproofing "Sealoflex Protecta Waterproof Coating" on the basis of a water dispersible acrylic solution
- polyester fleece as reinforcement
- top coat "Sealoflex Protecta Top Coat"

For an adequate adhesion of the waterproofing layer – depending on the type of substrate – a primer is required. In general the primer belonging to the substrate is given in the manufacturer technical documents¹. In single cases the manufacturer is responsible to give guidance which pretreatment/primer is required.

The minimum layer thickness of the roof waterproofing applied is 2.0 mm.

As an assembled system these components form a homogeneous seamless roof waterproofing. The components and the system build-up of the roof waterproofing "BMI Sealoflex Protecta" are given in Annex A.

2 Specification of the intended use in accordance with the applicable EAD

The product is used for the waterproofing of roof surfaces against penetration of atmospheric water.

In the technical file the manufacturer give information concerning the substrates which the product is suitable for and on how these substrates shall be pre-treated.

The levels of use categories are given in Annex A.

The verification and assessment methods on which this European Technical Assessment is based lead to the assumption of working life of the product of 25 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

The levels of use categories and performances given in Section 3 are only valid if the liquid applied roof waterproofing is used in compliance with the specifications and conditions given in Annex B and the installation instructions of the manufacturer stated in the technical file.

¹ The manufacturer's technical documents comprises all information necessary for the production and the installation of the product as well as for repair of the roof waterproofing made from that and it is deposited with DIBt.

3 Performance of the product and references to the methods used for its assessment

3.1 Safety in case of fire (BWR 2)

Essential characteristic	Performance
External fire performance	See Annex A
Reaction to fire	See Annex A

3.2 Hygiene, health and the environment (BWR 3)

Essential characteristic	Performance
Water vapour permeability	See Annex A
Watertightness	See Annex A
Release of dangerous substances	The product does not contain dangerous substances specified in TR 034, except: - a biocide according to Commission Directive 98/8/EC and the BPR - (EU) No. 528/2012 of the European Parliament and of the Council
Resistance to mechanical damage (perforation)	See Annex A, Levels of use categories
Resistance to plant roofs	See Annex A

3.3 Safety and accessibility in use (BWR 4)

Essential characteristic	Performance
Resistance to wind loads	See Annex A
Slipperiness	See Annex A

3.4 General aspects

The verification of durability and serviceability is part of testing the essential characteristics. Durability and serviceability is only ensured if the specifications of intended use according to Annex B and the specifications of the technical file of the manufacturer are kept.

4 Assessment and verification of constancy of performance (AVCP) system applied with reference to its legal base

In accordance with ETAG 005 used as EAD, the applicable European legal act is: 98/599/EC

The system to be applied is: 3

In addition, with regard to e.g. reaction to fire for products covered by this ETAG the applicable European legal act is: 2001/596/EC

The system to be applied is: 3


5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with Deutsches Institut für Bautechnik.

Issued in Berlin on 11 October 2019 by Deutsches Institut für Bautechnik

Dr.-Ing. Lars Eckfeldt
p. p. Head of Department

beglaubigt:
Gnamou



Components:

- 1 Primer (if necessary)
- 2 Waterproofing: liquid synthetic material "Sealoflex Protecta Waterproof Coating"
- 3 Polyester fleece
- 4 Top coat: liquid synthetic material "Sealoflex Protecta Top Coat"

Applicable to the roof waterproofing "BMI Sealoflex Protecta"

Polyester fleece with at least a weight of		140 g/m²
Minimum layer thickness		2,0 mm
minimum quantity consumed:		Sealoflex Protecta Waterproof Coating: 1,7 l/m² Sealoflex Protecta Top Coat: 0,7 l/m²
<u>Levels of use categories according to ETAG 005 with relation to:</u>		
Working life:		W3 (25 years)
Climatic zones		M and S (moderate and severe climatic)
Resistance to mechanical damage (perforation) (non-compressible substrates)		P1 to P3 (low to normal only for less com-pressible substrate, e.g. concrete/steel)
Roof slope		S1 to S4 (all slopes)
Lowest surface temperature		TL3 (-20 °C)
Highest surface temperature		TH4 (90 °C)
<u>Performance of the product:</u>		
External fire performance	EN 13501-5	B _{ROOF} (t ₁)*
Reaction to fire	EN 13501-1	E
Water vapour diffusion resistance factor μ		μ ≈6800
Watertightness		pass
Statement on dangerous substances		see section 3.2
Resistance to plant roots		no performance assessed
Resistance to wind loads		≥ 50 kPa
Resistance to slipperiness		no performance assessed

* Class B_{ROOF} (t₁)

The classification is valid for the following supporting decks:

- roof pitches $\leq 20^\circ$
- any non-combustible continuous deck with a minimum thickness of 10 mm

Any other roof systems for which classification documents for B_{ROOF} (t₁) according EN 13501-5 are available.

BMI Sealoflex Protecta
BMI Group Management UK Limited

System built-up, levels of use categories and performances of the product

Annex A

Installation

The levels of use categories and the performances of the roof waterproofing can be assumed only, if the installation is carried out according to the installation instructions stated in the technical file of the manufacturer, in particular taking account of the following points:

- installation by appropriately trained personnel
- installation of only those components which are marked components of the kit
- installation with the required tools and adjuvants
- precautions during installation
- inspecting the roof surface for cleanliness and correct preparation, if need be, applying a primer before applying the product
- inspecting compliance with suitable weather and curing conditions
- ensuring a thickness of the cured waterproofing of at least 2.0 mm by processing appropriate minimum quantities of material
- inspections during installation and of the finished product and documentation of the results

BMI Sealoflex Protecta
BMI Group Management UK Limited

Intended use
Specifications

Annex B