

Approval body for construction products
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and
Laender Governments



European Technical Assessment

ETA-19/0264
of 25 September 2019

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the
European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

KSM 6301
Betocal 6301

Product family
to which the construction product belongs

Calcium carbonate filler aggregate with additional
characteristics

Manufacturer

Karl Kraft, Steinwerke
Nattheimer Straße 201
89520 Heidenheim
DEUTSCHLAND

Manufacturing plant

Karl Kraft Steinwerke
Werk Waibertal
89520 Heidenheim

This European Technical Assessment
contains

4 pages which form an integral part of this assessment

This European Technical Assessment is
issued in accordance with Regulation (EU)
No 305/2011, on the basis of

EAD 260048-00-0301

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

Specific part

1 Technical description of the product

The calcium carbonate filler aggregate with additional characteristics "KSM 6301"/ "Betocal 6301" is a filler aggregate obtained by processing (grinding) natural calcium carbonate (white calcium carbonate from Jurassic rock) for use in concrete. The calcium carbonate filler aggregate possesses the following additional characteristics according to EN 197-1, clause 5.2.6 for limestone (LL):

- CaCO_3 content at least 75 % by mass,
- content of fines $\leq 1,20$ g/100 g and
- total organic content (TOC) $\leq 0,20$ % by mass.

Furthermore, the chloride content complies with EN 197-1, clause 7.3:

- chloride content $\leq 0,10$ % by mass.

2 Specification of the intended use in accordance with the applicable European Assessment Document

The calcium carbonate filler aggregate "KSM 6301"/ "Betocal 6301" is a type I addition for concrete conforming to European standard EN 206, i.e. concrete for structures cast in situ, precast structures, and structural precast products for buildings and civil engineering structures. The concrete can be mixed on site, ready-mixed or produced in a plant for precast concrete products.

The calcium carbonate filler aggregate "KSM 6301"/ "Betocal 6301" is also intended to be used for self-compacting concrete (SCC).

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of concrete incorporating the calcium carbonate filler aggregate "KSM 6301"/ "Betocal 6301" of at least 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and references to the methods used for its assessment

Table 1 Mechanical resistance and stability (BWR 1)

Essential characteristic	Performance	
	Sieve [mm]	Percentage passing by mass
Particle size distribution	2	100
	0,125	100
	0,063	99
Specific surface (Blaine)	6600 ± 500 cm ² /g	
Particle density	2,70 ± 0,10 g/cm ³	
CaCO ₃ content	≥ 98 % by mass	
Content of fines (Clay content)	≤ 0,20 g/100 g	
Total organic content (TOC)	≤ 0,10 % by mass	
MgCO ₃ content	≤ 1,0 % by mass	
Chloride content (Cl ⁻)	≤ 0,10 % by mass	
Sulfate content (SO ₃)	AS _{0,2}	
Total content of sulfur	≤ 1,0 % by mass	
Constituents which alter the rate of setting and hardening of concrete	Passed	
Initial setting time	Control Mix: 180 min Test mixes: 130/120/115 min	
Soundness	≤ 10 mm	

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with EAD No. 260048-00-0301 the applicable European legal act is: 1999/469/EC(EU).

The system to be applied is: 2+

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with Deutsches Institut für Bautechnik.

Issued in Berlin on 25 September 2019 by Deutsches Institut für Bautechnik

BD Dipl.-Ing. Andreas Kummerow
Head of Department

beglaubigt:
Bahlmann