

Approval body for construction products
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and
Laender Governments



European Technical Assessment

ETA-13/0372
of 15 December 2020

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the
European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

CELO Drop-in anchor SA plus

Product family
to which the construction product belongs

Mechanical fastener for use in concrete

Manufacturer

CELO Befestigungssysteme GmbH
Industriestraße 6
86551 Aichach
DEUTSCHLAND

Manufacturing plant

Plant 8
Plant 13

This European Technical Assessment
contains

14 pages including 3 annexes which form an integral part
of this assessment

This European Technical Assessment is
issued in accordance with Regulation (EU)
No 305/2011, on the basis of

EAD 330232-00-0601, Edition 10/2016

This version replaces

ETA-13/0372 issued on 25 May 2018

European Technical Assessment

ETA-13/0372

English translation prepared by DIBt

Page 2 of 14 | 15 December 2020

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

Specific Part**1 Technical description of the product**

The CELO Drop-In Anchor SA plus in the sizes M8, M10, M12 and M16 is an anchor made of zinc-plated steel which is placed into a drilled hole and anchored by deformation-controlled expansion.

The product description is given in Annex A.

2 Specification of the intended use in accordance with the applicable European Assessment Document

The performances given in Section 3 are only valid if the concrete screw is used in compliance with the specifications and conditions given in Annex B.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the anchor of at least 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and references to the methods used for its assessment**3.1 Mechanical resistance and stability (BWR 1)**

Essential characteristic	Performance
Characteristic resistance to tension load (static and quasi-static loading)	see Annex B 2 and C 1
Characteristic resistance to shear load (static and quasi-static loading)	see Annex C 2
Displacements (static and quasi-static loading)	see Annex C 3
Characteristic resistance and displacements for seismic performance categories C1 and C2	No performance assessed
Durability	See Annex B 1

3.2 Safety in case of fire (BWR 2)

Essential characteristic	Performance
Reaction to fire	Class A1
Resistance to fire	No performance assessed

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with European Assessment Documents EAD No. 330232-00-0601 the applicable European legal act is: [96/582/EC].

The system to be applied is: 1

5 Technical details necessary for the implementation of the AVCP system, as provided for the applicable European Assessment Document


Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with Deutsches Institut für Bautechnik.

Issued in Berlin on 15 December 2020 by Deutsches Institut für Bautechnik.

Dipl.-Ing. Beatrix Wittstock
Head of Section

beglaubigt:
Baderschneider

Installation situation in uncracked concrete C20/25 – C50/60





- h_1 = depth of drill hole
- h_{ef} = effective embedment depth
- t_{fix} = thickness of fixture
- L_s = length of thread inside of the anchor
- T_{inst} = max. installation torque

CELO Drop in anchor SA plus



Product description
Installed condition

Annex A1

CELO Drop in anchor SA plus



SA plus without collar



SA plus with collar

marking:

brand marking
type
size

Logo or company
SA plus
M ... (i.e. M10)

Example:

◆ SA plus M10

Table A2: Dimensions of the anchor

Anchor		Sleeve		Cone	
	Thread inside	Length	Outer- \varnothing sleeve	Length	Outer- \varnothing sleeve
type		L_H	d_{nom}	L_c	d_c
SA plus		[mm]	[mm]	[mm]	[mm]
M8 x 30	M8	30	10	12	6
M10 x 40	M10	40	12	16	7,5
M12 x 50	M12	50	15	21	9,5
M16 x 65	M16	65	20	26	13

CELO Drop in anchor SA plus

Product description
Product, marking and dimensions

Annex A2

Table A3.1: Designation and materials

Designation	Material
Sleeve M8 M10 M12 M16	Steel for cold forming C1008-C1012 or EN 10277:2018 C1015 or EN 10277:2018 C1008-C1012 or EN 10277:2018 C1008-C1012 or EN 10277:2018
Spreading cone	Steel for cold forming C1006-1008
Retaining disc	Paper or plastics

all parts zinc plated and blue passivated $\geq 5 \mu\text{m}$ acc. EN ISO 4042:2018

Table A3.2: Strength of the sleeve

CELO Drop in anchor SA plus			Size			
			M8	M10	M12	M16
Nominal characteristic steel ultimate strength	f_{uk}	[N/mm ²]	535	535	430	430
Nominal characteristic steel yield strength	f_{yk}	[N/mm ²]	485	485	390	390

CELO Drop in anchor SA plus

Product description
Materials

Annex A3

Handsetting tool

Optional: setting tool with size marking and/or rubber grip possible




Table A4: Geometry of the setting tool

Setting tool	Setting pin		
Steel HRc 38-42	Dimension		
Type	D ₁	D ₂	H ₁
	[mm]	[mm]	[mm]
ESW 8	6,6	9,5	17,5
ESW 10	8,3	12	23,5
ESW 12	10,2	14	29
ESW 16	13,9	19	39

CELO Drop in anchor SA plus

Product description
Setting tools

Annex A4

Specifications of Intended use

Anchorage subject to:

- Static and quasi-static loading,

Base materials:

- Compacted, reinforced or unreinforced normal weight concrete without fibres according to EN 206:2013 + A1:2016.
- Strength classes C20/25 to C50/60 according to EN 206:2013 + A1:2016.
- Only uncracked concrete.

Use conditions (Environmental conditions):

- Structures subject to dry internal conditions.

Design:

- Anchorages are designed under the responsibility of an engineer experienced in anchorages and concrete work.
- Verifiable calculation notes and drawings are prepared taking account of the loads to be anchored. The position of the anchor is indicated on the design drawings (e. g. position of the anchor relative to reinforcement or to supports, etc.).
- The anchorages are designed in accordance to EN 1992-4:2018 and Technical Report TR 055, Edition February 2018.
- For effective embedment depth $h_{ef} < 40$ mm only statically indeterminate fixings (e.g. light-weight suspended ceilings with internal exposure) are covered by the ETA

Installation:

- Anchor installation carried out by appropriately qualified personnel and under the supervision of the person responsible for technical matters of the site.
- Create drill hole with hammer drill only.
- In case of aborted hole: new drilling at a minimum distance away of twice the depth of the aborted hole or smaller distance if the aborted drill hole is filled with high strength mortar and only if the hole is not in the direction of the oblique tensile or shear load.
- Anchor installation in accordance with the manufacturer's specifications and drawings and using the appropriate tools.

CELO Drop in anchor SA plus

**Intended use
Specifications**

Annex B1

Table B2.1: Installation parameters

Fixing screws or anchor rods:

It can be used the strength categories 4.6, 5.6, 5.8 or 8.8 acc. EN ISO 898-1:2013.

Minimal screwing depth:

The length of the fixing screw depends on the thickness t_{fix} on the fixed part, permissible tolerances and usable thread length $L_{s,max}$ as well as on the minimal screwing depth $L_{s,min}$.

CELO drop in anchor SA plus			Size			
			M8	M10	M12	M16
Nominal driller diameter	d_o	[mm]	10	12	15	20
Cutting diameter of drillbit	$d_{cut} \leq$	[mm]	10,45	12,50	15,50	20,55
Diameter of thread	M	[mm]	8	10	12	16
Depth of drill hole (deepest point)	$h_1 \geq$	[mm]	32	43	54	70
Effective embedment depth	h_{ef}	[mm]	30	40	50	65
Maximum screwing depth	$L_{s,max}$	[mm]	13	16	23	32
Minimum screwing depth	$L_{s,min}$	[mm]	8	10	12	16
Diameter of clearance hole in the fixture	$d_f \leq$	[mm]	9	12	14	18
Maximum installation torque moment	$\max T_{inst}$	[Nm]	8	15	35	60

Table B2.2: Minimum thickness of concrete member, spacing and edge distance


CELO drop in anchor SA plus			Size			
			M8	M10	M12	M16
Minimum thickness of member	h_{min}	[mm]	100	100	120	160
Minimum spacing	s_{min}	[mm]	105	105	125	180
Minimum edge distance	c_{min}	[mm]	105	140	175	230

CELO Drop in anchor SA plus

Intended use
Installation parameters

Annex B2


Installation instruction:




1. Drill the hole with a hammer drill




2. Clean the borehole



3. To set the anchor by hand or by hammer blows, anchor should be flush to the concrete edge



4. To spread the anchor with the setting tool. The anchor is installed correctly, if the setting pin is completely inside



5. To fix the fixture, not allowed to pass over the max. installation torque T_{inst}

CELO Drop in anchor SA plus

Intended use
Installation instruction

Annex B3

Table C1: Characteristic resistance under tension loads

CELO drop in anchor SA plus				size			
				M8	M10	M12	M16
Steel failure							
Characteristic resistance	N _{Rk,s}	[kN]	steel 4.6	14,6	23,2	33,7	62,7
Partial factor	γ _{Ms}	[-]		2,0			
Characteristic resistance	N _{Rk,s}	[kN]	steel 5.6	18,3	29,0	42,1	78,3
Partial factor	γ _{Ms}	[-]		2,0			
Characteristic resistance	N _{Rk,s}	[kN]	steel 5.8	18,3	22,5	30,8	51,5
Partial factor	γ _{Ms}	[-]		1,5			
Characteristic resistance	N _{Rk,s}	[kN]	steel 8.8	17,8	22,5	30,8	51,5
Partial factor	γ _{Ms}	[-]		1,5			
Pull out failure							
Characteristic resistance in uncracked concrete C 20/25	N _{Rk,p}	[kN]		7,5	12	16	30
Increasing factors for N _{Rk,p}	Ψ _C	[-]	C30/37	1,22	1,11	1,22	
			C40/50	1,41	1,21	1,41	
			C50/60	1,58	1,28	1,58	
Installation factor	γ _{inst}	[-]		1,0	1,2		
Concrete cone failure							
Effective anchorage depth	h _{ef}	[mm]		30	40	50	65
Factor for uncracked concrete	k _{ucr,N}	[-]		11,0			
Factor for cracked concrete	k _{cr,N}	[-]		No performance assessed			
Spacing	s _{cr,N}	[mm]		3 x h _{ef}			
Edge distance	c _{cr,N}	[mm]		1,5 x h _{ef}			
Installation factor	γ _{inst}	[-]		1,0	1,2		
Concrete splitting failure							
Characteristic resistance	N ⁰ _{Rk,sp}	[kN]		N ⁰ _{Rk,sp} = min[N _{Rk,p} ; N ⁰ _{Rk,c} ¹⁾]			
Spacing (splitting)	s _{cr,sp}	[mm]		210	280	350	460
Edge distance (splitting)	c _{cr,sp}	[mm]		105	140	175	230
Installation factor	γ _{inst}	[-]		1,0	1,2		

¹⁾ $N^0_{Rk,c}$ according to EN 1998-4:2018

CELO Drop in anchor SA plus

Performances

Characteristic resistance under tension loads

Annex C1

Table C2: Characteristic resistance under shear load

CELO drop in anchor SA plus				size			
				M8	M10	M12	M16
Steel failure without lever arm							
Characteristic resistance	$V_{Rk,s}^0$	[kN]	steel 4.6	7,3	9,5	15,4	25,7
Partial factor	γ_{Ms}	[-]		1,67	1,5		
Characteristic resistance	$V_{Rk,s}^0$	[kN]	steel 5.6	8,9	9,5	15,4	25,7
Partial factor	γ_{Ms}	[-]		1,5			
Characteristic resistance	$V_{Rk,s}^0$	[kN]	steel 5.8	8,9	9,5	15,4	25,7
Partial factor	γ_{Ms}	[-]		1,5			
Characteristic resistance	$V_{Rk,s}^0$	[kN]	steel 8.8	8,9	9,5	15,4	25,7
Partial factor	γ_{Ms}	[-]		1,5			
Steel failure with lever arm							
Characteristic bending moment	$M_{Rk,s}^0$	[Nm]	steel 4.6	15,0	29,9	52,4	132,8
Partial factor	γ_{Ms}	[-]		1,67			
Characteristic bending moment	$M_{Rk,s}^0$	[Nm]	steel 5.6	18,7	37,4	65,5	165,9
Partial factor	γ_{Ms}	[-]		1,67			
Characteristic bending moment	$M_{Rk,s}^0$	[Nm]	steel 5.8	18,7	37,4	65,5	165,9
Partial factor	γ_{Ms}	[-]		1,25			
Characteristic bending moment	$M_{Rk,s}^0$	[Nm]	steel 8.8	30,0	59,8	104,7	265,5
Partial factor	γ_{Ms}	[-]		1,25			
Ductility factor	k_7	[-]		0,8			
Concrete pryout failure							
k-Factor	k_8	[-]		1,0			2,0
Concrete edge failure							
Effective anchor length under shear load	l_f	[mm]		30	40	50	65
Effective external diameter of anchor	d_{nom}	[mm]		10	12	15	20
Installation factor	γ_{inst}	[-]		1,0			

CELO Drop in anchor SA plus

Performances

Characteristic resistance under shear loads

Annex C2

Table C3.1: Displacements of the anchors under tension loads

CELO drop in anchor SA plus			Size			
			M8	M10	M12	M16
Tension load	N	[kN]	3,5	4,8	6,3	11,9
Displacements	δ_{N_0}	[mm]	0,2			
Displacements	$\delta_{N_{\infty}}$	[mm]	1,3			

Table C3.2: Displacements under shear loads

Celo drop in anchor SA plus			Size			
			M8	M10	M12	M16
Shear load	V	[kN]	4,2	4,5	7,3	12,2
Displacements	δ_{V_0}	[mm]	1,4	1,6	2,3	1,0
Displacements	$\delta_{V_{\infty}}$	[mm]	2,1	2,4	3,5	1,5

CELO Drop in anchor SA plus

Performances

Displacement under tension and shear loads

Annex C3