

Approval body for construction products  
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and  
Laender Governments



## European Technical Assessment

**ETA-20/0024**  
**of 21 January 2020**

English translation prepared by DIBt - Original version in German language

### General Part

Technical Assessment Body issuing the  
European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

TER LAARE BX XTREME ETA 1 EV/ZL, TER LAARE BX  
XTREME ETA 1 A4, TER LAARE BX XTREME ETA 1  
HCR concrete screw

Product family  
to which the construction product belongs

Mechanical fasteners for use in concrete

Manufacturer

TER LAARE VERANKERINGSTECHNIEKEN BV.  
Elektraweg 5  
3144 CB MAASSLUIS  
NIEDERLANDE

Manufacturing plant

Plant 3

This European Technical Assessment  
contains

22 pages including 3 annexes which form an integral part  
of this assessment

This European Technical Assessment is  
issued in accordance with Regulation (EU)  
No 305/2011, on the basis of

EAD 330232-00-0601

**European Technical Assessment**

**ETA-20/0024**

English translation prepared by DIBt

**Page 2 of 22 | 21 January 2020**

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

**Specific Part****1 Technical description of the product**

The TER LAARE BX EXTREME ETA 1 concrete screw is an anchor in size 6, 8, 10, 12 and 14 mm made of galvanised steel respectively steel with zinc flake coating, made of stainless or high corrosion resistant steel. The anchor is screwed into a predrilled cylindrical drill hole. The special thread of the anchor cuts an internal thread into the member while setting. The anchorage is characterised by mechanical interlock in the special thread.

Product and product description is given in Annex A.

**2 Specification of the intended use in accordance with the applicable European Assessment Document**

The performances given in Section 3 are only valid if the anchor is used in compliance with the specifications and conditions given in Annex B.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the anchor of at least 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

**3 Performance of the product and references to the methods used for its assessment****3.1 Mechanical resistance and stability (BWR 1)**

Essential characteristic	Performance
Characteristic resistance to tension load (static and quasi-static loading)	See Annex C 1 and C 2
Characteristic resistance to shear load (static and quasi-static loading)	See Annex C 1 and C 2
Displacements (static and quasi-static loading)	See Annex C 7
Characteristic resistance and displacements for seismic performance categories C1 and C2	See Annex C 3, C 4, C 5 and C 8

**3.2 Safety in case of fire (BWR 2)**

Essential characteristic	Performance
Reaction to fire	Class A1
Resistance to fire	See Annex C 6

**4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base**

In accordance with European Assessment Document EAD No. 330232-00-0601 the applicable European legal act is: [96/582/EC].

The system to be applied is: 1

**5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable European Assessment Document**

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited at Deutsches Institut für Bautechnik.

Issued in Berlin on 21 January 2020 by Deutsches Institut für Bautechnik


BD Dipl.-Ing. Andreas Kummerow  
Head of Department

*beglaubigt:*  
Tempel


Product in installed condition

TER LAARE BX XTREME ETA 1 concrete screw


- Galvanized carbon steel
- Zinc flakes coated carbon steel



- Stainless steel A4
- Stainless steel HCR



e.g. BX XTREME ETA 1 concrete screw, zinc flakes coated, with hexagon head and fixture




$d_0$  = nominal drill hole diameter  
 $t_{fix}$  = thickness of fixture  
 $d_f$  = clearance hole diameter

$h_{min}$  = minimum thickness of member  
 $h_{nom}$  = nominal embedment depth  
 $h_1$  = drill hole depth  
 $h_{ef}$  = effective embedment depth

TER LAARE BX XTREME ETA 1 concrete screw

Product description  
Product in installed condition


Annex A1




1. Configuration with metric connection thread and hexagon socket e.g. 8x105 M10 SW5




2. Configuration with metric connection thread and hexagon drive e.g. 8x105 M10 SW7




3. Configuration with washer and hexagon head e.g. 8x80 SW13 VZ 40




4. Configuration with washer, hexagon head and TORX drive e.g. 8x80 SW13




5. Configuration with hexagon head e.g. 8x80 SW13 OS



6. Configuration with countersunk head and TORX drive e.g. 8x80 C VZ 40



7. Configuration with pan head and TORX drive e.g. 8x80 P VZ 40





8. Configuration with large pan head and TORX drive e.g. 8x80 LP VZ 40



9. Configuration with countersunk head and connection thread e.g. 6x55 AG M8



10. Configuration with hexagon drive and connection thread e.g. 6x55 M8 SW10



11. Configuration with internal thread and hexagon drive e.g. 6x55 IM M8/10

**TER LAARE BX XTREME ETA 1 concrete screw**

**Product description**  
Screw types

**Annex A2**


Table 1: Material

Part	Product name	Material
all types	BX XTREME ETA 1 EV	- Steel EN 10263-4:2017 galvanized acc. to EN ISO 4042:2018
	BX XTREME ETA 1 ZL	- Zinc flake coating according to EN ISO 10683:2018 ( $\geq 5\mu\text{m}$ )
	BX XTREME ETA 1 A4	1.4401; 1.4404; 1.4571; 1.4578
	BX XTREME ETA 1 HCR	1.4529

Part	Product name	Nominal characteristic steel		Rupture elongation $A_5$ [%]
		Yield strength $f_{yk}$ [N/mm <sup>2</sup> ]	Ultimate strength $f_{uk}$ [N/mm <sup>2</sup> ]	
all types	BX XTREME ETA 1 EV / ZL	560	700	$\leq 8$
	BX XTREME ETA 1 A4			
	BX XTREME ETA 1 HCR			

Table 2: Dimensions

Anchor size			6		8			10			12			14		
Nominal embedment depth	$h_{nom}$	[mm]	1	2	1	2	3	1	2	3	1	2	3	1	2	3
			40	55	45	55	65	55	75	85	65	85	100	75	100	115
Screw length	$\leq L$	[mm]	500													
Core diameter	$d_k$	[mm]	5,1		7,1			9,1			11,1			13,1		
Thread outer diameter	$d_s$	[mm]	7,5		10,6			12,6			14,6			16,6		
Shaft diameter	$d_p$	[mm]	5,7		7,9			9,9			11,7			13,7		



**Marking:**

BX XTREME ETA 1 EV / ZL

Screw type: TSM

Screw size: 10

Screw length: 100

BX XTREME ETA 1 A4

Screw type: TSM

Screw size: 10

Screw length: 100

Material: A4



BX XTREME ETA 1 HCR

Screw type: TSM

Screw size: 10

Screw length: 100

Material: HCR



**TER LAARE BX XTREME ETA 1 concrete screw**

**Product description**

Material, Dimensions and markings

**Annex A3**

## Specification of Intended use

Table 3: Anchorages subject to

Screw size		6		8			10			12			14		
Nominal embedment depth		$h_{nom1}$	$h_{nom2}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$
	[mm]	40	55	45	55	65	55	75	85	65	85	100	65	85	115
Static and quasi-static loads		All sizes and all embedment depths													
Fire exposure															
C1 category - seismic		x	x	ok	x	ok	x	ok	x	ok	x	ok	x	ok	
C2 category – seismic (A4 and HCR unsuitable)															

### Base materials:

- Reinforced and unreinforced concrete without fibers according to EN 206:2013.
- Strength classes C20/25 to C50/60 according to EN 206:2013.
- Cracked and uncracked concrete.

### Use conditions (Environmental conditions):

- Concrete screws subject to dry internal conditions: all screw types.
- Structural subject to external atmospheric exposure (including industrial and marine environment) and to permanently damp internal condition no particular aggressive conditions exists: screw types made of stainless steel with marking A4.
- Structural subject to external atmospheric exposure (including industrial and marine environment) and to permanently damp internal condition if particular aggressive conditions exists: screw types made of stainless steel with marking HCR.

Note: Such particular aggressive conditions are e.g. permanent, alternating immersion in seawater or splash zone of seawater, chloride atmosphere of indoor swimming pools or atmosphere with chemical pollution (e.g. in desulphurization plants or road tunnels where de-icing materials are used).

TER LAARE BX XTREME ETA 1 concrete screw

Intended use  
Specification

Annex B1



## Specification of Intended use - continuation

### Design:

- Anchorages are to be designed under the responsibility of an engineer experienced in anchorages and concrete work.
- Verifiable calculation notes and drawings are to be prepared taking account of the loads to be anchored. The position of the anchor is indicated on the design drawings (e.g. position of the anchor relative to reinforcement or to supports, etc.).
- Anchorages are designed according to EN 1992-4:2018 and EOTA Technical Report TR 055. The design for shear load according to EN 1992-4:2018, Section 6.2.2 applies for all specified diameters  $d_f$  of clearance hole in the fixture in Annex B3, Table 4.

### Installation:

- Hammer drilling or hollow drilling; hollow drilling only for sizes 8-14.
- Anchor installation carried out by appropriately qualified personnel and under the supervision of the person responsible for technical matters on site.
- In case of aborted hole: new drilling must be drilled at a minimum distance of twice the depth of aborted hole or closer, if the aborted hole is filled with high strength mortar and only if the hole is not in the direction of the oblique tensile or shear load.
- After installation further turning of the anchor must not be possible. The head of the anchor is supported in the fixture and is not damaged.
- The borehole may be filled with injection mortar IM FAST ETA 1 or IM PURE HX ETA 1.
- Adjustability according to Annex B6 for sizes 8-14, all embedment depths, but not for seismic loading
- Cleaning of borehole is not necessary, if using a hollow drill

**TER LAARE BX XTREME ETA 1 concrete screw**


**Intended use**  
Specification continuation

**Annex B2**

Table 4: Installation parameters

Concrete screw size			6		8			10		
Nominal embedment depth		h <sub>nom</sub>	h <sub>nom1</sub>	h <sub>nom2</sub>	h <sub>nom1</sub>	h <sub>nom2</sub>	h <sub>nom3</sub>	h <sub>nom1</sub>	h <sub>nom2</sub>	h <sub>nom3</sub>
		[mm]	40	55	45	55	65	55	75	85
Nominal drill hole diameter	d <sub>0</sub>	[mm]	6		8			10		
Cutting diameter of drill bit	d <sub>cut</sub> ≤	[mm]	6,40		8,45			10,45		
Drill hole depth	h <sub>1</sub> ≥	[mm]	45	60	55	65	75	65	85	95
Clearance hole diameter	d <sub>f</sub> ≤	[mm]	8		12			14		
Installation torque (version with connection thread)	T <sub>inst</sub>	[Nm]	10		20			40		
Torque impact screw driver		[Nm]	Max. torque according to manufacturer's instructions							
			160		300			400		

Concrete screw size			12			14		
Nominal embedment depth		$h_{nom}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$
		[mm]	65	85	100	75	100	115
Nominal drill hole diameter	$d_0$	[mm]	12			14		
Cutting diameter of drill bit	$d_{cut} \leq$	[mm]	12,50			14,50		
Drill hole depth	$h_1 \geq$	[mm]	75	95	110	85	110	125
Clearance hole diameter	$d_f \leq$	[mm]	16			18		
Installation torque (version with connection thread)	$T_{inst}$	[Nm]	60			80		
Torque impact screw driver		[Nm]	Max. torque according to manufacturer's instructions					
			650			650		



TER LAARE BX XTREME ETA 1 concrete screw


Intended use  
Installation parameters

Annex B3

Table 5: Minimum thickness of member, minimum edge distance and minimum spacing

Concrete screw size			6		8			10		
Nominal embedment depth		$h_{nom}$	$h_{nom1}$	$h_{nom2}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$
		[mm]	40	55	45	55	65	55	75	85
Minimum thickness of member	$h_{min}$	[mm]	100		100		120	100	130	
Minimum edge distance	$c_{min}$	[mm]	40		40	50		50		
Minimum spacing	$s_{min}$	[mm]	40		40	50		50		

Concrete screw size			12			14		
Nominal embedment depth		$h_{nom}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$
		[mm]	65	85	100	75	100	115
Minimum thickness of member	$h_{min}$	[mm]	120	130	150	130	150	170
Minimum edge distance	$c_{min}$	[mm]	50		70	50	70	
Minimum spacing	$s_{min}$	[mm]	50		70	50	70	



TER LAARE BX XTREME ETA 1 concrete screw


**Intended use**

Minimum thickness of member, minimum edge distance and minimum spacing

**Annex B4**


## Installation Instructions

1




Create hammer drilled or hollow drilled borehole

2




Remove drill dust by vacuuming or blowing of

3



Install with torque impact screw driver or torque wrench

4



The head must be undamaged and in contact with the fixture

Note:

Cleaning of borehole is not necessary when using a hollow drill

**TER LAARE BX XTREME ETA 1 concrete screw**




**Intended use**

Installation instructions




**Annex B5**

## Installation Instructions – Adjustment

### 1. Adjustment



### 2. Adjustment



#### Notes:

1. Adjustment for seismic loading is not allowed
2. The fastener can be adjusted maximum two times. The total allowed thickness of shims added during the adjustment process is 10mm. The final embedment depth after adjustment process must be larger or equal than  $h_{nom}$ .

TER LAARE BX XTREME ETA 1 concrete screw


#### Intended use

Installation instructions - Adjustment


Annex B6

## Installation Instructions – Filling annular gap


### Positioning of fixture and filling washer




After preparing borehole (Annex B5, figure 1+2), position first fixture (1), then filling washer (2)



Install with torque impact screw driver or torque wrench




Installed condition without injected mortar in the filling washer



Discard 3x full strokes of mortar till color is constant

### Filling the annular gap



Fill the annular gap with injection mortar (minimum compression strength of 40 N/mm<sup>2</sup>)

Note:

For seismic loading the installation with filled and without filled annular gap is approved. Differences in performance can be found in Annex C5 - C7.

**TER LAARE BX XTREME ETA 1 concrete screw**

**Intended use**

Installation instructions - Filling annular gap

**Annex B7**



Table 6: Characteristic values for static and quasi-static loading, sizes 6-10

Concrete screw size				6		8			10		
Nominal embedment depth		$h_{nom}$	$h_{nom1}$	$h_{nom2}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$	
		[mm]	40	55	45	55	65	55	75	85	
Steel failure for tension and shear loading											
Characteristic tension load	$N_{Rk,s}$	[kN]	14,0		27,0			45,0			
Partial factor tension load	$\gamma_{Ms,N}$	[-]	1,5								
Characteristic shear load	$V_{Rk,s}$	[kN]	7,0		13,5		17,0	22,5	34,0		
Partial factor shear load	$\gamma_{Ms,V}$	[-]	1,25								
Ductility factor	$k_7$	[-]	0,8								
Characteristic bending load	$M^0_{Rk,s}$	[Nm]	10,9		26,0			56,0			
Pull-out failure											
Characteristic tension load C20/25	cracked	$N_{Rk,p}$	[kN]	2,0	4,0	5,0	9,0	12,0	9,0	$\geq N^0_{Rk,c}$	
	uncracked	$N_{Rk,p}$	[kN]	4,0	9,0	7,5	12,0	16,0	12,0	20,0	26,0
Increasing factor for $N_{Rk,p}$	C25/30	$\Psi_c$	[-]	1,12							
	C30/37			1,22							
	C40/50			1,41							
	C50/60			1,58							
Concrete failure: Splitting failure, concrete cone failure and pry-out failure											
Effective embedment depth	$h_{ef}$	[mm]	31	44	35	43	52	43	60	68	
k-factor	cracked	$k_1 = k_{cr}$	[-]	7,7							
	uncracked	$k_1 = k_{ucr}$	[-]	11,0							
Concrete cone failure	spacing	$s_{cr,N}$	[mm]	$3 \times h_{ef}$							
	edge distance	$c_{cr,N}$	[mm]	$1,5 \times h_{ef}$							
Splitting failure	spacing	$s_{cr,Sp}$	[mm]	120	160	120	140	150	140	180	210
	edge distance	$c_{cr,Sp}$	[mm]	60	80	60	70	75	70	90	105
Factor for pry-out failure	$k_8$	[-]	1,0							2,0	
Installation factor	$\gamma_{inst}$	[-]	1,0								
Concrete edge failure											
Effective length in concrete	$l_f = h_{ef}$	[mm]	31	44	35	43	52	43	60	68	
Nominal outer diameter of screw	$d_{nom}$	[mm]	6			8			10		
TER LAARE BX XTREME ETA 1 concrete screw									Annex C1		
Performances											
Characteristic values for static and quasi-static loading, sizes 6-10											

Table 7: Characteristic values for static and quasi-static loading, sizes 12-14

Concrete screw size			12			14			
Nominal embedment depth		$h_{nom}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$	
		[mm]	65	85	100	75	100	115	
Steel failure for tension and shear loading									
Characteristic tension load	$N_{Rk,s}$	[kN]	67,0			94,0			
Partial factor tension load	$\gamma_{Ms,N}$	[-]	1,5						
Characteristic shear load	$V_{Rk,s}$	[kN]	33,5	42,0		56,0			
Partial factor shear load	$\gamma_{Ms,V}$	[-]	1,25						
Ductility factor	$k_7$	[-]	0,8						
Characteristic bending load	$M^0_{Rk,s}$	[Nm]	113,0			185,0			
Pull-out failure									
Characteristic tension load C20/25	cracked	$N_{Rk,p}$	[kN]	12,0	$\geq N^0_{Rk,c}$				
	uncracked	$N_{Rk,p}$	[kN]	16,0					
Increasing factor for $N_{Rk,p}$	C25/30	$\Psi_c$	[-]	1,12					
	C30/37			1,22					
	C40/50			1,41					
	C50/60			1,58					
Concrete failure: Splitting failure, concrete cone failure and pry-out failure									
Effective embedment depth		$h_{ef}$	[mm]	50	67	80	58	79	92
k-factor	cracked	$k_1 = k_{cr}$	[-]	7,7					
	uncracked	$k_1 = k_{ucr}$	[-]	11,0					
Concrete cone failure	spacing	$s_{cr,N}$	[mm]	$3 \times h_{ef}$					
	edge distance	$c_{cr,N}$	[mm]	$1,5 \times h_{ef}$					
Splitting failure	spacing	$s_{cr,Sp}$	[mm]	150	210	240	180	240	280
	edge distance	$c_{cr,Sp}$	[mm]	75	105	120	90	120	140
Factor for pry-out failure		$k_8$	[-]	1,0	2,0		1,0	2,0	
Installation factor		$\gamma_{inst}$	[-]	1,0					
Concrete edge failure									
Effective length in concrete		$l_f = h_{ef}$	[mm]	50	67	80	58	79	92
Nominal outer diameter of screw		$d_{nom}$	[mm]	12			14		

TER LAARE BX XTREME ETA 1 concrete screw

### Performances

Characteristic values for static and quasi-static loading, sizes 12-14

Annex C2



Table 8: Seismic category C1 – Characteristic load values

Concrete screw size			8	10	12	14
Nominal embedment depth	$h_{nom}$	$h_{nom3}$				
	[mm]	65	85	100	115	
Steel failure for tension and shear load						
Characteristic load	$N_{Rk,s,eq}$	[kN]	27,0	45,0	67,0	94,0
Partial factor tension load	$\gamma_{Ms}$	[-]	1,5			
Characteristic load	$V_{Rk,s,eq}$	[kN]	8,5	15,3	21,0	22,4
Partial factor shear load	$\gamma_{Ms}$	[-]	1,25			
With filling of the annular gap <sup>1)</sup>	$\alpha_{gap}$	[-]	1,0			
Without filling of the annular gap	$\alpha_{gap}$	[-]	0,5			
Pull-out failure						
Characteristic tension load in cracked concrete C20/25	$N_{Rk,p,eq}$	[kN]	12,0	$\geq N^0_{Rk,c}$		
Concrete cone failure						
Effective embedment depth	$h_{ef}$	[mm]	52	68	80	92
Edge distance	$c_{cr,N}$	[mm]	$1,5 \times h_{ef}$			
Spacing	$s_{cr,N}$	[mm]	$3 \times h_{ef}$			
Installation safety factor	$\gamma_{inst}$	[-]	1,0			
Concrete pry-out failure						
Factor for pry-out failure	$k_8$	[-]	1,0	2,0		
Concrete edge failure						
Effective length in concrete	$l_f = h_{ef}$	[mm]	52	68	80	92
Nominal outer diameter of screw	$d_{nom}$	[mm]	8	10	12	14

1) Filling of the annular gap according to annex B7, figure 5

TER LAARE BX XTREME ETA 1 concrete screw

**Performances**

Seismic category C1 – Characteristic load values

**Annex C3**

**Table 9: Seismic category C2 <sup>1)</sup> – Characteristic load values with filled annular gap according to annex B7, figure 5**

Concrete screw size			8	10	12	14
Nominal embedment depth	$h_{nom}$	$h_{nom3}$				
	[mm]	65	85	100	115	
Steel failure for tension						
Characteristic load	$N_{Rk,s,eq}$	[kN]	27,0	45,0	67,0	94,0
Partial factor tension load	$\gamma_{Ms}$	[-]	1,5			
With filling of the annular gap	$\alpha_{gap}$	[-]	1,0			
Pull-out failure						
Characteristic load in cracked concrete	$N_{Rk,p,eq}$	[kN]	2,4	5,4	7,1	10,5
Steel failure for shear load						
Characteristic load	$V_{Rk,s,eq}$	[kN]	9,9	18,5	31,6	40,7
Partial factor shear load	$\gamma_{Ms}$	[-]	1,25			
With filling of the annular gap	$\alpha_{gap}$	[-]	1,0			
Concrete cone failure						
Effective embedment depth	$h_{ef}$	[mm]	52	68	80	92
Edge distance	$c_{cr,N}$	[mm]	$1,5 \times h_{ef}$			
Spacing	$s_{cr,N}$	[mm]	$3 \times h_{ef}$			
Installation safety factor	$\gamma_{inst}$	[-]	1,0			
Concrete pry-out failure						
Factor for pry-out failure	$k_8$	[-]	2,0			
Concrete edge failure						
Effective length in concrete	$l_f = h_{ef}$	[mm]	52	68	80	92
Nominal outer diameter of screw	$d_{nom}$	[mm]	8	10	12	14

1) A4 and HCR not suitable

**TER LAARE BX XTREME ETA 1 concrete screw**

**Performances**

Seismic category C2 – Characteristic load values with filled annular gap

**Annex C4**

Table 10: Seismic category C2 <sup>1)</sup> – Characteristic load values **without filled annular gap according to annex B7, figure 3**

Concrete screw size			8	10	12	14
Nominal embedment depth	$h_{nom}$	$h_{nom3}$				
	[mm]	65	85	100	115	
Steel failure for tension ( <b>hexagon</b> head type)						
Characteristic load	$N_{Rk,s,eq}$	[kN]	27,0	45,0	67,0	94,0
Partial factor tension load	$\gamma_{Ms}$	[-]	1,5			
Pull-out failure ( <b>hexagon</b> head type)						
Characteristic load in cracked concrete	$N_{Rk,p,eq}$	[kN]	2,4	5,4	7,1	10,5
Steel failure for shear load ( <b>hexagon</b> head type)						
Characteristic load	$V_{Rk,s,eq}$	[kN]	10,3	21,9	24,4	23,3
Partial factor shear load	$\gamma_{Ms}$	[-]	1,25			
Without filling of the annular gap	$\alpha_{gap}$	[-]	0,5			
Steel failure for tension ( <b>countersunk</b> head type)						
Characteristic load	$N_{Rk,s,eq}$	[kN]	27,0	45,0	-	
Partial factor tension load	$\gamma_{Ms}$	[-]	1,5			
Pull-out failure ( <b>countersunk</b> head type)						
Characteristic load in cracked concrete	$N_{Rk,p,eq}$	[kN]	2,4	5,4	-	
Steel failure for shear load ( <b>countersunk</b> head type)						
Characteristic load	$V_{Rk,s,eq}$	[kN]	3,6	13,7	-	
Partial factor shear load	$\gamma_{Ms}$	[-]	1,25			
Without filling of the annular gap	$\alpha_{gap}$	[-]	0,5			
Concrete cone failure						
Effective embedment depth	$h_{ef}$	[mm]	52	68	80	92
Edge distance	$c_{cr,N}$	[mm]	$1,5 \times h_{ef}$			
Spacing	$s_{cr,N}$	[mm]	$3 \times h_{ef}$			
Installation safety factor	$\gamma_{inst}$	[-]	1,0			
Concrete pry-out failure						
Factor for pry-out failure	$k_8$	[-]	2,0			
Concrete edge failure						
Effective length in concrete	$l_f = h_{ef}$	[mm]	52	68	80	92
Nominal outer diameter of screw	$d_{nom}$	[mm]	8	10	12	14

1) A4 and HCR not suitable

**TER LAARE BX XTREME ETA 1 concrete screw**

### Performances

Seismic category C2 – Characteristic load values without filled annular gap

**Annex C5**

Table 11: Fire exposure – characteristic values of resistance

Concrete screw size				6		8			10			12			14		
Nominal embedment depth		h <sub>nom</sub>		1	2	1	2	3	1	2	3	1	2	3	1	2	3
		[mm]		40	55	45	55	65	55	75	85	65	85	100	75	100	115
Steel failure for tension and shear load (F <sub>Rk,s,fi</sub> = N <sub>Rk,s,fi</sub> = V <sub>Rk,s,fi</sub> )																	
characteristic Resistance	R30	F <sub>Rk,s,fi30</sub>	[kN]	0,9		2,4			4,4			7,3			10,3		
	R60	F <sub>Rk,s,fi60</sub>	[kN]	0,8		1,7			3,3			5,8			8,2		
	R90	F <sub>Rk,s,fi90</sub>	[kN]	0,6		1,1			2,3			4,2			5,9		
	R120	F <sub>Rk,s,fi120</sub>	[kN]	0,4		0,7			1,7			3,4			4,8		
	R30	M <sup>0</sup> <sub>Rk,s,fi30</sub>	[Nm]	0,7		2,4			5,9			12,3			20,4		
	R60	M <sup>0</sup> <sub>Rk,s,fi60</sub>	[Nm]	0,6		1,8			4,5			9,7			15,9		
	R90	M <sup>0</sup> <sub>Rk,s,fi90</sub>	[Nm]	0,5		1,2			3,0			7,0			11,6		
	R120	M <sup>0</sup> <sub>Rk,s,fi120</sub>	[Nm]	0,3		0,9			2,3			5,7			9,4		
Pull-out failure																	
Characteristic Resistance	R30-R90	N <sub>Rk,p,fi</sub>	[kN]	0,5	1,0	1,3	2,3	3,0	2,3	4,0	4,8	3,0	4,7	6,2	3,8	6,0	7,6
	R120	N <sub>Rk,p,fi</sub>	[kN]	0,4	0,8	1,0	1,8	2,4	1,8	3,2	3,9	2,4	3,8	4,9	3,0	4,8	6,1
Concrete cone failure																	
Characteristic Resistance	R30-R90	N <sup>0</sup> <sub>Rk,c,fi</sub>	[kN]	0,9	2,2	1,2	2,1	3,4	2,1	4,8	6,6	3,0	6,3	9,9	4,4	9,6	14,0
	R120	N <sup>0</sup> <sub>Rk,c,fi</sub>	[kN]	0,7	1,8	1,0	1,7	2,7	1,7	3,8	5,3	2,4	5,1	7,9	3,5	7,6	11,2
Edge distance																	
R30 bis R120		C <sub>cr,fi</sub>	[mm]	2 x h <sub>ef</sub>													
In case of fire attack from more than one side, the minimum edge distance shall be ≥300mm.																	
Spacing																	
R30 bis R120		S <sub>cr,fi</sub>	[mm]	4 x h <sub>ef</sub>													
Pry-out failure																	
R30 bis R120		k <sub>8</sub>	[-]	1,0					2,0		1,0	2,0		1,0	2,0		
The anchorage depth has to be increased for wet concrete by at least 30 mm compared to the given value.																	

TER LAARE BX XTREME ETA 1 concrete screw

## Performances

Fire exposure – characteristic values of resistance

Annex C6

Table 12: Displacements under static and quasi-static tension load

Concrete screw size				6		8			10		
Nominal embedment depth			$h_{nom}$	$h_{nom1}$	$h_{nom2}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$
			[mm]	40	55	45	55	65	55	75	85
Cracked concrete	tension load	N	[kN]	0,95	1,9	2,4	4,3	5,7	4,3	7,9	9,6
	displacement	$\delta_{N0}$	[mm]	0,3	0,6	0,6	0,7	0,8	0,6	0,5	0,9
		$\delta_{N\infty}$	[mm]	0,4	0,4	0,6	1,0	0,9	0,4	1,2	1,2
Uncracked concrete	tension load	N	[kN]	1,9	4,3	3,6	5,7	7,6	5,7	9,5	11,9
	displacement	$\delta_{N0}$	[mm]	0,4	0,6	0,7	0,9	0,5	0,7	1,1	1,0
		$\delta_{N\infty}$	[mm]	0,4	0,4	0,6	1,0	0,9	0,4	1,2	1,2

Concrete screw size				12			14		
Nominal embedment depth			$h_{nom}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$
			[mm]	65	85	100	75	100	115
Cracked concrete	tension load	N	[kN]	5,7	9,4	12,3	7,6	12,0	15,1
	displacement	$\delta_{N0}$	[mm]	0,9	0,5	1,0	0,5	0,8	0,7
		$\delta_{N\infty}$	[mm]	1,0	1,2	1,2	0,9	1,2	1,0
Uncracked concrete	tension load	N	[kN]	7,6	13,2	17,2	10,6	16,9	21,2
	displacement	$\delta_{N0}$	[mm]	1,0	1,1	1,2	0,9	1,2	0,8
		$\delta_{N\infty}$	[mm]	1,0	1,2	1,2	0,9	1,2	1,0

Table 13: Displacements under static and quasi-static shear load

Concrete screw size				6		8			10		
Nominal embedment depth			$h_{nom}$	$h_{nom1}$	$h_{nom2}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$
			[mm]	40	55	45	55	65	55	75	85
Cracked and uncracked concrete	shear load	V	[kN]	3,3		8,6			16,2		
	displacement	$\delta_{V0}$	[mm]	1,55		2,7			2,7		
		$\delta_{V\infty}$	[mm]	3,1		4,1			4,3		

Concrete screw size				12			14		
Nominal embedment depth			$h_{nom}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$	$h_{nom1}$	$h_{nom2}$	$h_{nom3}$
			[mm]	65	85	100	75	100	115
Cracked and uncracked concrete	shear load	V	[kN]	20,0			30,5		
	displacement	$\delta_{V0}$	[mm]	4,0			3,1		
		$\delta_{V\infty}$	[mm]	6,0			4,7		

TER LAARE BX XTREME ETA 1 concrete screw

## Performances

Displacements under static and quasi-static loads

Annex C7

**Table 14: Seismic category C2 <sup>1)</sup> – Displacements with filled annular gap according to annex B7, figure 5**

Concrete screw size			8	10	12	14
Nominal embedment depth	$h_{nom}$	$h_{nom3}$				
	[mm]	65	85	100	115	
Displacements under tension loads ( <b>hexagon</b> head type)						
Displacement DLS	$\delta_{N,eq(DLS)}$	[mm]	0,66	0,32	0,57	1,16
Displacement ULS	$\delta_{N,eq(ULS)}$	[mm]	1,74	1,36	2,36	4,39
Displacements under shear loads ( <b>hexagon</b> head type with hole clearance)						
Displacement DLS	$\delta_{V,eq(DLS)}$	[mm]	1,68	2,91	1,88	2,42
Displacement ULS	$\delta_{V,eq(ULS)}$	[mm]	5,19	6,72	5,37	9,27

**Table 15: Seismic category C2 <sup>1)</sup> – Displacements without filled annular gap according to annex B7, figure 3**

Concrete screw size			8	10	12	14
Nominal embedment depth	$h_{nom}$	$h_{nom3}$				
	[mm]	65	85	100	115	
Displacements under tension loads ( <b>hexagon</b> head type)						
Displacement DLS	$\delta_{N,eq(DLS)}$	[mm]	0,66	0,32	0,57	1,16
Displacement ULS	$\delta_{N,eq(ULS)}$	[mm]	1,74	1,36	2,36	4,39
Displacements under tension loads ( <b>countersunk</b> head type)						
Displacement DLS	$\delta_{N,eq(DLS)}$	[mm]	0,66	0,32	-	
Displacement ULS	$\delta_{N,eq(ULS)}$	[mm]	1,74	1,36		
Displacements under shear loads ( <b>hexagon</b> head type with hole clearance)						
Displacement DLS	$\delta_{V,eq(DLS)}$	[mm]	4,21	4,71	4,42	5,60
Displacement ULS	$\delta_{V,eq(ULS)}$	[mm]	7,13	8,83	6,95	12,63
Displacements under shear loads ( <b>countersunk</b> head type with hole clearance)						
Displacement DLS	$\delta_{V,eq(DLS)}$	[mm]	2,51	2,98	-	
Displacement ULS	$\delta_{V,eq(ULS)}$	[mm]	7,76	6,25		

1) A4 and HCR not suitable

**TER LAARE BX XTREME ETA 1 concrete screw**

**Performances**

Displacements under seismic loads

**Annex C8**