

Approval body for construction products
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and
Laender Governments



European Technical Assessment

ETA-20/0030
of 24 February 2020

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the
European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

"steinonorm PUR-035-PVC", "steinonorm PUR-040-PVC"
and "steinonorm PUR-040-Alu"

Product family
to which the construction product belongs

Open cell factory made rigid polyurethane foam (PUR)
and polyisocyanurate foam (PIR) products for building
equipment and industrial installations

Manufacturer

Steinbacher Dämmstoff GmbH
Salzburger Straße 35
6383 Erpfendorf/Tirol
ÖSTERREICH

Manufacturing plant

see Annex A

This European Technical Assessment
contains

6 pages including 1 annex which form an integral part of
this assessment

This European Technical Assessment is
issued in accordance with Regulation (EU)
No 305/2011, on the basis of

EAD 041094-00-1201

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

Specific Part

1 Technical description of the product

This European Technical Assessment applies to the concentric pipe sections made of rigid polyurethane foam (PUR) with fire protection equipment with the designations:

"steinonorm PUR-035-PVC", "steinonorm PUR-040-PVC" and "steinonorm PUR-040-Alu"

The concentric pipe sections have an open cell content over 90 %.

Carbon dioxide (CO₂) is used as blowing agent.

The nominal thickness of the concentric pipe sections is 20 mm to 60 mm.

The concentric pipe sections "steinonorm PUR-035-PVC" and "steinonorm PUR-040-PVC" have a surface facing of approximately 0.25 mm PVC-foil and an inner facing of approximately 0.1 mm paper laminates.

The concentric pipe sections "steinonorm PUR-040-Alu" have a surface facing of approximately 0.2 mm aluminum composite paper and an inner facing of approximately 0.1 mm paper laminates.

The seams are closed with an adhesive closure (weight 2.5 g/m ± 5 %).

The European Technical Assessment has been issued for the product on the basis of agreed data/information, deposited with Deutsches Institut für Bautechnik, which identifies the product that has been assessed. The European Technical Assessment applies only to the product corresponding to this agreed data/information.

2 Specification of the intended use in accordance with the applicable European Assessment Document

The pipe sections are used to limit the heat emission of heat distribution and hot-water pipelines in buildings for metallic pipes as well as plastic pipes and multi-layer composite pipes, which have at least the reaction to fire class E.

The performance according to section 3 only applies if the pipe sections are installed according to the manufacture's installation instructions and if they are protected from precipitation, wetting or weathering during transport and storage before installation.

For the application of the pipe sections the relevant national provisions shall be taken into account¹.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the pipe sections of at least 25 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works

3 Performance of the product and references to the methods used for its assessment

For sampling, conditioning and testing the provisions of the EAD No 041094-00-1201 apply.

¹ Note: In Germany the Energy Saving Ordinance ("Verordnung über energiesparenden Wärmeschutz und energiesparende Anlagentechnik bei Gebäuden (Energieeinsparverordnung – EnEV")) apply.

3.1 Safety in case of fire (BWR 2)

Essential characteristic	Performance
Reaction to fire test acc. to EN ISO 11925-2:2010	Class E ² acc. to EN 13501-1:2018

3.2 Hygiene, health and the environment (BWR 3)

Essential characteristic	Performance
Trace quantities of water-soluble ions and pH-value	No performance assessed

3.3 Safety and accessibility in use (BWR 4)

Essential characteristic	Performance
Geometrical properties length test acc. to EN 13467:2018 thickness test acc. to EN 13467:2018 internal diameter test acc. to EN 13467:2018 squareness test acc. to EN 13467:2018 linearity test acc. to EN 13467:2018	Tolerance ± 3 mm ± 2 mm - 0 mm; + 2 mm ³ - 0 mm; + 3 mm ⁴ no performance assessed no performance assessed
Density test acc. to EN 13470:2001	"steinonorm PUR-035-PVC" 25 kg/m ³ to ⁵ 41 kg/m ³ "steinonorm PUR-040-PVC" and "steinonorm PUR-040-Alu" 20 kg/m ³ to ⁵ 41 kg/m ³
Maximum application (service) temperature	No performance assessed
Minimum application (service) temperature	No performance assessed

² The reaction to fire class E applies when used on metallic pipes with a nominal thickness of the thermal insulation from 20 mm to 60 mm. Class E applies to "steinonorm PUR-035-PVC" and "steinonorm PUR-040-PVC" when used on plastic pipes or multi-layer composite pipes, which have at least the reaction to fire class E, with a nominal thickness of the thermal insulation from 20 mm to 50 mm and for "steinonorm PUR-040-Alu" with a nominal thickness of the thermal insulation from 20 mm to 40 mm.

³ Applies to internal diameter < 170 mm

⁴ Applies to internal diameter ≥ 170 mm

⁵ Density without adhesive closure and surface facings. Only for the thermal insulation made of rigid polyurethane foam.

3.6 Energy economy and heat retention (BWR 6)

Essential characteristic	Performance					
Thermal conductivity at a reference temperature of ϑ °C test acc. to EN 8497:1996 in accordance with EN ISO 13787:2003	Declared value: ⁶					
	"steinonorm PUR-035-PVC"					
	ϑ °C	10	20	30	40	50
	λ_D W/(m·K)	0,032	0,034	0,035	0,036	0,038
	"steinonorm PUR-040-PVC" and "steinonorm PUR-040-Alu"					
	ϑ °C	10	20	30	40	50
	λ_D W/(m·K)	0,034	0,035	0,037	0,038	0,039
Conversion of humidity acc. to EN ISO 10456:2007+AC:2009 moisture conversion factor (23 °C/50 % rel. humidity to 23 °C/ 80 % rel. humidity):	$F_m = 1,00$					
Closed cells content	< 10 %					

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with EAD No 041094-00-1201, the applicable European legal act is: 1999/91/EC.
The system to be applied is: System 3

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with Deutsches Institut für Bautechnik.

Issued in Berlin on 24 February 2020 by Deutsches Institut für Bautechnik

Maja Tiemann
Head of Department

beglaubigt:
Meyer

⁶ The declared value is representative for at least 90 % of the production with a confidence level of 90 % and applies to the density range mentioned in section 3.

"steinonorm PUR-035-PVC", "steinonorm PUR-040-PVC"
and "steinonorm PUR-040-Alu"

Annex A

Manufacturing plants

1. Steinbacher Dämmstoff GmbH
Salzburger Straße 35
A-6383 Erpfendorf/Tirol
Austria
2. Steinbacher Izoterm Sp.z o.o.
ul. Gdanska 14, Czastkow Mazowiecki
05 – 152 Czosnow
Poland