



Approval body for construction products and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and Laender Governments



European Technical Assessment

ETA-09/0241 of 8 April 2021

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the European Technical Assessment:

Trade name of the construction product

Product family to which the construction product belongs

Manufacturer

Manufacturing plant

This European Technical Assessment contains

This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of

This version replaces

Deutsches Institut für Bautechnik

Mariseal Detail Roof Waterproofing Kit

Liquid applied roof waterproofing on the basis of polyurethane

MARIS POLYMERS S.M.S.A. Industrial Area of Inofita 32011 INOFITA GRIECHENLAND

MARIS POLYMERS S.M.S.A. Industrial Area of Inofita 32011 INOFITA GRIECHENLAND

7 pages including 2 annexes which form an integral part of this assessment

EAD 030350-00-0402

ETA-09/0241 issued on 29 April 2016

Deutsches Institut für Bautechnik Kolonnenstraße 30 B | 10829 Berlin | GERMANY | Phone: +49 30 78730-0 | Fax: +49 30 78730-320 | Email: dibt@dibt.de | www.dibt.de



European Technical Assessment ETA-09/0241 English translation prepared by DIBt

Page 2 of 7 | 8 April 2021

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.



Page 3 of 7 | 8 April 2021

European Technical Assessment ETA-09/0241 English translation prepared by DIBt

Specific part

1 Technical description of the product

The liquid applied roof waterproofing "Mariseal Detail Roof Waterproofing Kit" is a kit, which consists of the components:

- Primer (if required)
- liquid applied roof waterproofing on the basis of a one-component reactive polyurethane
- polyester fleece as reinforcement

For an adequate adhesion of the waterproofing layer – depending on the type of substrate – a primer is required. In general, the primer belonging to the substrate is given in the manufacturer technical documents¹. In single cases the manufacturer is responsible to give guidance which pretreatment/primer is required.

The liquid applied roof waterproofing Materials can be applied by pouring and/or brushing. Depending on the levels the minimum layer thickness of the roof waterproofing applied is 1.6 mm respectively 2.9 mm.

As an assembled system these components form a homogeneous seamless roof waterproofing.

The liquid applied roof waterproofing "MARISEAL DETAIL" does not contain any substances that are intended to inhibit or prevent root penetration (root protection agents).

The components and the system build-up of the roof waterproofing "Mariseal Detail Roof Waterproofing Kit" are given in Annex A.

2 Specification of the intended use in accordance with the applicable EAD

The liquid applied roof waterproofing is used for the waterproofing of roof surfaces, terraces and balconies.

In the technical file the manufacturer gives information concerning the substrates which the product is suitable for and on how these substrates shall be pre-treated.

The product can be used for new roofs or for upgrading existing roof waterproofing. It can also be used on vertical surfaces.

The categorisation according to use is given in Annex A.

The verification and assessment methods on which this European Technical Assessment is based lead to the assumption of working life of the product of 10 respectively 25 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

The levels of use categories and performances given in Section 3 are only valid if the liquid

applied roof waterproofing is used in compliance with the specifications and conditions given in

Annex B and the installation instructions of the manufacturer stated in the technical documents.

1

The manufacturer's technical documents comprise all information necessary for the production and the installation of the product as well as for repair of the roof waterproofing made from that and it is deposited with DIBt.



Page 4 of 7 | 8 April 2021

European Technical Assessment

ETA-09/0241

English translation prepared by DIBt

3 Performance of the product and references to the methods used for its assessment

3.1 Basic Works Requirement 2: Safety in case of fire

Essential characteristic	Performance
External fire performance	see annex A
Reaction to fire	see annex A

3.2 Basic Works Requirement 3: Hygiene, health and the environment

Content, emission and/or release of dangerous	substances		
Release scenario	S/W2		
Substance/s classified as EU-cat. Carc. 1A and/or 1B ^{a)}	The kit does not contain these dangerous substances.		
Substance/s classified as EU-cat. Muta. 1A and/or 1B ^{a)}			
Substance/s classified as EU-cat. Repr. 1A and/or 1B ^{a)}			
Essential characteristic	Performance		
Water vapour permeability	see annex A		
Watertightness	see annex A		
Resistance to wind loads	see annex A		
Resistance to mechanical damage (perforation)	see annex A, levels of use categories		
Resistance to fatigue movement	see annex A		
Resistance to the effects of low and high surface temperature	see annex A		
Resistance to ageing media (heat and water)	see annex A		
Resistance to UV radiation in the presence of moisture	see annex A		
Resistance to plant roots	see annex A		
Effects of variations in kit components and site practices	see annex A		
Effects of day joints	see annex A		
a) In accordance with Derwletien (EQ) No. 1070/2000			

^{a)} In accordance with Regulation (EC) No 1272/2008.

3.3 Basic Works Requirement 4: Safety and accessibility in use

Essential characteristic	Performance
Slipperiness	see annex A

3.4 General aspects

The verification of durability and serviceability is part of testing the essential characteristics. Durability and serviceability are only ensured if the specifications of intended use according to Annex B and the specifications of the technical file of the manufacturer are kept.



European Technical Assessment ETA-09/0241

Page 5 of 7 | 8 April 2021

English translation prepared by DIBt

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with EAD 030350-00-0402 the applicable European legal act is: 98/599/EC and amended by Commission Decision 2001/596/EC.

The system to be applied is: 3 In addition, with regard to reaction to fire for products covered by this EAD the applicable European legal act is: 2001/596/EC The system to be applied is: 3

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with Deutsches Institut für Bautechnik.


Issued in Berlin on 8 April 2021 by Deutsches Institut für Bautechnik

Bettina Hemme Head of Section *beglaubigt:* Gnamou

Page 6 of European Technical Assessment ETA-09/0241 of 8 April 2021

English translation prepared by DIBt





Description of the	e product			
Minimum layer thickness			1.6 mm	2.9 mm
minimum quantity consumed:			2.4 kg/m ²	4.1 kg/m²
Roof slope		S1 to S4 (from < 5° to > 30°)		
Performance of the product:			Description / Class / Level	
External fire performance EN 13501-5			Froof	
Reaction to fire EN 13501-1			E	
Statement on dangerous substances			see section 3.2	
Water vapour diffusion resistance factor µ			µ ≈ 1830	
Watertightness			watertight	
Resistance to wind loads			≥ 50 kPa	
Resistance to mec	hanical dar	nage (perforation)	P1 to P3	P1 to P4
(compressible and	non-compr	essible substrates)	(from low to normal)	(from low to high)
Resistance to fatig	ue moveme	ent	W2	W3
Resistance to the e	effects of	low surface temperature	TL3 (-20 °C)	TL4 (-30 °C)
high surface te		high surface temperature	TH4 (90 °C)	
Working life according to the resistance to ageing media (heat and water)			W2 (10 years)	W3 (25 years)
UV resistance in presence of moisture (climatic zones)			M and S (moderate and severe climatic)	
Resistance to plant roots			no performance assessed	
Effects of	at 8 °C	Maximum tensile strength	9,7 MPa 27,7 %	
variations in kit		Elongation		
components and		Dynamic identitation	P3	P4
site practices	at 40 °C	Maximum tensile strength	10,4 MPa	
		Elongation	29,9 %	
		Dynamic identitation	P3	P4
Effects of day joints			≥ 300 kPa	
Resistance to slipperiness			no performance assessed	

Mariseal Detail Roof Waterproofing Kit MARIS POLYMERS S.M.S.A.

System built up and classification

Annex A

Page 7 of European Technical Assessment ETA-09/0241 of 8 April 2021

English translation prepared by DIBt



Installation

The levels of use categories and the performances of the roof waterproofing can be assumed only, if the installation is carried out according to the installation instructions stated in the technical file of the manufacturer, in particular taking account of the following points:

- installation by appropriately trained personnel
- installation of only those components which are marked components of the kit
- installation with the required tools and adjuvants
- precautions during installation
- inspecting the roof surface for cleanliness and correct preparation, if need be, applying a primer before applying the product
- inspecting compliance with suitable weather and curing conditions
- ensuring a thickness of the cured waterproofing of at least 1.6 mm respectively 2.9 mm by processing appropriate minimum quantities of material
- inspections during installation and of the finished product and documentation of the results

Intended use Specifications Annex B