

Approval body for construction products
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and
Laender Governments



European Technical Assessment

ETA-20/0892
of 12 March 2021

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the
European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

MEISTERPaneele

Product family
to which the construction product belongs

Composite-based panels for indoor wall and ceiling
design

Manufacturer

MeisterWerke Schulte GmbH
Johannes-Schulte-Allee 5
59602 Rüthen / Meiste
DEUTSCHLAND

Manufacturing plant

MeisterWerke Schulte GmbH
Johannes-Schulte-Allee 5
59602 Rüthen / Meiste
DEUTSCHLAND

This European Technical Assessment
contains

6 pages including 1 annex which form an integral part of
this assessment

This European Technical Assessment is
issued in accordance with Regulation (EU)
No 305/2011, on the basis of

EAD 210058-00-0504

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

Specific part

1 Technical description of the product

The construction product is a non-load bearing composite-based panel used for decorative indoor wall design and/or indoor ceiling design, in the following referred to as composite-based panel.

The composite-based panels consist of a central core layer made of wood-based panels (medium-density fibreboard – MDF) associated with a printed decorative layer and a coating.

The possible product assembly is mentioned below:

- coating (varnish or melamine resin),
- printed decorative layer (paper, PP-foil) as well as
- central core layer made of wood-based panels (MDF)

The milled front edges of the elements are covered with a stamping foil. No flame retardants are added to the wood-based panels.

This European Technical Assessment is applicable for composite-based panels of different dimensions (width and length), thicknesses and area weights. The respective dimensions, total thicknesses and total basis weights of the composite boards are listed in Annex 1.

For mounting the composite-based panels to the wall and/or ceiling a fixing with ventilation gap and movement joint to the walls and other fixed components is recommended, on e.g. wooden battens or metal bars as substructure, using mechanic connectors as e.g. screws, screw claws and mounting clamps. The manufacturer's instructions for mounting have to be considered adequately.

The composite-based panels are joined by a smooth tongue and groove connection and can contain design joints.

Decorative for finishing corners and/or edges can be used - they are not part of this European Technical Assessment as well as any thermal insulation that may be used. Also the substructure is not part of this European Technical Assessment.

The European Technical Assessment has been issued for the products on the basis of agreed data/information, deposited with Deutsches Institut für Bautechnik (DIBt). The European Technical Assessment applies only to products corresponding to this agreed data/information.

2 Specification of the intended use in accordance with the applicable European Assessment Document

The composite-based panels are intended to be used for decorative purposes as non-load bearing component for internal wall and/or indoor ceiling finishes. The panels are also intended for the use in wet rooms. Exposition to direct water is not intended.

A partial cladding of only a single or parts of a single wall and/or ceilings is conceivable.

The performances given in Section 3 are only valid if the composite-based panels are used in compliance with the specifications and conditions given in clause 1.2.1 of the corresponding European Assessment Document 210058-00-0504.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the composite-based panels of at least 25 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and references to the methods used for its assessment

3.1 Safety in case of fire (BWR 2)

Essential characteristic	Performance
Reaction to fire test according to EN ISO 11925-2:2020-07	Class E according to EN 13501-1:2018-12
Propensity to undergo continuous smouldering	NPA

3.2 Hygiene, health and the environment (BWR 3)

Essential characteristic	Performance																		
Content, emission and/or release of dangerous substances																			
Substances classified as Carc. 1A/1B ^{a)}	None of these raw materials are actively used in the manufacture of the construction product. ^{b)}																		
Substances classified as Muta. 1A/1B ^{a)}																			
Substances classified as Acute Tox. 1, 2, 3; Repr. 1A/1B; STOT SE 1 and STOT RE 1 ^{a)}																			
SVOC and VOC	The products "bocado DP 200", "bocado DP 300" and "terra DP 250" were tested representatively for the emission of dangerous substances, using the loading factor $L = 1,4 \text{ m}^2/\text{m}^3$ for ceilings and walls. The products achieved the following performances: ^{c)}																		
	<table border="1"> <thead> <tr> <th></th> <th>3 days</th> <th>28 days</th> </tr> </thead> <tbody> <tr> <td>Carcinogens (Cat. 1A/1B)</td> <td>< 0.01 mg/m³</td> <td>< 0.001 mg/m³</td> </tr> <tr> <td>TVOCspez</td> <td>< 10 mg/m³</td> <td>< 1.0 mg/m³</td> </tr> <tr> <td>TSVOC</td> <td></td> <td>< 0.1 mg/m³</td> </tr> <tr> <td>TVOC without NIK</td> <td></td> <td>< 0.1 mg/m³</td> </tr> <tr> <td>R-value</td> <td></td> <td>< 1</td> </tr> </tbody> </table>		3 days	28 days	Carcinogens (Cat. 1A/1B)	< 0.01 mg/m ³	< 0.001 mg/m ³	TVOCspez	< 10 mg/m ³	< 1.0 mg/m ³	TSVOC		< 0.1 mg/m ³	TVOC without NIK		< 0.1 mg/m ³	R-value		< 1
	3 days	28 days																	
Carcinogens (Cat. 1A/1B)	< 0.01 mg/m ³	< 0.001 mg/m ³																	
TVOCspez	< 10 mg/m ³	< 1.0 mg/m ³																	
TSVOC		< 0.1 mg/m ³																	
TVOC without NIK		< 0.1 mg/m ³																	
R-value		< 1																	
Pentachlorophenol (wood based core layers)	not relevant																		
Formaldehyde (central core layer material/MDF)	E1																		
Release scenarios regarding BWR 3: IA1																			
^{a)} In accordance with Regulation (EC) No 1272/2008. ^{b)} Assessment based on the detailed manufacturers' statements on dangerous substances. ^{c)} Statement according to test report.																			

3.3 Protection against noise (BWR 5)

Essential characteristic	Performance
Sound absorption coefficient α_s test according to EN ISO 354:2003	NPA
Sound absorption characteristics α_p and α_w test according to EN ISO 11654:1997	NPA

3.4 Energy economy and heat retention (BWR6)

Essential characteristic	Performance
Thermal resistance test according to EN 12664:2001	NPA

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

For the products covered by European Assessment Document 210058-00-0504 the applicable European legal act is: Decision 1998/437/EC for internal and external wall and ceiling finishes.

System 3 is to be applied with regard to the content, emission and/or and release of dangerous substances.

In addition, with regard to reaction to fire including propensity to undergo continuous smouldering, for products covered by European Assessment Document 210058-00-0504 the applicable European legal acts are: the aforementioned Decision as amended by Decision 2001/596/EC.

The system(s) is (are): 1, 3 or 4 (system 1 in case of classes A1 to C; system 3 in case of classes D and E; system 4 in case of class F).

Based on the determined test performance specified in clause 3.1, system 3 is to be applied with regard to reaction to fire.

For other uses than specified above the system is: 4

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with Deutsches Institut für Bautechnik.

Issued in Berlin on 12 March 2021 by Deutsches Institut für Bautechnik.

Dr. Astrid Gräff
Head of Section

beglaubigt:
Tykiel

Trade name of the construction product

Annex 1

"MEISTERPaneele"

Table - Dimensions, thicknesses and weights of the products

Product-name	MEISTERPaneele						
Kollektion	terra DP 200	terra DP 250	tertio DP 200	tertio DP 250	bocado DP 200	bocado DP 250	bocado DP 300
Width [mm]	200	250	200	250	200	250	300
Length [mm]	1280 2050 2600 3300 4100	1280 2050 2600 3300 4100	1280 2600	1280 2600	1280 2050 2600 3300 4100	1280 2050 2600 3300 4100	1280 2600
Thickness [mm]	12	12	9,5	9,5	12	12	12
Area weight [g/m ²]	8,3	8,3	6,7	6,7	8,4	8,4	8,4
Joint	Invisible joint (rounded edges)	Discreet invisible-joint (rounded edges)	Invisible joint (rounded edges)	Invisible joint (rounded edges)	Invisible joint (rounded edges)	Discreet invisible-joint (rounded edges)	3 mm shadow joint
Assembly method	Tongue and groove connection for fastening with screw clamps on wooden slats or with mounting clamps on a metal slat profile	Tongue and groove connection for fastening with screw clamps on wooden battens or with mounting clamps on a metal batten profile	Tongue and groove connection for fastening with screw clamps on wooden slats	Tongue and groove connection for fastening with screw clamps on wooden slats	Tongue and groove connection for fastening with screw clamps on wooden slats or with mounting clamps on a metal slat profile	Tongue and groove connection for fastening with screw clamps/ special screws on wooden laths or with mounting brackets on a metal lath profile	Tongue and groove connection for fastening with screw clamps/ special screws on wooden laths or with mounting brackets on a metal lath profile