

Approval body for construction products
and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and
Laender Governments



European Technical Assessment

ETA-22/0151
of 13 June 2022

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the
European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

"SIBRALIT DX" and "FLAMMOPLAST KS 3"

Product family
to which the construction product belongs

Intumescent products for fire sealing and fire stopping
purposes

Manufacturer

Flamro Brandschutz-Systeme GmbH
Glüsinger Straße 86
21217 Seevetal
DEUTSCHLAND

Manufacturing plant

1

This European Technical Assessment
contains

6 pages including 1 annex which forms an integral part of
this assessment

This European Technical Assessment is
issued in accordance with Regulation (EU)
No 305/2011, on the basis of

EAD 350005-00-1104, edition May 2015

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

Specific Part

1 Technical description of the product

Object of this European technical assessment (ETA) are the intumescent, chemically identical construction products "SIBRALIT DX" and "FLAMMOPLAST KS 3".

In case of fire, exposed to high temperatures the intumescent products expand the intumescent products and generate foam. This foam seals joints and gaps, closes voids and openings and restricts this way the passage and propagation of heat, smoke, flames or any combination of them.

The construction products "SIBRALIT DX" and "FLAMMOPLAST KS 3" do not generate essential expansion pressure during the foaming reaction.

The construction products "SIBRALIT DX" and "FLAMMOPLAST KS 3" are viscous, non-halogen, white, water-based dispersions, which essentially consist of intumescent substances and binder. They are preferably delivered in cartridges.

The technical characteristics relevant for the fire sealing and fire stopping effect of the construction products "SIBRALIT DX" and "FLAMMOPLAST KS 3" are given in Annex 1.

2 Specification of the intended use in accordance with the applicable European assessment Document (EAD)

The construction products "SIBRALIT DX" and "FLAMMOPLAST KS 3" are assessed on the basis of EAD N° 350005-00-1104, edition May 2015¹ as intumescent products for fire sealing and fire stopping purposes without specific final use (IU 1).

The construction products "SIBRALIT DX" and "FLAMMOPLAST KS 3" are intended to be used as essential components in, between or on construction products, construction elements, kits and special constructions which meet requirements concerning the safety in case of fire e.g. in pipe and cable penetration seals or on the surface of construction elements. In case of fire, the product delays the heat transfer through fire resistant construction elements, assemblies or special constructions by expanding under the impact of high temperatures and restricts the spread of fire.

The performance "resistance to fire" shall be tested for the specific final use, if requested.

The performance given in Section 3 is only valid when the intumescent construction products "SIBRALIT DX" and "FLAMMOPLAST KS 3" will be used considering the remarks and the boundary conditions of clause 3.2.

The tests and assessment methods on which this European Technical Assessment is based lead to an assumption of working life of the intumescent construction products "SIBRALIT DX" and "FLAMMOPLAST KS 3" in final use of at least 10 years.

The indication given on the assumed working life cannot be interpreted as a guarantee given by the producer, because it is essentially determined of the use conditions in final use of the works.

¹ Official Journal of the EU N° C 378/02 of 13 November 2015

3 Performance of the products and references to the methods used for the assessment

3.1 Safety in case of fire (BWR 2)

3.1.1 Reaction to fire

Essential characteristic	Performance
Reaction to fire	in accordance with EN 13501-1 ² ; class E

3.1.2 Resistance to fire

The performance "Resistance to fire" shall be demonstrated separately for the intended final use if requested.

3.2 General aspects

The evidence of durability is part of testing the basic works requirements and the achievement of the performance assessed. The durability is only presumed, if the provisions for the intended use are considered.

The assessment of the durability regarding to the product's fire safety performance was done for climatic use conditions of type Z₂ - dry indoor frost-protected use and of type Z₁ – frost protected indoor use at relative humidity of above 85 % temporarily and re-drying condensation in accordance with EAD Nr. 350005-00-1104, clause 1.2.2.

Conclusion:

The identical intumescent construction products "SIBRALIT DX" and "FLAMMOPLAST KS 3" may be used permanently in dry, frost-protected rooms also with changing relative humidity without having to fear essential changes in the relevant fire sealing and fire stopping properties and the resulting performance.

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with the European Assessment Document EAD No 350005-00-1104 the Decision of the commission N° 1999/454/EC of 22 June 1999 (OJ of the EU L 178 of 14 July 1999, p 42), amended by EC Decision 2001/596/EC of 8 January 2001 (OJ of the EU L 209 of 2 August 2001, p 33) is the legal basis for the determination of the AVCP system. So system 1 applies for the assessment and verification of constancy of performance (AVCP) (see Annex V in conjunction with Article 65 (2) of the Regulation (EU) N° 305/2011) according to the following table:

Product	Intended use	Characteristic	System
"SIBRALIT DX" "FLAMMOPLAST KS 3"	Components effective in the view of safety in case of fire used in construction products, construction elements, kits and special constructions	- Reaction to fire - properties relevant for the fire sealing and fire stopping effect	1

² EN 13501-1:2007

Fire classification of construction products and building elements, Part 1 Classification using test data from reaction to fire tests of the products

English translation prepared by DIBt

5 Technical details necessary for the implementation of System 1 for the Assessment and verification of constancy of performance (AVCP), as provided for in the applicable European Assessment Document

The technical details necessary for the implementation of the system of Assessment and Verification of Constancy of Performance are laid down in the control plan (confidential part of this ETA) deposited at Deutsches Institut für Bautechnik.

Issued in Berlin on 13 June 2022 by Deutsches Institut für Bautechnik

Christina Pritzkow
Head of Department

beglaubigt:
Dr.-Ing. Dierke

ANNEX 1

**CHARACTERISTICS RELEVANT FOR THE FIRE SEALING AND FIRE STOPPING
EFFECTS OF THE CONSTRUCTION PRODUCTS**

"SIBRALIT DX" and "FLAMMOPLAST KS 3"

Characteristics	Range and tolerances	Test method
Density (as delivered)	1200 kg/m ³ to 1385 kg/m ³	see control plan
Content of non-volatile components (fresh)	65,0 % ± 5 %	
Loss of mass at a certain temperature (hardened)	61,0 % ± 5 % (at 400 °C for 30 minutes)	
Expansion ratio	35,0 to 55,0 (at 400 °C without a top load for 30 minutes, sample thickness ca. 2 mm)	

The product does not develop remarkable expansion pressure during foaming.
The chemical reaction starts at approximately 250 °C.