

Public-law institution jointly founded by the federal states and the Federation

European Technical Assessment Body  
for construction products



## European Technical Assessment

ETA-24/0098  
of 16 April 2024

English translation prepared by DIBt - Original version in German language

### General Part

Technical Assessment Body issuing the European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

H 30-1

Product family to which the construction product belongs

H 30-1

Manufacturer

Hörmann KG Verkaufsgesellschaft  
Upheider Weg 94  
33803 Steinhagen

Manufacturing plant

HÖRMANN KG Freisen  
Bahnhofstraße 43  
66629 Freisen

This European Technical Assessment contains

10 pages including 6 annexes which form an integral part of this assessment

This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of

020029-00-1102

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

## Specific Part

### 1 Technical description of the product

The subject of this European technical assessment are internal pedestrian fire resisting and/or smoke control single leaf doors "H 30-1", made of steel.

The products with the classification EI<sub>2</sub> 30-C5 S<sub>a</sub> and EI<sub>2</sub> 30-C5 S<sub>200</sub> involve those which are used manually, opening and self-closing as a normal mode of operation. They can also be normally held open but self-close in the event of fire or smoke.

The fire resisting and/or smoke control doors shall be designed:

- using steel plates featuring fire-resistant inlays;
- with building hardware;
- with a three-sided permanently elastic seal (for fire resistance), optionally with a bottom seal;
- with a three-sided permanently elastic seal in conjunction with a soil liner (for smoke control).

The system setup is given in Annexes 1 to 6.

### 2 Specification of the intended use in accordance with the applicable European Assessment Document

Fire resisting and/or smoke control doors are used internally as closures in fire resisting walls and/or for escape routes. The products can be used as internal fire resisting and/or smoke control single and double leaf doors in internal walls.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the fire resisting and/or smoke control doors at least 15 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

The performances given in Section 3 are only valid if the products are used in compliance with the specifications and conditions given in Annexes 1 to 6.

### 3 Performance of the product and references to the methods used for its assessment

#### 3.1 Safety in case of fire (BWR 2)

Essential characteristic	Performance
Reaction to fire of components acc. to EN 13501-1	Steel plate A1
	Insulation A1
	Gypsum plaster board A2
	Intumescent material B1
Resistance to fire acc. to EN 13501-2	EI <sub>2</sub> 30
Smoke control acc. to EN 13501-2	S <sub>a</sub> /S <sub>200</sub>

### 3.2 Safety and accessibility in use (BWR 4)

Essential characteristic	Performance
Self-closing acc. to EN 13501-2	C
Ability to release	"released"
Durability of the ability to release	"release maintained"
Durability of self-closing against degradation (cycling testing) acc. to EN 13501-2	5
Durability of self-closing against ageing (corrosion)	"achieved"
Impact resistance acc. to EN 13049	No performance assessed
Strength requirements	No performance assessed

### 3.3 Sustainable use of natural resources (BWR 7)

For the sustainable use of natural resources no performance was investigated for this product.

### 4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with EAD No. 020029-00-1102, the applicable European legal act is: 1999/93/EU.  
The system to be applied is: 1

### 5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with Deutsches Institut für Bautechnik.

Issued in Berlin on 16 April 2024 by Deutsches Institut für Bautechnik

Christina Pritzkow  
Head of Section

*beglaubigt:*  
Fritzsche

Annexes 2 to 6 contains internal single leaf doors "H30-1" (pivot doors) with the classification EI<sub>2</sub> 30-C5 S<sub>a</sub> and EI<sub>2</sub> 30-C5 S<sub>200</sub>.

The fire resisting and/or smoke control doors are made of steel plates and fire-resistant inlays with building hardware.


Fire resisting doors are made with a three-sided permanently elastic seal, optionally with a bottom seal.

Fire resisting and/or smoke control doors are made with a three-sided permanently elastic seal in conjunction with a bottom seal.

The single leaf "H30-1" doors with the classification EI<sub>2</sub> 30-C5 S<sub>a</sub> and EI<sub>2</sub> 30-C5 S<sub>200</sub> are proved as internal fire resisting and/or smoke control single doors in internal walls/on internal components:

- solid wall of masonry with an overall density of  $\geq 1800 \text{ kg/m}^3$  and a thickness  $\geq 100 \text{ mm}$  or
- solid wall of masonry with an overall density  $\geq 600 \text{ kg/m}^3$  and a thickness  $\geq 115 \text{ mm}$  or
- assembly walls of fire resistance class EI 30 - in construction with wooden- or steel supports and paneling on both sides with plasterboard with a thickness  $\geq 100 \text{ mm}$  or
- covered steel supports or -beams of the fire resistance class EI 30, provided that they are connected to room-enclosing components that are at least equally fire-resistant over their entire length or height with a thickness  $\geq 100 \text{ mm}$ .

H 30-1	Annex 1
Generally	



All dimensions in mm


DIN right as shown,  
DIN left mirror-image.

	Ordering size		Clear opening		Overall frame size	
	width from-till	height from-till	width from-till	height from-till	width from-till	height from-till
H30-1	562.5-1125	1687.5-2250	480.5-1043	1645.5-2208	626.5-1189	1718.5-2281
escape door	957-1125	2042-2250	875-1043	2000-2208	1021-1189	2073-2281

H 30-1

Summary

Annex 2




(\*1)- Applies to doors on escape routes

H 30-1

Horizontal section

Annex 3




H 30-1

Vertical section

Annex 4





1-Construction / Spring Hinges acc. to EN 1935/DIN 18272

2-Handles acc. to EN 1906 / DIN 18273

2a-Panic bar- or push bar acc. EN 1125 tested acc. to 1634

3-Door closer face fixed acc. to 1154

4-Electric door opener

5-Escape door opener with latch-lock

6-Lock acc. to EN 12209/ EN 179/ EN 1125

7-Magnetic contact, alarm contact


Various:

- Additional bolt/latch lock
- Holding magnet
- Bolt- switch contact
- Steel or aluminium push plates, kick plates and bumpers
- Door dampers

H 30-1

Equipment

Annex 5



H 30-1

Frame

Annex 6