

Public-law institution jointly founded by the
federal states and the Federation

European Technical Assessment Body
for construction products



European Technical Assessment

ETA-13/0217
of 11 December 2025

English translation prepared by DIBt - Original version in German language

Technical Assessment Body issuing the
European Technical Assessment:

Trade name of the construction product

Product family
to which the construction product belongs

Manufacturer

Manufacturing plant

This European Technical Assessment
contains

This European Technical Assessment is
issued in accordance with Regulation (EU)
No 305/2011, on the basis of

This version replaces

Deutsches Institut für Bautechnik

joint filling rope "SG 300"

linear joint and gap seals

Rex Industrie-Produkte
Graf von Rex GmbH
Großaltdorfer Straße 59
74541 Vellberg
DEUTSCHLAND

1

9 pages including 4 annexes which form an integral part
of this assessment

EAD 350141-00-1106

ETA-13/0217 issued on 12 May 2014

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

Specific Part

1 Technical description of the product

SG 300 is a flexible and elastic joint filling rope made of mineral fibres with a braid of textile glass yarn.

SG 300 is produced in seven different diameters.

For further product properties, see Annex A.

Details of the material specifications and the manufacturing process of SG 300 are deposited with the Deutsches Institut für Bautechnik.

2 Specification of the intended use in accordance with the applicable European assessment Document

SG 300 is assessed in accordance with EAD Nr. 350141-00-1106¹.

SG 300 is used for sealing horizontal and vertical linear joints (structural joints as stepped joints and linear butt joints) with or without shear stress between fire-resistant separating rigid walls and floors.

SG 300 is intended to maintain or reinstate the fire resistance performance of separating building elements where they are interrupted or separated by joints.

The maximum permitted joint width is 55 mm.

The maximum lateral stretching capability of SG 300 is 7.4 %.

SG 300 is not intended for load transmission.

The performances given in section 3 are only valid if the joint filling rope is used in compliance with

- The specifications and conditions given in Annex B
- The manufacturer's instructions according to section 5.

The verifications and assessment methods on which this European Technical Assessment is based lead the assumption of working life of the joint filling rope SG 300 of 25 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and references to the methods used for its assessment

3.1 Safety in case of fire (BWR 2)

Essential characteristic	Performance
reaction to fire	class A1 in accordance with EN 13501-1
resistance to fire	classes in accordance with EN 13501-2 See Annex B

¹ OJ C 417/07 of 16. 11. 2018; p. 24, EAD Nr. 350141-00-1106 „Linear joint and gap seals“, Version September 2017

3.2 Hygiene, health and the environment (BWR 3)

Content, emission and/or release of dangerous substances	
Substances classified as Carc. 1A/1B ^{a)}	The product does not contain these classified substances actively used. ^{b), c)}
Substances classified as Muta. 1A/1B ^{a)}	
Substances classified as Acute Tox. 1, 2, 3; Repr. 1A/1B; STOT SE 1 and STOT RE 1 ^{a)}	
Release scenarios regarding BWR 3: IA1, IA2	
<p>^{a)} In accordance with Regulation (EC) No 1272/2008.</p> <p>^{b)} Assessment based on the detailed manufacturers' statements on dangerous substances.</p> <p>^{c)} Active use is the targeted use of substances to achieve specific product properties. Substances that are present as impurities and/or as a secondary component in the product are therefore not to be regarded as "actively used".</p>	

3.3 Safety and accessibility in use (BWR 4)

No performance determined.

3.4 Protection against noise (BWR 5)

No performance determined.

3.5 Energy economy and heat retention (BWR 6)

No performance determined.

3.6 General aspects

The verification of durability is part of testing the essential characteristics.

In accordance with EAD Nr. 350141-00-1106¹, SG 300 can be used under the following final use conditions, without any essential change in the properties relevant for the fire protective effect and the resulting performance:

Type Y₁: intended for use at temperatures below 0 °C with casual exposure to UV but no exposure to rain.

Type Y₂: intended for use at temperatures below 0 °C, but with no exposure to rain or UV radiation.

Type Z₁: intended for use in internal conditions with humidity equal to or higher than 85 % RH, excluding temperatures below 0 °C (no exposure to frost or changing frost-thaw but permanent or alternating condensation)

Type Z₂: intended for use in internal conditions with humidity lower than 85 % RH, excluding temperatures below 0 °C.

Durability is only ensured if the specifications of intended use according to Annex B and the manufacturer's instructions according to section 5 are taken into account.

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with EAD Nr. EAD 350141-00-11061, the applicable European legal act is: 1999/454/EC².

The system of assessment and verification of constancy of performance (AVCP) (see annex V and article 65, paragraph 2 to Regulation (EU) Nr. 305/2011) is: **System 1** as given in the following table:

product	intended use	level(s) or class(es)	AVCP-System
joint filling rope "SG 300"	sealing of joints between fire-resistant separating building elements	any	1

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with Deutsches Institut für Bautechnik.

The manufacturer shall provide installation instructions on every construction product according to this ETA containing at least the following information:

- type, properties (minimum thickness, density) and fire resistance of the building elements in which the joint filling rope may be installed
- description or graphic presentation of the proper installation (number of layers and arrangement of the joint filling rope depending on the type of the building element, the intended fire resistance and the width of the joints).

The manufacturer shall also provide instructions on processing, packaging, transport, storage and use, maintenance and repair of the construction product.

Issued in Berlin on 11 Dezember 2025 by Deutsches Institut für Bautechnik

Johanna Held
Head of section

beglaubigt:
Haberstroh

² Decision of the European commission N° 1999/454/EC of 22.06.1999 (OJ L 178/52 of 14.07.1999, p. 3), amended by decision N° 2001/596/EC of 08.01.2001 (OJ L 209/33 of 02.08.2001, p. 2).

Product description

Table A.1 shows the dimensions and the nominal bulk density of the joint filling rope SG 300.

Table A.1

nominal diameter* [mm]	joint width b [mm]	bulk density [kg/m ³]
12	≤ 10	≥ 440
15	≤ 12	≥ 288
20	≤ 17	≥ 224
30	≤ 27	≥ 208
40	≤ 37	≥ 196
50	≤ 47	≥ 224
60	≤ 55	≥ 200

* nominal diameter depending on the joint width to be sealed

joint filling rope "SG 300"

Product description

Annex A

Separating building elements

The joint filling rope SG 300 is used for sealing linear joints between the following separating building elements:




- rigid walls and floors
 - aerated concrete, concrete, reinforced concrete or masonry with a minimum density of 700 kg/m³ (see Table B.2)
 - concrete, reinforced concrete or masonry with a minimum density 2400 kg/m³ ± 20 % (see Table B.3)

The minimum thickness of the separating building elements shall be 150 mm (see Table B.2 and B.3). The separating building elements shall be classified according to EN 13501-2 for the required fire resistance period.

According to table B.1, the joint filling rope SG 300 is used

- in horizontal joints between fire-resistant separating floors or between walls and floors (A)
- in vertical joints between fire-resistant separating walls (B)
- in horizontal joints between fire-resistant separating floors and walls (C).

Table B.1

Application (A)	Application (B)	Application (C)
 <p>joint filling rope with/without shear stress</p> <p>joint filling rope</p> <p>Ceiling/ Floor</p> <p>joint filling rope</p> <p>Wall</p>	 <p>joint filling rope</p> <p>joint filling rope</p> <p>wall</p>	 <p>joint filling rope with/without shear stress</p>

For the number of layers and the arrangement of the joint filling rope, see Table B.2 and B.3.

joint filling rope "SG 300"

Intended Use

Specification of the intended use relating to the verified fire resistance
- Building elements -

Annex B 1

Design and arrangement of the joint filling rope

The joint filling ropes shall be arranged overlapped. For joints

- with a single-layer arrangement the joint filling ropes shall overlap a minimum of 100 mm,
- with a multi-layer arrangement, the joints of the joint filling rope shall be arranged 500 mm shifted to each other.

For joints with vertical shear stress, the joint filling ropes shall be arranged with a minimum distance of 25 mm to the outer edge of the building element. For arrangement and number of layers of the joint filling rope, see Table B.2 and B.3.

Tabelle B.2

Overview of the fire-resistant designs for the arrangement in rigid wall constructions and rigid floor constructions with a minimum thickness of 150 mm and a minimum density of 700 kg/m ³				
application	joint width [mm]	SG 300 number of layers and arrangement		classification fire resistance
(A) (B)	10 to 55	1	any arrangement within the joint	EI 90-V-X-F-W 10 to 55 EI 90-H-X-F-W 10 to 55
(A) (B)	55	1		EI 120-V-X-F-W 55 EI 120-H-X-F-W 55

Table B.3

Overview of the fire-resistant designs for the arrangement in rigid wall constructions and rigid floor constructions with a minimum thickness of 150 mm and a minimum density of 2400 kg/m ³ ± 20 %				
application	joint width [mm]	SG 300 number of layers and arrangement		classification fire resistance
(A) (C)	10 to 50	2	One strip on each side, minimum distance 25 mm to the outer edge of the building element	EI 90-H-M 65-F-W 10 to 50
(A) (B)	10 to 55	2	layers arranged close together, any arrangement within the joint	EI 120-V-X-F-W 10 to 55 EI 120-H-X-F-W 10 to 55
(A) (B)	10 to 27	4		EI 180-V-X-F-W 10 to 55 EI 180-H-X-F-W 10 to 55
	37 to 55	3		

* The maximum shear stress of horizontal joints is restricted to $\Delta h = 100$ mm compared to the installed condition.

For the choice of the suitable joint filling rope (nominal diameter depending on the joint width to be sealed) see Table A.1.

joint filling rope "SG 300"	Annex B 2
Intended Use Specification of the intended use relating to the verified fire resistance - Design and arrangement -	

List of reference documents

- EAD 350141-00-1106 Fire stopping and fire sealing products - Linear joint and gap seals, Version September 2017
- EN 13501-1:2019-05 Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests
- EN 13501-2:2023-12 Fire classification of construction products and building elements - Part 2: Classification using data from resistance tests, excluding ventilation services
- EN ISO 1182:2020-06 Reaction to fire tests for products – non-combustibility test
- EN ISO 1716:2018-10 Reaction to fire tests for products – Determination of the gross heat of combustion (calorific value)
- EN 1363-1:2020-05 Fire resistance tests – Part 1: General requirements
- EN 1366-4:2021-05 Fire resistance tests for service installations – Part 4: Linear joint seals

joint filling rope "SG 300"

Reference documents

Annex C