

Public-law institution jointly founded by the federal states and the Federation

European Technical Assessment Body  
for construction products



## European Technical Assessment

ETA-20/0613  
of 14 November 2025

English translation prepared by DIBt - Original version in German language

### General Part

Technical Assessment Body issuing the European Technical Assessment:

Deutsches Institut für Bautechnik

Trade name of the construction product

System FWK Plus

Product family to which the construction product belongs

Service ducts and shafts

Manufacturer

Tehalit GmbH  
Seebergstraße 37  
67716 Heltersberg  
DEUTSCHLAND

Manufacturing plant

Tehalit GmbH

This European Technical Assessment contains

34 pages including 29 annexes which form an integral part of this assessment

This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of

350003-01-1109

This version replaces

ETA-20/0613 issued on 3 December 2020

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

## Specific Part

### 1 Technical description of the product

This European Technical Assessment (ETA) covers the "System FWK Plus" kit for the assembly of the "System FWK Plus" electrical service duct.

The kit, depending on the project, consists of the following components:

- a) - prefabricated special connecting pieces in four-sided, rectangular design in various dimensions – such as moulded duct parts in two pieces and length adapters – essentially made of sheet steel and an inlay of an intumescent material,
  - coupling pieces made of sheet steel with seals,
  - barrier strip made of sheet steel (optional),
  - cable retaining clips
  - wall connection piece.
- b) - prefabricated rectangular special end caps made of sheet steel,
  - cable outlet(s) in the form of cable glands, cable sleeves, a gypsum fibreboard or intumescent/ablative building materials
- c) - accessories such as fasteners, suspensions and construction products for sealing or closing remaining openings and gaps.

Details on the material and dimensions of the prefabricated connecting pieces and end caps, the cable outlets as well as the accessories are deposited with DIBt.

The components and the system structure of the kit are shown in Annex 1.

Further information on the components of the kit and its fire protection characteristics is provided in Annexes 2 to 18.

Note:

The characteristics listed may serve as a guide for the implementation of the manufacturer's factory production control system.

### 2 Specification of the intended use in accordance with the applicable European Assessment Document

The "System FWK Plus" kit is intended for the assembly of the fire-resistant electrical service duct "System FWK Plus" for inside use.

In the case of fire exposure from the inside or outside, fire resistant service ducts prevent, when installed, the spread of fire from one fire compartment to another across the separating wall.

This ETA has served to verify the fire resistance of the service duct "System FWK Plus" assembled from the "System FWK Plus" kit in accordance with the specifications set out in Annexes 19 to 27 of this ETA.

The performances given in Section 3 of this ETA apply to the products specified by the manufacturer and used in the assessment procedure and to the variants of the electrical service ducts tested or listed in the European Assessment Document on which this ETA is based (e. g. with regard to the design, cross-section, type and arrangement of the electrical service ducts and the configuration with cables and services, type and position of cable outlets).

The testing and assessment methods on which this ETA is based lead to the assumption of a working life of installed fire resistant "System FWK Plus" service duct, assembled from the kit, of at least 10 years. The indications given on the working life cannot be interpreted as a guarantee given by the manufacturer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

The kit in end use conditions is suitable for fire-resistant electrical service ducts of use category Z<sub>2</sub> in accordance with EAD No. 350003-01-1109, Annex E.1, with no essential changes to the fire protection characteristics to be expected.

Fire resistant service ducts "System FWK Plus" may thus be exposed to the conditions of use category Z<sub>2</sub> (application in frost-free interiors with relative humidity below 85%).

Durability is ensured if the specifications for the intended use in accordance with Annexes 1 to 27 and the manufacturer's instructions are taken into account.

### 3 Performance of the products and references to the methods used for their assessment

#### 3.1 Safety in case of fire (BWR 2)

No.	Essential characteristic	Performance
1	Reaction to fire of the components	Class(es) in accordance with EN 13501-1 See Annexes 3 to 7
2	Propensity to undergo continuous smouldering of kit components	No performance assessed (NPA)
3	Fire resistance of the service duct	The fire resistance depends on the design/installation of the electrical service duct. Details of the variants tested and listed in the European Assessment Document and the associated fire resistance classes are given in Annexes 19 to 27.
4	Durability of the service duct	
4.1	Fire protective performance <sup>1</sup>	Expansion ratio $f_x$ 17.0 to 22.0 Expansion pressure $p_{ex} > 0.5 \text{ N/mm}^2$
4.2	Resistance to the effects of higher temperatures <sup>1</sup>	Expansion ratio $f_x$ 17.0 to 22.0 Expansion pressure $p_{ex}$ 0.5 N/mm <sup>2</sup> to 0.85 N/mm <sup>2</sup>
4.3	Resistance to the effects of direct contact with metals and plastics (rigid PVC, PE) <sup>1</sup>	Expansion ratio $f_x$ 17.0 to 22.0 Expansion pressure $p_{ex}$ 0.5 N/mm <sup>2</sup> to 0.85 N/mm <sup>2</sup>
4.4	Adhesion between the intumescent material and the substrate <sup>1</sup>	NPA
4.5	Resistance to the effects of constant low temperatures (permanent frost) <sup>1</sup>	Expansion ratio $f_x$ 17.0 to 22.0 Expansion pressure $p_{ex}$ 0.5 N/mm <sup>2</sup> to 0.85 N/mm <sup>2</sup>
4.6	Heat insulation efficiency (ablative component)	NPA <sup>2</sup>

<sup>1</sup> intumescent inlay

<sup>2</sup> not applicable to the kit

**3.2 Hygiene, health and the environment (BWR 3)**

Essential characteristic	Performance
<b>Content and/or release of dangerous substances</b>	
Substances classified as Carc. 1A/1B <sup>a</sup>	The product does not contain any of these dangerous substances that are actively used. <sup>b</sup>
Substances classified as Muta. 1A/1B <sup>a</sup>	
Substances classified as Acute Tox. 1, 2, 3; Repr. 1A/1B; STOT SE 1 and STOT RE 1 <sup>a</sup>	
SVOC and VOC	NPA
Release scenarios regarding BWR 3 in accordance with EOTA TR 034: IA1, IA2	

a) In accordance with Regulation (EC) No. 1272/2008.

b) The assessment was based on the manufacturer's declaration substantiated by detailed information on the product composition.

**4 Assessment and verification of constancy of performance system (AVCP) applied, with reference to its legal basis**

In accordance with the European Assessment Document (EAD) No. 350003-01-1109, the legal basis is 1999/454/EC, as amended by 2001/596/EC.

The system to be applied is: 1.

In addition, the European legal basis for reaction to fire for products<sup>1</sup> covered by this EAD is: 1999/454/EC.

The following systems are to be applied: 1, 3 or 4.

**5 Technical details necessary for the implementation of the AVCP system as provided for in the applicable EAD**


The technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with DIBt.

Issued in Berlin on 14 November 2025 by Deutsches Institut für Bautechnik

Amelung-Sökezoğlu  
Head of Section

*beglaubigt:*  
Johannes Kopp


<sup>1</sup> including smouldering behaviour



System FWK Plus

Properties and performance criteria of the kit components:  
System overview

Annex 1



System FWK Plus

Properties and performance criteria of the kit components:  
Connecting pieces overview

Annex 2

**Table 1 Prefabricated connecting pieces**

No.	Description/dimensions	Design/reaction to fire	Annex ETA
1	<b>Connecting piece<sup>1</sup></b> consisting of bottom and top part, in various designs: - straight duct piece, internal corner, external corner, flat angle, T-piece, cross piece, levelling piece  <u>External dimensions:</u> Width: 60 to 250 mm Height: 60 to 100 mm Length: 100 to 3000 mm	Galvanised sheet steel <sup>1</sup> of steel grade DX51D or DX52D, material number 1.0226 or 1.0350, in accordance with EN 10143, EN 10346  Or: Stainless sheet steel <sup>1</sup> X5CrNi1810, material number 1.4301, in accordance with EN 10088-2 Sheet thickness: 1 mm Reaction to fire class A1 in accordance with Decision 96/602/EC	2, 8 and 9
		Optionally sheet steel, sheet thickness 1 mm, with external epoxy-polyester powder coating, thickness $\leq 0.15$ mm <sup>1</sup> Reaction to fire class A2-s1, d0 in accordance with EN 13501-1	
		Intumescent building material, deposited with DIBt <sup>1</sup> Thickness 1.2 mm Reaction to fire class B-s1, d0 in accordance with EN 13501-1	
2	<b>End cap<sup>1</sup></b>  <u>Dimensions:</u> Width: 60 to 250 mm Height: 60 to 100 mm	Galvanised or stainless sheet steel, as in no. 1 Sheet thickness: 1 mm	2
		2 to 4x button head screw, self-tapping 5x10, steel case hardened, deposited with DIBt <sup>1</sup> Reaction to fire class A1 in accordance with Decision 96/602/EC	
3	<b>Coupling piece<sup>1</sup></b> consisting of bottom and top part  suitable for dimensions of connecting pieces	Galvanised or stainless sheet steel, as in no. 1 Sheet thickness, top part: 1 mm Sheet thickness, bottom part: 1.5 mm	10
		Intumescent building material, as in no. 1 <sup>1</sup>	
		EPDM cellular rubber seal (in top parts), deposited with DIBt <sup>1</sup> Width x height: 17 mm x 3 mm and 6 mm x 2 mm Reaction to fire class E in accordance with EN 13501-1 in joints between sheet steel components	
		2x button head screw M5x12, galvanised steel, 8.8, ISO 7380-2 Reaction to fire class A1 in accordance with Decision 96/602/EC	
4	<b>Length adapter<sup>1</sup></b> consisting of bottom part and top part  suitable for dimensions of connecting pieces in accordance with no. 1	Galvanised or stainless sheet steel, as in no. 1 Sheet thickness: 1.5 mm	11
		Intumescent building material, as in no. 1 <sup>1</sup> Thickness: 1.2 mm	
		EPDM cellular rubber seal, as in no. 3 <sup>1</sup>	
		2x button head screw M5x12, as in no. 3	

System FWK Plus

Characteristics and performance criteria of the kit components  
Description and reaction to fire performance of components of the connecting pieces – Part 1

Annex 3

**Table 1 – Continued**

No.	Description/dimensions	Design/reaction to fire	Annex ETA
5	<b>Wall connection piece</b> <sup>1</sup> consisting of wall connection plate and wall connection piece suitable for the dimensions of the connecting pieces in accordance with no. 1	Galvanised or stainless sheet steel, as in no. 1 Sheet thickness: 1,5 mm Optionally sheet steel, sheet thickness 1,5 mm, with external epoxy-polyester powder coating, as in no. 1	12
Intumescent building material, as in no. 1 <sup>1</sup>			
EPDM cellular rubber seal, 17 mm x 3 mm, as in no. 3 <sup>1</sup>			
Fire protection board, deposited with DIBt <sup>1</sup> Thickness: 8 mm Reaction to fire class A1 in accordance with EN 13501-1			
4x button head screw M5x12, as in no. 3 (only four-sided wall connector)			

<sup>1</sup> Geometry or material, position and cut in accordance with the specifications deposited with DIBt

System FWK Plus

Characteristics and performance criteria of the kit components  
Description and fire behaviour of components of the connecting pieces – Part 2

Annex 4

**Table 2 Construction products for sealing remaining openings and gaps (wall penetrations, cable inlets and outlets)**

No.	Description/dimensions	Design/reaction to fire of components	Annex ETA
6a	<b>Fire protection mortar</b> 'System Ignitect Z'	The composition is deposited with DIBt, Reaction to fire class A in accordance with Decision 96/603/EC	15, 18 and 25
6b	<b>Fire protection foam</b> 'Silikon-Brandschutzschaum 2K' and 'Formstück KR 150'	in accordance with ETA-17/0458 of 7 July 2017 with declaration of performance no. 1 of 6 February 2019 Reaction to fire class E in accordance with EN 13501-1	15, 18 and 25
6c	<b>Fire protection pad</b> 'KBS Sealbags'	The composition is deposited with DIBt Reaction to fire class E in accordance with EN 13501-1	15 and 18
6d	<b>Fire protection stoppers and boards</b> 'System ISO-FLAME plugs and bricks S90'	Components made of impregnated PU soft foam and ablation coating according to ETA-18/0237 from 16.05.2018 Reaction to fire class E in accordance with EN 13501 1	15 and 18
6e	<b>Fire protection coating</b> 'PYRO-SAFE FLAMMOTECT A'	in accordance with ETA-14/0418 and with declaration of performance no. 01155-PYRO-SAFE-FLAMMOTECT-A of 27 January 2015 Reaction to fire class E in accordance with EN 13501-1	15 and 18
6f	<b>Fire protection putty</b> 'KBS Foamcoat HS'	in accordance with ETA-15/0657 and with declaration of performance no. 0761-CPR-0550 of 2 May 2017  Reaction to fire class E in accordance with EN 13501-1	17
6g	<b>Gypsum fibreboard</b> <u>Maximum dimension:</u> Width x height x depth 200 mm x 75 mm x 18 mm	Material: GF-I-W2-C1 in accordance with EN 15283-2, apparent density $1150 \pm 50 \text{ kg/m}^3$ Reaction to fire class at least A2-s1, d0 in accordance with EN 13501-1	17

System FWK Plus

Characteristics and performance criteria of the kit components  
Description and reaction to fire behaviour of construction products for sealing remaining openings and gaps (wall penetrations, cable inlets and outlets)

Annex 5

**Table 3 Accessories for the electrical service duct**

No.	Description/dimensions of the connecting pieces	Design/reaction to fire of components	Annex ETA
7	<b>Cable retaining clip</b> (in conjunction with no. 1)  <u>Width x length:</u> 60 mm x 25 mm 60 to 150 mm x 35 mm 150 to 250 mm x 45 mm	Galvanised or stainless sheet steel, as in no. 1 Sheet thickness: 1.5 mm	13
8a	<b>Barrier strip</b> (in conjunction with no. 1)  <u>Dimensions for the duct</u> Height: 60 to 100 mm Length: max. 3000 mm	Galvanised or stainless sheet steel, as in no. 1 Sheet thickness: 0.8 mm	14
8b	<b>Barrier strip adapter</b> (in conjunction with no. 1 and no. 8a)	Galvanised or stainless sheet steel, as in no. 1 Sheet thickness: 1.5 mm  Screws and nuts for suspended installation at least M6, steel, min. 8.8 in accordance with EN ISO 898-1/ EN 20898-2  Reaction to fire class A1 in accordance with Decision 96/602/EC	14
9	<b>Cable gland, brass, with lock nut</b>  <u>Dimensions:</u> M 25 to M 63	Material: brass in accordance with EN 60423 / EN 62444 Reaction to fire class A1 in accordance with Decision 96/603/EC	16
10	<b>Cable gland, plastic, with lock nut</b> for individual cables  <u>Dimensions:</u> M 25 to M 63	Material: PA6 polyamide in accordance with EN 60423 / EN 62444	16
11	<b>Cable sleeve</b> for cable diameter $\leq 16$ mm	Material: PVC, deposited with DIBt	16

System FWK Plus

Characteristics and performance criteria of the kit components  
Description and reaction to fire of accessories for the electrical service duct

Annex 6

**Table 4 Accessories for fastening**


No.	Description/dimensions of the connecting pieces	Design/reaction to fire of components	Annex ETA
12	<b>Wall bracket and suspension bracket</b>	Steel, galvanised/electrolytically galvanised, material number: 1.0330 Reaction to fire class A1 in accordance with Decision 96/603/EC	23 to 26
13	<b>Screws and nuts</b> for fastening wall bracket to suspension brackets	Steel in accordance with EN ISO898-1/EN 20898-2, min. 8.8 Reaction to fire class A1 in accordance with Decision 96/603/EC	23 to 26
14	<b>C-profile mounting rail</b> <u>Dimensions</u> 25 x 50 mm (height x width), thickness 2.5 mm	Material: steel 1.0330 / 1.0332 in accordance with EN 10130 / EN 10111 Reaction to fire class A1 in accordance with Decision 96/603/EC	23 to 26
15	<b>Threaded rod M10</b> for suspension by means of crossbars and support for wall bracket tip	Material: galvanised/electrolytically galvanised steel, min. 8.8 in accordance with EN ISO 225 Reaction to fire class A1 in accordance with Decision 96/603/EC	23 to 26
16	<b>Washer</b> (in conjunction with nos. 14 and 15) External diameter 30 mm, internal diameter 10.5 mm, thickness at least 1.25 mm	Material: steel, min. 8.8 in accordance with EN ISO 7093-1 Reaction to fire class A1 in accordance with Decision 96/603/EC	23 to 26
17	<b>Nut M10</b> (in conjunction with nos. 15 and 16)	Material: steel, min. 8.8 in accordance with ISO 4032 Reaction to fire class A1 in accordance with Decision 96/603/EC	23 to 26
18	<b>Screws and nuts M8</b> - for fastening duct pieces to C-profile rail (suspended or top-mounted), - for installation of gypsum fibreboard, see Annex 5, no. 6g and Annex 17	Steel in accordance with EN ISO898-1/EN 20898-2, min. 8.8 Reaction to fire class A1 in accordance with Decision 96/603/EC	17 and 23
19	<b>Washer</b> (in conjunction with nos. 14 and 18 for installation variant 4, see Annex 23) External diameter 30 mm, internal diameter 8.4 mm, thickness at least 1.25 mm	Material: steel, min. 8.8 in accordance with EN ISO 4759-3 Reaction to fire class A1 in accordance with Decision 96/603/EC	23
20	<b>Connector for C-profile rails</b>	Steel as in no. 1 (slot side); steel 1.0332 in accordance with EN 10111 (hole side) <sup>2</sup> Reaction to fire class A1 in accordance with Decision 96/603/EC	23

<sup>2</sup> Geometry in accordance with the specifications deposited with DIBt

System FWK Plus

Characteristics and performance criteria of the kit components  
Description and reaction to fire of accessories/fasteners

Annex 7



System FWK Plus

Properties and performance criteria of the kit components:  
Composition of connecting piece "Straight duct piece"; Accessories


Annex 8

Standard dimensions:  
(height x width [mm])

Duct 100x250



Duct 100x150




Duct 60x150



Duct 60x100



Duct 60x60




Intermediate sizes possible

System FWK Plus

Properties and performance criteria of the kit components:  
Duct dimensions


Annex 9



System FWK Plus

Properties and performance criteria of the kit components:  
Composition and arrangement coupling


Annex 10



System FWK Plus

Properties and performance criteria of the kit components:  
Composition cut blinding


Annex 11



System FWK Plus

Properties and performance criteria of the kit components:  
Composition wall connection piece (two, three and four-sides)

Annex 12




Intermediate sizes possible

System FWK Plus

Properties and performance criteria of the kit components:  
Design clamp

Annex 13


Duct with mounted barrier strip



Installation of barrier strip:


- direct wall/ceiling/floor mounting: fire protection approved fasteners, where appropriate, joint use of the fixing materials for the duct base
- suspended mounting: screw + nut at least M6, where appropriate, joint use of the fixing materials for the duct base

t=0.8mm



Barrier strip for duct  
Height 60 to 100

t=1.5mm




Barrier strip adapter

System FWK Plus

Properties and performance criteria of the kit components:  
Design and arrangement of barrier strip and barrier strip adapter (optional)

Annex 14




Dimensions in mm


System FWK Plus

Properties and performance criteria of the kit components:  
Composition and arrangement cable outlet through open connecting piece end


Annex 15



Distance between cable gland/cable grommet and separating wall according to Annex 20/21, paragraph 2.4



Example of a cable grommet made of PVC




Example of a metric screwed cable gland made of plastic or brass



System FWK Plus

Properties and performance criteria of the kit components:  
Cable outlet through screwed cable gland and cable grommet

Annex 16



Distance of cable inlet or outlet to separating wall according to Annex 20/21, paragraph 2.4




Dimensions in mm

System FWK Plus

Properties and performance criteria of the kit components:  
Cable outlet through gypsum fibreboard

Annex 17

Distance between cable inlet or cable outlet by means of the "cross-section reduction" fitting and separating wall according to Annex 20/21, paragraph 2.4



Hint:  
At least 100 mm overlap required.

Dimensions in mm

System FWK Plus

Properties and performance criteria of the kit components:  
Composition cross-section reduction

Annex 18

## 2 Resistance to fire

### 2.1 Classification in accordance with EN 13501-2

The resistance to fire depends on the design/installation of the electrical service duct as well as on the associated components. Within the framework of this ETA, the resistance to fire of an electrical service duct assembled from the 'System FWK Plus' kit was verified at a penetration through a separating lightweight partition in accordance with EN 1363-1 of resistance to fire class EI90 in accordance with EN 13501-2

- configured with steel cables, cables and services
- with inlets and outlets for cables and services.

The electrical service duct fulfils the requirements of resistance to fire classes EI 30 ( $h_o \leftrightarrow o$ ), EI 60 ( $h_o \leftrightarrow o$ ) and EI 90 ( $h_o \leftrightarrow o$ ) if the provisions of this ETA are met. Details of the variants tested and assessed in accordance with EAD 350003-01-1109 and the associated resistance to fire classes are listed below and in Annexes 20 to 27.

### 2.2 Separating elements

2.2.1 The electrical service duct has been verified for suspension from and direct fastening to rigid ceilings made of concrete, reinforced concrete or aerated concrete as well as for direct fastening to rigid walls made of masonry, concrete, reinforced concrete or aerated concrete – in each case with thicknesses in accordance with the structural requirements and depending on the required resistance to fire duration.

2.2.2 The electrical service duct has been verified for penetration through:

- a) rigid walls made of masonry, concrete, reinforced concrete or aerated concrete, thickness in accordance with structural requirements and depending on the required resistance to fire duration, but  $\geq 100$  mm
- b) Partitions
  - Thickness in accordance with structural requirements and depending on the required resistance to fire duration, but  $\geq 100$  mm and
  - design types 1), 2) or 3)
    - 1) Partitions with a steel substructure made of UW profiles (ceiling or floor profile) and CW profiles (stud profile) each 50 mm x 0.6 mm and
      - stud spacing  $\leq 625$  mm and
      - double-sided panelling made of at least two layers of  $\geq 12.5$  mm-thick cement- or gypsum-bonded boards, apparent density  $\geq 800$  kg/m<sup>3</sup>, reaction to fire class A1 or A2 in accordance with EN 13501-1 and
      - an internal insulation made of mineral wool from molten rock in accordance with EN 13162, thickness 40 mm, apparent density 100 kg/m<sup>3</sup>, reaction to fire class A1 in accordance with EN 13501-1
    - 2) Partitions as in 1) but without insulation or with an insulation differing from 1) but with reaction to fire class A1 in accordance with EN 13501-1
    - 3) Partitions with wooden substructure and
      - double-sided panelling as in 1)
      - with or without insulation
      - The distance between the opening through which the electrical service duct is fed and the wooden substructure shall be  $\geq 100$  mm. The cavities between the wall panelling, the wooden substructure and the opening reveal shall be tightly filled with mineral wool made of molten rock in accordance with EN 13162 of reaction to fire class A1 or A2 in accordance with EN 13501-1, over a depth of  $\geq 100$  mm.

System FWK Plus	Annex 19
Performance of the electrical service duct Resistance to fire Classification and information on the building components	

For partitions of types 2) and 3), the opening reveal shall be fitted with a surrounding reveal made of  $\geq 12.5$  mm-thick cement- or gypsum-bonded boards, apparent density  $\geq 800 \text{ kg/m}^3$ , reaction to fire class A1 or A2 in accordance with EN 13501-1.

2.2.3 The ceilings and walls shall meet at least the resistance to fire class of the electrical service duct and be classified in accordance with EN 13501-2 (EI 30, EI 60 or EI 90).

### 2.3 Configuration of the electrical service duct

The electrical service duct assembled from the kit has been verified for configuration with cables and services with an external diameter  $\leq 58$  mm, a copper cross-section of the single cable  $\leq 4 \times 185 \text{ mm}^2$  or with cable bundles  $\varnothing \leq 90$  mm as well as for their inlet or outlet from the duct.

The cables and cable bundles are held in the electrical service duct by means of cable retaining clips (see Annex 13), with which the connecting pieces are fitted at a maximum distance of 500 mm.

Depending on the application, the duct connecting pieces are fitted with a barrier strip (see Annexes 8 and 14), which is inserted and locked into the support on the bottom part of the duct. The barrier strip adapter is clamped under the fastening screws of the bottom part of the duct (see Annex 7, Table 4).

The permitted total weight of the configuration of the electrical service ducts with cables and services is limited to:

- 2.7 kg/m for the external dimensions height = 60 mm, width = 60 mm and
- 25 kg/m for the external dimensions height  $\leq 100$  mm, width  $\leq 250$  mm.

The specifications and information of Annexes 5 to 7, 15 to 17 and – if mineral wool is used to seal the remaining cross-section – of Annex 22 apply to the inlets or outlets of the cables and services. The outlet of the cables and services through the end cap in accordance with Annexes 2 and 3 has not been verified within the framework of this ETA.

For the reduction of the duct cross-section, the specifications and information given in Annexes 5 and 18 and – if mineral wool is used to seal the remaining cross-section – in Annex 22 shall apply.

### 2.4 Arrangement and fastening of the service duct

The electrical service duct has been verified for

- suspension from adjacent rigid ceilings using threaded rods  $\geq M10$  and mounting rails or
- suspension from adjacent rigid ceilings using ceiling hanger with a suspension bracket and threaded rod at the tip of the bracket or
- placement on brackets fastened to adjacent rigid walls with a threaded rod at the tip of the bracket or
- direct fastening to the rigid wall or rigid ceiling/floor

The execution is subject to Annexes 7 and 23 respectively.

The electrical service duct may be moved vertically within the storey (see Annex 1); separating ceilings shall not be penetrated. The ducts shall be fastened in accordance with the following provisions. For the arrangement of the cables and services in the duct the technical rules for electrical line systems at the place of application shall be observed; the distance between the cable retaining clips shall not exceed 500 mm.

An assessment of a change in the length of the electrical service duct due to operating conditions or fire exposure is not covered by this ETA.

The suspension devices and brackets including the threaded rods shall be made of steel and shall be dimensioned such that the calculated stresses do not exceed the values given in EN 1366-5, Table 5. The maximum suspension length shall be 1.50 m. EN 1366-5, Clause 13.4.2 shall be observed with regard to the elongation of the suspension devices or brackets.

System FWK Plus	Annex 20
Performance of the electrical service duct Resistance to fire Configuration, arrangement and fastening	

The threaded rods at the bracket tips shall be fastened with washers and nuts in accordance with Annex 7 so that they cannot slip out when loaded or exposed to fire.

When the duct is suspended, each direction-changing piece of the electrical service duct shall be suspended in the area of the connections. (For examples, see Annexes 15 and 18).

The suspension devices and/or brackets as well as the electrical service ducts (direct fastening) shall be fastened to the rigid ceilings by means of anchors with steel screws suitable for the intended use in accordance with a European Technical Assessment covering the fire protection performance and the associated steel screws in accordance with the structural requirements.

Fasteners with a European Technical Assessment suitable for the intended use shall be used for fastening the electrical service duct directly to rigid walls.

Electrical service ducts arranged directly on rigid walls and/or ceilings in accordance with Section 2.2.1 or in the corner area of these walls and ceilings shall be connected to the walls to be penetrated in accordance with Section 2.2.2 by means of three- or two-sided wall connection pieces in accordance with Annex 12 and shall be fastened using the aforementioned fasteners.

The spacings and distances of the fasteners shall be in accordance with the structural requirements, but shall at least comply with the specifications given in Table 5.

**Table 5 Spacing and distances of fasteners**

Type of fastener	Spacing
Electrical service ducts suspended from mounting rails	≤ 1200 mm
Electrical service ducts mounted on top of mounting rails or brackets	≤ 1500 mm
First suspension on both sides of the wall penetration	≤ 500 mm
Electrical service ducts fastened directly to the wall/ceiling	≤ 500 mm
Electrical service ducts fastened directly to the floor	≤ 1500 mm
First fastening on both sides of the wall penetration for electrical service ducts directly fastened to the wall or ceiling	≤ 250 mm
First suspension or fastening of cables and services upstream or downstream from cable inlets or outlets	≤ 100 mm

Furthermore, the distances listed in Table 6 shall be observed for the arrangement of the electrical service ducts:

**Table 6 Distances**

Description	Distance
Distance of the first connection of the connecting pieces from the separating wall penetrated by the electrical service duct	≥ 265 mm
Distance of the cable inlets or outlets from the separating wall penetrated by the electrical service duct	≥ 500 mm (Axial dimension)
Distance of the cable gland from the separating wall penetrated by the electrical service duct	≥ 350 mm (Axial dimension)
Distance between two electrical service ducts	≥ 100 mm

System FWK Plus	Annex 21
Performance of the electrical service duct Resistance to fire Fastening and distances	

## 2.5 Sealing of the remaining cross-section (annular gap) of the wall opening

The remaining cross-section (annular gap) around the electrical service duct at the penetration of separating walls in separate or continuous design in accordance with Annexes 25 and 26 shall be between 5 and 35 mm. If the electrical service duct is arranged directly on the separating rigid wall or in a room corner of the rigid building components, no gap is required on the duct sides adjacent to the respective rigid component.

The remaining cross-section (annular gap) shall be sealed with fire protection foam or fire protection mortar in accordance with Annex 5 or with materials in accordance with Table 7.

**Table 7 Materials for sealing the remaining cross-section of the wall opening**








No.	Description/dimensions	Requirements regarding the material/reaction to fire of the components used	Annex ETA
1	<b>Gypsum mortar/bonding plaster</b>	EN 13279-1 Reaction to fire class A1 in accordance with EN 13501-1	25 and 26
3	<b>Cement mortar</b>	EN 998-1 or EN 998-2 Reaction to fire class at least A1 in accordance with Decision 96/603/EC	25 and 26
4	<b>Mineral wool</b>	Insulation wool made of molten rock in accordance with EN 13162 Apparent density $\geq 100 \text{ kg/m}^3$ , melting point $> 1000 \text{ }^\circ\text{C}^*$ Reaction to fire class A1 in accordance with EN 13501-1**	25 and 26
*	to be verified by testing in accordance with DIN 4102-17		
**	There is currently no possibility of declaring the characteristic 'propensity to undergo continuous smouldering' in declarations of performance for products in accordance with EN 13162. As long as the amendment of the standard is outstanding, the requirements relating to this characteristic applicable at the location where the kit is used shall be observed.		

## 2.6 Sealing of the remaining cross-section of the cable inlet or outlet and of the duct reducer piece with mineral wool in accordance with Annex 20, Section 2.3

Within the framework of the ETA, the sealing of the remaining cross-section of the cable inlet or outlet and/or duct reducer piece in accordance with Annex 20, Section 2.3 with mineral wool in accordance with EN 13162, apparent density  $\geq 100 \text{ kg/m}^3$ , melting point  $> 1000 \text{ }^\circ\text{C}^*$ , resistance to fire class A1 in accordance with EN 13501-1\*\* was verified. The provisions regarding the melting point and the 'propensity to undergo continuous smouldering' in accordance with Table 7, No. 4 shall be observed.

System FWK Plus	Annex 22
Performance of the electrical service duct Resistance to fire Sealing of remaining cross-section of wall opening	

1-7 approved installation types



A = max. 50 mm  
B = max. 1500 mm


Values for A and B valid for  
Installation types 4-7

- 1 - Rigid wall and ceilings according to Annex 20, paragraph 2.2. Structure and thickness according to static requirements and the respective required fire resistance duration.
- 2 - Fasteners, dimensioning according to Annex 20, paragraph 2.4.  
- Fastening distances according to Annex 21 and 27.
- 3 - Duct made of connecting pieces according to annexes 3, 8 to 11, 13, 14.  
- Dimensions depending on the area of application, configuration according to appendix 20.  
- Fix the duct to the C-rail with M8 screws and connectors according to Annex 7.
- 4-7 - Support system: Cantilever, ceiling hanger, C-profile rail, threaded rod, connectors and connecting elements according to Annex 7

System FWK Plus

Performance of the electrical service duct:  
Fire resistance  
Installation types

Annex 23




- ① Separation wall depending on the required fire resistance class EI30, EI60 Structure according to Annex 19, paragraph 2.2
- ② Rigid wall depending on the required fire resistance class EI30, EI60 Structure according to Annex 19, paragraph 2.2
- ③ Connecting pieces according to Annexes 3 and 8 to 11  
Dimensions depending on the area of application  
Configuration according to Annex 20
- ④ Suspension according to Annex 7 and Annexes 20 and 21, paragraph 2.4  
Fixing with suitable anchors according to ETB according to Annex 20, paragraph 2.4
- ⑤ Wall connection piece according to Annex 12  
Fixing with suitable anchors according to ETB according to Annex 20, paragraph 2.4

System FWK Plus

Performance of the installed electrical service duct:  
Fire resistance  
Installation in walls, fire resistance class EI30, EI60 - Butt joint -

Annex 24




- ① Separation wall depending on the required fire resistance class EI30 to EI90 Structure according to Annex 19, paragraph 2.2
- ② Rigid wall depending on the required fire resistance class EI30 to EI90 Structure according to Annex 19, paragraph 2.2
- ③ Connecting pieces according to Annexes 3 and 8 to 11  
Dimensions depending on the area of application  
Configuration according to Annex 20
- ④ Suspension according to Annex 7 and Annexes 20 and 21, paragraph 2.4  
Fixing with suitable anchors according to ETB according to Annex 20, paragraph 2.4
- ⑤ Wall connection piece according to Annex 12  
Fixing with suitable anchors according to ETB according to Annex 20, paragraph 2.4
- ⑥ Closure with:
  - Fire protection mortar or fire protection foam according to Annex 5
  - Gypsum mortar, gypsum plaster, mineral wool according to Annex 22

System FWK Plus

Performance of the installed electrical service duct:  
Fire resistance  
Installation in walls, fire resistance class EI30 to EI90 - Separated -

Annex 25



- ① Separation wall depending on the required fire resistance class EI30 to EI90 Structure according to Annex 19, paragraph 2.2
- ② Rigid wall depending on the required fire resistance class EI30 to EI90 Structure according to Annex 19, paragraph 2.2
- ③ Connecting pieces according to Annexes 3 and 8 to 11  
Dimensions depending on the area of application  
Configuration according to Annex 20
- ④ Suspension according to Annex 7 and Annexes 20 and 21, paragraph 2.4  
Fixing with suitable anchors according to ETB according to Annex 20, paragraph 2.4
- ⑤ Wall connection piece according to Annex 12  
Fixing with suitable anchors according to ETB according to Annex 20, paragraph 2.4
- ⑥ Closure with:
  - Fire protection mortar or fire protection foam according to Annex 5
  - Gypsum mortar, gypsum plaster, mineral wool according to Annex 22

System FWK Plus

Performance of the installed electrical service duct:  
Fire resistance  
Installation in walls, fire resistance class EI30 to EI90 - Continuous -

Annex 26

		Direct mounting			Suspended mounting			
		Wall	Ceiling	Floor	Cross beam		Cantiveler	
					hanging	overlying		
Numbering according to Annex 23		①	②	③	④	⑤	⑥	⑦
Max. Fastening distance [mm]		500		1500	1200	1500		
Fitting part length [mm]		100 to 3000						
Wall opening	Wall opening $\nabla$	1		<b>EI 60 h<sub>o</sub> i↔o</b>				
	Duct cross-section	2						
	Duct cross-section	3						
		<p>Filling of remaining cross-section of wall opening with:</p> <ul style="list-style-type: none"> <li>&gt; Fire protection mortar according to Annex 5</li> <li>&gt; Mineral wool (Melting point &gt; 1000 °C, Density &gt; 100 kg/m<sup>2</sup>) according to Annex 22</li> <li>&gt; Fire protection foam and fitting piece according to Annex 5</li> <li>&gt; Gypsum / cement according to Annex 22</li> </ul>						
Cable outlet	Open shaped part end		<p>Cable outlet according to Annex 15:</p> <ul style="list-style-type: none"> <li>&gt; Maximum cable diameter: 58 mm</li> <li>&gt; Filling of remaining cross-section with fire protection mortar/bag/foam and shaped piece/plug, mineral wool (depth &gt; 100 mm)</li> </ul>					
	Cable gland		<p>Cable outlet according to Annex 16:</p> <ul style="list-style-type: none"> <li>&gt; Material cable gland: PA6 or brass</li> <li>&gt; Maximum size of cable gland: M63, maximum cable diameter: 40 mm</li> </ul>					
	Cable grommet		<p>Cable outlet according to Annex 16:</p> <ul style="list-style-type: none"> <li>&gt; Maximum cable diameter: 16 mm</li> </ul>					
	Gypsum fibreboard + Foamcoat		<p>Cable outlet according to Annex 17:</p> <ul style="list-style-type: none"> <li>&gt; Max. cut-out in duct/gypsum fibreboard [HxW]: 55 x 150 mm</li> <li>&gt; Gypsum fibreboard thickness: &gt; 18 mm , maximum cable diameter: 40 mm</li> </ul>					
System FWK Plus							Annex 27	
Classification overview + cable outlet								

**Standards**

EN 13501-1:2018-12	Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests
EN 13501-2:2016-12	Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services
EN 1363-1:2012-10	Fire resistance tests - Part 1: General requirements
EN 1366-5:2010-06	Fire resistance tests for service installations - Part 5: Service ducts and shafts
EN 13823:2015-02	Reaction to fire tests for building products - Building products excluding floorings exposed to the thermal attack by a single burning item
EN 16733:2016	Reaction to fire tests for building products - Determination of a building product's propensity to undergo continuous smouldering
EN 13162:2015-04	Thermal insulation products for buildings - Factory made mineral wool (MW) products - Specification
EN 10088-2:2014-12	Stainless steels - Part 2: Technical delivery conditions for sheet/plate and strip of corrosion resisting steels for general purposes
EN 10143:2006-09	Continuously hot-dip coated steel sheet and strip - Tolerances on dimensions and shape
EN 10346:2015-10	Continuously hot-dip coated steel flat products for cold forming - Technical delivery conditions
EN 10111 :2008-06	Continuously hot rolled low carbon steel sheet and strip for cold forming - Technical delivery conditions
EN 10130:2007-02	Cold rolled low carbon steel flat products for cold forming - Technical delivery conditions
EN ISO 225:2011-02	Fasteners - Bolts, screws, studs and nuts - Symbols and descriptions of dimensions
EN ISO 898-1:2013-05	Mechanical properties of fasteners made of carbon steel and alloy steel - Part 1: Bolts, screws and studs with specified property classes - Coarse thread and fine pitch thread
EN ISO 898-2:2012-08	Mechanical properties of fasteners made of carbon steel and alloy steel - Part 2: Nuts with specified property classes - Coarse thread and fine pitch thread
EN ISO 7093-1:2000-01	Plain washers - Large series - Part 1: Product grade A
EN ISO 4759-3:2016-12	Tolerances for fasteners - Part 3: Washers for bolts, screws and nuts - Product grades A, C and F
ISO 4032:2012-12	Hexagon regular nuts (style 1) - Product grades A and B
ISO 7380-2:2011-08	Button head screws - Part 2: Hexagon socket button head screws with collar
EN 15283-2:2009-12	Gypsum boards with fibrous reinforcement - Definitions, requirements and test methods - Part 2: Gypsum fibre boards
EN 60423:2008-07	Conduit systems for cable management - Outside diameters of conduits for electrical installations and threads for conduits and fittings
EN 62444:2014-05	Cable glands for electrical installations
EN 13279-1:2008-11	Gypsum binders and gypsum plasters - Part 1: Definitions and requirements
EN 998-1:2017-02	Specification for mortar for masonry - Part 1: Rendering and plastering mortar
EN 998-2:2017-02	Specification for mortar for masonry - Part 2: Masonry mortar

System FWK Plus

List of documents referred to – Part 1

Annex 28

**Other documents**

Decision 96/603/EC	Decision of the European Commission on the establishment of a list of products to be classified in category A "No contribution to fire" in accordance with Decision 94/611/EC implementing Article 20 of Council Directive 89/106/EEC on construction products amended by decision 2000/605/EG and by decision 2003/424 / EG
EAD 350003-01-1109	Kit for fire resistant service ducts consisting of pre-fabricated connection pieces (made of steel sheet with an intumescent coating or lining) and accessories
TR 034	General BWR3 Checklist for EADs/ETAs - Dangerous substances, (October 2015)

System FWK Plus

List of documents referred to - Part 2

Annex 29